


VENTILATION AUDIT REPORT

SCHOOL:	Tullimbar Public School (4649)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Kiama
LOCAL GOVERNMENT AREA:	Shellharbour

4649 - Tullimbar Public School
Site Plan (14726)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (16.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0001 - Entry Vestibule - (16.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Sick Bay - (8.83 SQM)	● Student Space (4)	
B00A - R0005 - Principal - (16.84 SQM)	● Office (4)	
B00A - R0006 - Interview - (12.81 SQM)	● Office (3)	
B00A - R0007 - Deputy Principal - (16.17 SQM)	● Office (4)	
B00A - R0008 - Staff Room - (38.74 SQM)	● Office (9)	
B00A - R0009 - Staff Room Annexe - (18.65 SQM)	● Office (4)	
B00A - R0010 - Movement - (37.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Interview/Office - Type 3 - (16.76 SQM)	● Office (4)	
B00A - R0018 - Clerical Office - (28.68 SQM)	● Office (7)	
B00A - R0019 - Duplicating Workroom - (22.77 SQM)	● Office (5)	
B00A - R0020 - Staff Kitchen - (9.24 SQM)	● Office (2)	
B00B - R0001 - Communal Space - (147.65 SQM)	● Student Space (68)	
B00B - R0002 - Raised Platform - (55.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (16.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Canteen - (29.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Reading Area - (150.09 SQM)	● Student Space (69)	
B00D - R0009 - Special Programs Room - (36.52 SQM)	● Student Space (16)	
B00D - R0011 - Practical Activities - 1hb - (19.3 SQM)	● Student Space (8)	
B00D - R0012 - Home Base - (60.75 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0013 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00D - R0014 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00D - R0016 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0019 - Practical Activities - 1hb - (18.85 SQM)	● Student Space (8)	
B00D - R0020 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0021 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00D - R0022 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0023 - Practical Activities - 1hb - (19.3 SQM)	● Student Space (8)	
B00E - R0009 - Practical Activities - 1hb - (19.26 SQM)	● Student Space (8)	
B00E - R0010 - Home Base - (60.54 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0011 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00E - R0012 - Home Base - (55.95 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0013 - Practical Activities - 1hb - (20.05 SQM)	● Student Space (9)	
B00F - R0001 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0003 - Practical Activities - 1hb - (19.33 SQM)	● Student Space (8)	
B00F - R0004 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00F - R0005 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0006 - Practical Activities - 1hb - (18.66 SQM)	● Student Space (8)	
B00F - R0009 - Practical Activities - 1hb - (18.6 SQM)	● Student Space (8)	
B00F - R0010 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0011 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00F - R0012 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0013 - Practical Activities - 1hb - (18.85 SQM)	● Student Space (8)	
B00F - R0016 - Practical Activities - M - 1hb - (18.68 SQM)	● Student Space (8)	
B00F - R0017 - Home Base - M - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0018 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00F - R0019 - Home Base - M - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0020 - Practical Activities - M - 1hb - (19.3 SQM)	● Student Space (8)	
B00F - R0025 - Movement - (7.67 SQM)	Not Applicable	Circulation or storage space.