


VENTILATION AUDIT REPORT

SCHOOL:	Tumbarumba Public School (3275)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Albury
LOCAL GOVERNMENT AREA:	Snowy Valleys



3275 - Tumbarumba Public School
Site Plan (12882)



1:933

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (47.55 SQM)	Office (11)	
B00A - R0003 - Home Base - (47.67 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0014 - Movement - (41.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Clerical Office - (39.99 SQM)	Office (9)	
B00A - R0017 - Sick Bay - (7.02 SQM)	Student Space (3)	
B00A - R0018 - Principal - (18.97 SQM)	Office (4)	
B00A - R0019 - Movement - (11.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Canteen - (22.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (11.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (25.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - Home Base - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0001 - Home Base - (52.48 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Special Programs Room - (52.48 SQM)	Student Space (24)	
B00D - R0003 - Movement - (27.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Withdrawal Space - 1hb - (23.32 SQM)	Student Space (10)	
B00E - R0002 - Movement - (9.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Reading Area - (52.13 SQM)	Student Space (24)	
B00F - R0002 - Reading Area - (51.9 SQM)	Student Space (24)	
B00F - R0003 - Reading Area - (29.2 SQM)	Student Space (13)	
B00G - R0004 - Movement - (24.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (18.93 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Communal Space - (20.44 SQM)	Student Space (9)	
B00J - R0001 - Movement - (35.44 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Communal Space - (80.29 SQM)	Student Space (37)	
B00J - R0004 - Raised Platform - (21.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Home Base - (85.18 SQM) - Teaching Space: 1	Student Space (39)	
B00K - R0006 - Home Base - (57.97 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0009 - Home Base - (57.5 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0013 - Home Base - (57.73 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0014 - Movement - (5.16 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Movement - (20.63 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Staff Room - (15.21 SQM)	Office (3)	
B00K - R0020 - Staff Room Annexe - (10.72 SQM)	Office (2)	
B00K - R0022 - Movement - (78.31 SQM)	Not Applicable	Circulation or storage space.
B00K - R0023 - Movement - (13.51 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Home Base - (63.55 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R0003 - Home Base - (63.1 SQM) - Teaching Space: 1	Student Space (29)	
B00N - R0001 - Raised Platform - (61.01 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Communal Space - (146.94 SQM)	Student Space (68)	
B00N - R0015 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00N - R0016 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Movement - (10.52 SQM)	Not Applicable	Circulation or storage space.