

VENTILATION AUDIT REPORT

SCHOOL:	Turrumurra North Public School (3288)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ku-Ring-Gai
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

3288 - Turrumurra North Public School
Site Plan (10781)




1:950

Printed: 31-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (13.21 SQM)	● Student Space (6)	
B00A - R0004 - Special Programs Room - (42.3 SQM)	● Student Space (19)	
B00A - R0011 - Movement - (10.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Reading Area - (184.35 SQM) - Teaching Space: 3	● Student Space (85)	
B00A - R0019 - Seminar/Study - (8.56 SQM)	● Office (2)	
B00A - R0020 - Seminar/Study - (8.56 SQM)	● Office (2)	
B00A - R0023 - Special Programs Room - (31.32 SQM)	● Student Space (14)	
B00A - R1009 - Movement - (37.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Home Base - (55.41 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1012 - Practical Activities - 2hb - (8.48 SQM)	● Student Space (3)	
B00A - R1013 - Withdrawal Space - 2hb - (7.3 SQM)	● Student Space (3)	
B00A - R1015 - Home Base - (55.25 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0002 - Communal Space - (165.24 SQM)	● Student Space (76)	
B00B - R0005 - Raised Platform - (38.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Canteen - (32.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (27.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Duplicating Workroom - (14.26 SQM)	● Office (3)	
B00C - R0014 - Principal - (28.65 SQM)	● Office (7)	
B00C - R0015 - Movement - (11.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Entry Vestibule - (19.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Clerical Office - (29.41 SQM)	● Office (7)	
B00C - R0020 - Sick Bay - (10.23 SQM)	● Student Space (4)	
B00D - R0001 - Staff Room - (57.31 SQM)	● Office (14)	
B00D - R0006 - Movement - (11.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Practical Activities - 1hb - (16.88 SQM)	● Student Space (7)	
B00D - R0025 - Home Base - (66.93 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0026 - Practical Activities - 1hb - (14.74 SQM)	● Student Space (6)	
B00D - R0027 - Withdrawal Space - 2hb - (13.6 SQM)	● Student Space (6)	
B00D - R0030 - Practical Activities - 1hb - (18.29 SQM)	● Student Space (8)	
B00D - R0031 - Home Base - (67.05 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0001 - Home Base - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0004 - Movement - (9.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (57.1 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0010 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Interview - (15.43 SQM)	● Office (3)	
B00F - R0003 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Practical Activities - 1hb - (13.91 SQM)	● Student Space (6)	
B00F - R0007 - Home Base - (85.86 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0008 - Home Base - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0009 - Practical Activities - 1hb - (14.52 SQM)	● Student Space (6)	
B00F - R0012 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (46.87 SQM)	● Student Space (21)	
B00G - R0003 - Practical Activities - 1hb - (5.17 SQM)	● Student Space (2)	
B00I - R0010 - Home Base - (57.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0013 - Home Base - (73.98 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0002 - Practical Activities/Movement - 1hb - (19.85 SQM)	● Student Space (9)	
B00J - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	● Student Space (4)	
B00J - R0008 - Practical Activities/Movement - 1hb - (19.85 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 10214 - OS 602 10214 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	