


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Turrumurra Public School (3855)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Ku-Ring-Gai</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Ku-Ring-Gai</b>

3855 - Turrumurra Public School  
Site Plan (11349)



1:1,348

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Interview - (12.22 SQM)	Office (3)	
B00A - R0008 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (57.45 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0012 - Staff Room Annexe - (8.35 SQM)	Office (2)	
B00A - R0013 - Home Base - (56.62 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0014 - Special Programs Room - (8.01 SQM)	Student Space (3)	
B00A - R0015 - Home Base - (76.86 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R9004 - Canteen - (24.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (8.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Deputy Principal - (16.03 SQM)	Office (4)	
B00B - R0009 - Movement - (11.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0017 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0023 - Practical Activities - (7.96 SQM)	Student Space (3)	
B00B - R0024 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0026 - Staff Room - (14.97 SQM)	Office (3)	
B00C - R0004 - Home Base - (85.36 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0005 - Home Base - (84.89 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0012 - Home Base - (86.15 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0013 - Home Base - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Clerical Office - (13.55 SQM)	Office (3)	
B00D - R0002 - Principal - (19.07 SQM)	Office (4)	
B00D - R0011 - Staff Room Annexe - (19.52 SQM)	Office (4)	
B00D - R0012 - Duplicating Workroom - (13.7 SQM)	Office (3)	
B00D - R0013 - Entry Vestibule - (13.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Interview - (21.61 SQM)	Office (5)	
B00E - R0005 - Staff Room - (56.78 SQM)	Office (14)	
B00E - R0008 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0012 - Home Base - (57.4 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0015 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0019 - Movement - (326.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (55.73 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0006 - Movement - (10.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (12.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Home Base - (55.66 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R1001 - Home Base - (55.65 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R1004 - Movement - (12.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - Home Base - (55.81 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R9001 - Movement - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R9004 - Canteen - (19.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (46.74 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0006 - Home Base - (46.74 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0007 - Home Base - (46.74 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0011 - Movement - (59.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (55.42 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0006 - Home Base - (54.28 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0012 - Home Base - (55.04 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0013 - Home Base - (54.88 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0017 - Staff Room Annexe - (18.23 SQM)	○ Office (4)	
B00H - R0026 - Staff Kitchen - (10.37 SQM)	○ Office (2)	
B00H - R0027 - Staff Room - (55.64 SQM)	○ Office (13)	
B00I - R0004 - Movement - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00I - R0013 - Entry Vestibule - (26.14 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Clerical Office - (26.57 SQM)	○ Office (6)	
B00I - R0015 - Duplicating Workroom - (23.63 SQM)	○ Office (5)	
B00I - R0016 - Movement - (23.53 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Staff Kitchen - (6.48 SQM)	○ Office (1)	
B00I - R0019 - Principal - (19.59 SQM)	○ Office (4)	
B00I - R0020 - Clerical Office - (18.88 SQM)	○ Office (4)	
B00I - R0021 - Sick Bay - (9.52 SQM)	● Student Space (4)	
B00I - R0022 - Interview/Office - Type 3 - (17.36 SQM)	○ Office (4)	
B00I - R0023 - Interview - (14.14 SQM)	○ Office (3)	
B00I - R0024 - Deputy Principal - (12.62 SQM)	○ Office (3)	
B00I - R0026 - Home Base - (67.74 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0001 - Movement - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Communal Space - (217.12 SQM)	● Student Space (100)	
B00J - R0003 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Raised Platform - (48.14 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00J - R0014 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00J - R9002 - Withdrawal Space - 1hb - (59.08 SQM)	● Student Space (27)	
B00O - R0001 - Reading Area - (222.19 SQM)	● Student Space (103)	
B00O - R0012 - Special Programs Room - (14.57 SQM)	● Student Space (6)	
B00O - R0013 - Special Programs Room - (16.17 SQM)	● Student Space (7)	