

VENTILATION AUDIT REPORT

SCHOOL:	Tweed Heads Public School (3290)
AMU REGION:	North Coast
STATE ELECTORATE:	Tweed
LOCAL GOVERNMENT AREA:	Tweed

3290 - Tweed Heads Public School
Site Plan (11497)



1:699

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office/Workroom - (27.12 SQM)	Office (6)	
B00A - R0006 - Principal - (13.29 SQM)	Office (3)	
B00A - R0008 - Entry Vestibule - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (11.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office - (21.53 SQM)	Office (5)	
B00A - R0012 - Sick Bay - (8.53 SQM)	Student Space (3)	
B00B - R0001 - Staff Room Annexe - (13.92 SQM)	Office (3)	
B00B - R0002 - Home Base - (63.14 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0004 - Staff Room Annexe - (16.41 SQM)	Office (4)	
B00B - R0006 - Movement - (8.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (25.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Staff Room - (42.45 SQM)	Office (10)	
B00B - R0012 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Staff Room - (34.84 SQM)	Office (8)	
B00B - R1001 - Movement - (9.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Raised Platform - (19.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Communal Space - (121.24 SQM)	Student Space (56)	
B00B - R1005 - Practical Activities - 1hb - (82.13 SQM)	Student Space (38)	
B00B - R1006 - Home Base - (47.79 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1007 - Home Base - (47.48 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1009 - Home Base - (42.9 SQM) - Teaching Space: 1	Student Space (19)	
B00B - R1010 - Home Base - (54.29 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1014 - Reading Area - (129.82 SQM)	Student Space (60)	
B00C - R0004 - Canteen - (55.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (27.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (52.05 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0003 - Practical Activities - 1hb - (9.08 SQM)	Student Space (4)	
B00D - R0004 - Practical Activities - 1hb - (17.59 SQM)	Student Space (8)	
B00D - R0005 - Home Base - (52.05 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0001 - Home Base - (51.99 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0002 - Practical Activities - 1hb - (10.79 SQM)	Student Space (5)	
B00G - R0003 - Interview - (11.22 SQM)	Office (2)	
B00G - R0004 - Staff Room Annexe - (5.49 SQM)	Office (1)	
B00G - R0005 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (17.86 SQM)	Student Space (8)	
B00H - R0003 - Home Base - (47.79 SQM) - Teaching Space: 1	Student Space (22)	
B00I - R0001 - Movement - (29.83 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (63.02 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Home Base - (41.83 SQM) - Teaching Space: 1	Student Space (19)	
B00J - R0003 - Practical Activities - 1hb - (24.35 SQM)	Student Space (11)	
B00J - R0004 - Home Base - (41.88 SQM) - Teaching Space: 1	Student Space (19)	
B00J - R1001 - Staff Room Annexe - (6.3 SQM)	Office (1)	
B00J - R1002 - Home Base - (50.29 SQM) - Teaching Space: 1	Student Space (23)	
B00J - R1005 - Home Base - (57.83 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0001 - Home Base - (74.84 SQM) - Teaching Space: 1	Student Space (34)	
B00K - R0002 - Practical Activities - 1hb - (5.88 SQM)	Student Space (2)	
B00L - R0001 - Communal Space - (153.43 SQM)	Student Space (71)	
B00L - R0002 - Raised Platform - (60.04 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (11.89 SQM)	Not Applicable	Circulation or storage space.