

VENTILATION AUDIT REPORT

SCHOOL:	Tyalla Public School (4503)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

4503 - Tyalla Public School
Site Plan (11740)



1:1,711

Printed: 23-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (107.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Home Base - (70.96 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0004 - Practical Activities - 1hb - (23.92 SQM)	● Student Space (11)	
B00A - R0005 - Home Base - (71.06 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0006 - Withdrawal Space - 1hb - (11.68 SQM)	● Student Space (5)	
B00A - R0008 - Home Base - (70.57 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0010 - Practical Activities - 1hb - (12 SQM)	● Student Space (5)	
B00A - R0011 - Clerical Office/Workroom - (11.91 SQM)	● Office (2)	
B00A - R0012 - Practical Activities - 1hb - (16.48 SQM)	● Student Space (7)	
B00A - R0013 - Home Base - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0014 - Home Base - (53.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0015 - Practical Activities - 1hb - (16.02 SQM)	● Student Space (7)	
B00A - R0016 - Home Base - (56.57 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0017 - Practical Activities - 1hb - (16.54 SQM)	● Student Space (7)	
B00A - R0023 - Movement - (16.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (10.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (10.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (103.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Home Base - (55.26 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1003 - Practical Activities - 1hb - (24.36 SQM)	● Student Space (11)	
B00A - R1004 - Home Base - (55.97 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1005 - Home Base - (55.97 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1006 - Practical Activities - 1hb - (24.29 SQM)	● Student Space (11)	
B00A - R1007 - Home Base - (55.33 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1011 - Movement - (16.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Movement - (7.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Deputy Principal - (12.31 SQM)	● Office (3)	
B00B - R0002 - Movement - (20.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Principal - (20.48 SQM)	● Office (5)	
B00B - R0004 - Duplicating Workroom - (12.27 SQM)	● Office (3)	
B00B - R0005 - Clerical Office - (12.66 SQM)	● Office (3)	
B00B - R0006 - Entry Vestibule - (23.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Sick Bay - (8.75 SQM)	● Student Space (4)	
B00B - R0009 - Deputy Principal - (12.66 SQM)	● Office (3)	
B00B - R0010 - Interview - (12.44 SQM)	● Office (3)	
B00B - R0011 - Movement - (20.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Staff Room - (91.66 SQM)	● Office (22)	
B00B - R0014 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (116.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (38.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (44.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Seminar/Study - (14.25 SQM)	● Office (3)	
B00B - R1006 - Reading Area - (259.26 SQM)	● Student Space (120)	
B00B - R1008 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Movement - (32.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Movement - (40.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (60.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Communal Space - (242.59 SQM)	● Student Space (112)	
B00C - R0003 - Raised Platform - (28.3 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0005 - Movement - (44.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Canteen - (42.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (16.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (9.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (58.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Movement - (26.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Practical Activities - 1hb - (27.46 SQM)	● Student Space (12)	
B00C - R1005 - Home Base - (55.75 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1006 - Home Base - (55.74 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0010 - Movement - (16.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Clerical Office/Workroom - (16.69 SQM)	● Office (4)	
B00E - R0002 - Movement - (48.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (56.47 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0004 - Practical Activities - 1hb - (24.35 SQM)	● Student Space (11)	
B00E - R0005 - Home Base - (56.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0006 - Home Base - (58.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0007 - Practical Activities - 1hb - (16.09 SQM)	● Student Space (7)	
B00E - R0010 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (48.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Home Base - (55.41 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R1003 - Practical Activities - 1hb - (24.32 SQM)	● Student Space (11)	
B00E - R1004 - Home Base - (56.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R1005 - Home Base - (58.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1006 - Practical Activities - 1hb - (16.17 SQM)	● Student Space (7)	
B00F - R0002 - Practical Activities - 1hb - (24.28 SQM)	● Student Space (11)	
B00F - R0003 - Home Base - (55.76 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0004 - Home Base - (55.57 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0005 - Home Base - (57.29 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0006 - Practical Activities - 1hb - (16.48 SQM)	● Student Space (7)	
B00F - R0009 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (55.29 SQM)	Not Applicable	Circulation or storage space.