


VENTILATION AUDIT REPORT

SCHOOL:	Uki Public School (3298)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Tweed

3298 - Uki Public School
Site Plan (11518)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Home Base - (56 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0006 - Practical Activities - 1hb - (6.07 SQM)	Student Space (2)	
B00A - R0012 - Special Programs Room - (71.67 SQM)	Student Space (33)	
B00B - R0001 - Staff Room - (43.94 SQM)	Office (10)	
B00B - R0011 - Duplicating Workroom - (10.99 SQM)	Office (2)	
B00B - R0012 - Sick Bay - (10.87 SQM)	Student Space (5)	
B00B - R0013 - Clerical Office - (21.58 SQM)	Office (5)	
B00B - R0015 - Deputy Principal - (11.81 SQM)	Office (2)	
B00B - R0019 - Principal - (14.42 SQM)	Office (3)	
B00B - R0020 - Interview - (8.65 SQM)	Office (2)	
B00B - R0021 - Movement - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Practical Activities - 1hb - (18.68 SQM)	Student Space (8)	
B00C - R0005 - Withdrawal Space - 1hb - (5.96 SQM)	Student Space (2)	
B00C - R0006 - Home Base - (61.13 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0007 - Practical Activities - 1hb - (18.67 SQM)	Student Space (8)	
B00C - R0008 - Home Base - (61.05 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0010 - Withdrawal Space - 1hb - (6.51 SQM)	Student Space (3)	
B00E - R0003 - Practical Activities - 1hb - (18.7 SQM)	Student Space (8)	
B00E - R0005 - Withdrawal Space - 1hb - (5.97 SQM)	Student Space (2)	
B00E - R0006 - Home Base - (61.28 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0007 - Practical Activities - 1hb - (18.68 SQM)	Student Space (8)	
B00E - R0008 - Home Base - (61.19 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0010 - Withdrawal Space - 1hb - (6.54 SQM)	Student Space (3)	
B00G - R0003 - Practical Activities - 1hb - (26.14 SQM)	Student Space (12)	
B00G - R0005 - Withdrawal Space - 1hb - (5.91 SQM)	Student Space (2)	
B00G - R0006 - Home Base - (51.48 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0007 - Home Base - (51.32 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0008 - Withdrawal Space - 1hb - (5.95 SQM)	Student Space (2)	
B00G - R0010 - Practical Activities - 1hb - (25.72 SQM)	Student Space (11)	
B00G - R0011 - Practical Activities - 1hb - (25.82 SQM)	Student Space (11)	
B00G - R0013 - Withdrawal Space - 1hb - (5.98 SQM)	Student Space (2)	
B00G - R0014 - Home Base - (51.32 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0015 - Home Base - (51.18 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0016 - Withdrawal Space - 1hb - (5.96 SQM)	Student Space (2)	
B00G - R0018 - Practical Activities - 1hb - (26.08 SQM)	Student Space (12)	
B00H - R0002 - Special Programs Room - Type 1 - (69.25 SQM)	Student Space (32)	
B00H - R0004 - Special Programs Room - Type 1 - (63.16 SQM)	Student Space (29)	
B00I - R0002 - Reading Area - (91.76 SQM)	Student Space (42)	
B00J - R0001 - Canteen - (29.32 SQM)	Not Applicable	Circulation or storage space.