


VENTILATION AUDIT REPORT

SCHOOL:	Ulladulla Public School (3302)
AMU REGION:	Southern NSW
STATE ELECTORATE:	South Coast
LOCAL GOVERNMENT AREA:	Shoalhaven

3302 - Ulladulla Public School
Site Plan (11843)



1:1,329

Printed: 31-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0004 - Practical Activities - 1hb - (21.75 SQM)	● Student Space (10)	
B001 - R0005 - Home Base - (51.46 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0006 - Home Base - (59.59 SQM) - Teaching Space: 1	● Student Space (27)	
B001 - R0007 - Practical Activities - 1hb - (13.79 SQM)	● Student Space (6)	
B001 - R0009 - Practical Activities - 1hb - (21.78 SQM)	● Student Space (10)	
B001 - R0010 - Home Base - (51.69 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0011 - Home Base - (51.09 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0012 - Practical Activities - 1hb - (21.88 SQM)	● Student Space (10)	
B001 - R0015 - Movement - (164.84 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Practical Activities - 1hb - (21.85 SQM)	● Student Space (10)	
B002 - R0002 - Home Base - (51.52 SQM) - Teaching Space: 1	● Student Space (23)	
B002 - R0003 - Home Base - (51.53 SQM) - Teaching Space: 1	● Student Space (23)	
B002 - R0004 - Practical Activities - 1hb - (21.86 SQM)	● Student Space (10)	
B002 - R0005 - Home Base - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R0006 - Practical Activities - 1hb - (21.77 SQM)	● Student Space (10)	
B002 - R0008 - Practical Activities - 1hb - (21.73 SQM)	● Student Space (10)	
B002 - R0009 - Home Base - (52.22 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R0010 - Practical Activities - 1hb - (21.89 SQM)	● Student Space (10)	
B002 - R0011 - Home Base - (51.48 SQM) - Teaching Space: 1	● Student Space (23)	
B002 - R0012 - Home Base - (51.4 SQM) - Teaching Space: 1	● Student Space (23)	
B002 - R0013 - Practical Activities - 1hb - (16.63 SQM)	● Student Space (7)	
B002 - R0014 - Withdrawal Space - 1hb - (5.07 SQM)	● Student Space (2)	
B002 - R0016 - Movement - (51.26 SQM)	Not Applicable	Circulation or storage space.
B002 - R0017 - Movement - (88.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0001 - Movement - (9.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Duplicating Workroom - (22.03 SQM)	● Office (5)	
B00A - R0004 - Movement - (24.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Deputy Principal - (14.57 SQM)	● Office (3)	
B00A - R0006 - Principal - (19.02 SQM)	● Office (4)	
B00A - R0010 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Sick Bay - (11.83 SQM)	● Student Space (5)	
B00A - R0017 - Deputy Principal - (15.04 SQM)	● Office (3)	
B00A - R0019 - Movement - (13.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (9.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Clerical Office/Workroom - (19.98 SQM)	● Office (4)	
B00A - R0023 - Entry Vestibule - (18.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Withdrawal Space - 1hb - (16.42 SQM)	● Student Space (7)	
B00B - R0003 - Staff Room Annexe - (8.75 SQM)	● Office (2)	
B00B - R0004 - Staff Room Annexe - (12.48 SQM)	● Office (3)	
B00B - R0005 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Reading Area - (224.01 SQM)	● Student Space (103)	
B00C - R0005 - Special Programs Room - (42.65 SQM)	● Student Space (19)	
B00C - R1001 - Staff Room Annexe - (25.04 SQM)	● Office (6)	
B00C - R1002 - Interview - (17.19 SQM)	● Office (4)	
B00C - R1004 - Movement - (18.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R1009 - Staff Room - (63.3 SQM)	● Office (15)	
B00D - R0001 - Canteen - (45.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (266.32 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0010 - Movement - (26.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (23.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Raised Platform - (44.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Communal Space - (201.17 SQM)	● Student Space (93)	
B00D - R0022 - Movement - (43.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (35.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (5.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (66.96 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0003 - Special Programs Room - (52.54 SQM)	● Student Space (24)	
B00F - R0004 - Home Base - (52.54 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0006 - Withdrawal Space - 1hb - (5.51 SQM)	● Student Space (2)	
B00F - R0008 - Staff Room Annexe - (12.65 SQM)	● Office (3)	
B00F - R0012 - Practical Activities/Movement - 4hb - (15.77 SQM)	● Student Space (7)	
B00G - R0001 - Home Base - (58.29 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0004 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (58.29 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0010 - Home Base - (58.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R9004 - Staff Room - (46.91 SQM)	● Office (11)	
B00H - R0001 - Home Base - (56.8 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0004 - Movement - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - (19.2 SQM)	● Student Space (8)	
B00K - R0003 - Home Base - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00K - R0006 - Home Base - (61.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0007 - Practical Activities - (20.31 SQM)	● Student Space (9)	
B00K - R0009 - Practical Activities - (20.31 SQM)	● Student Space (9)	
B00K - R0011 - Home Base - (61.24 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0012 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00K - R0013 - Home Base - (61.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0014 - Practical Activities - (20.31 SQM)	● Student Space (9)	
B00K - R0016 - Practical Activities - (20.31 SQM)	● Student Space (9)	
B00K - R0018 - Home Base - (61.24 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0019 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00K - R0020 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0021 - Practical Activities - (20.06 SQM)	● Student Space (9)	
OS 601 10444 - OS 601 10444 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12499 - OS 601 12499 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14114 - OS 601 14114 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14486 - OS 601 14486 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 13142 - OS 602 13142 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13638 - OS 602 13638 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13768 - OS 602 13768 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14397 - OS 602 14397 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15660 - OS 602 15660 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18360 - OS 602 18360 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 12141 - OS 603 12141 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	