

VENTILATION AUDIT REPORT



















SCHOOL:	Ulmarra Public School (3303)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Clarence Valley

3303 - Ulmarra Public School
Site Plan (11711)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Home Base - (47.99 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0004 - Practical Activities - 1hb - (74.08 SQM)	 Student Space (34)	
B00A - R0005 - Home Base - (47.92 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0007 - Withdrawal Space - 1hb - (11.09 SQM)	 Student Space (5)	
B00A - R0008 - Withdrawal Space - 1hb - (16.04 SQM)	 Student Space (7)	
B00A - R0009 - Home Base - (48.05 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0010 - Home Base - (47.86 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0001 - Practical Activities - 1hb - (17.29 SQM)	 Student Space (8)	
B00D - R0001 - Home Base - (37.97 SQM) - Teaching Space: 1	 Student Space (17)	
B00D - R0002 - Practical Activities - 1hb - (15.34 SQM)	 Student Space (7)	
B00D - R0004 - Withdrawal Space - 1hb - (15.49 SQM)	 Student Space (7)	
B00E - R0005 - Duplicating Workroom - (8.74 SQM)	 Office (2)	
B00E - R0006 - Principal - (17.23 SQM)	 Office (4)	
B00E - R0008 - Clerical Office - (12.71 SQM)	 Office (3)	
B00E - R0009 - Staff Room - (27.17 SQM)	 Office (6)	
B00E - R0010 - Sick Bay - (5.02 SQM)	 Student Space (2)	
B00H - R0005 - Practical Activities - (45.54 SQM)	 Student Space (21)	
B00I - R0002 - Reading Area - (91.79 SQM)	 Student Space (42)	
OS 801 15083 - OS 801 15083 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.