


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Undercliffe Public School (3310)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Canterbury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

3310 - Undercliffe Public School  
Site Plan (13123)



















1:569

Printed: 27-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (19.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (48.04 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0005 - Home Base - (46.98 SQM) - Teaching Space: 1	 Student Space (21)	
B00A - R0006 - Home Base - (46.99 SQM) - Teaching Space: 1	 Student Space (21)	
B00A - R0007 - Home Base - (48.37 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0008 - Staff Room Annexe - (17.52 SQM)	 Office (4)	
B00A - R0009 - Movement - (22.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Practical Activities - 1hb - (54.98 SQM)	 Student Space (25)	
B00A - R0016 - Communal Space - (34.57 SQM)	 Student Space (16)	
B00A - R0017 - Movement - (62.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Raised Platform - (23.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Movement - (8.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Movement - (36.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Home Base - (49.44 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R1005 - Home Base - (48.44 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R1013 - Home Base - (49.76 SQM) - Teaching Space: 1	 Student Space (23)	
B00A - R1014 - Reading Area - (48.62 SQM)	 Student Space (22)	
B00A - R1015 - Reading Area - (36.13 SQM)	 Student Space (16)	
B00B - R0001 - Movement - (13.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Canteen - (31.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (23.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (41.91 SQM)	 Student Space (19)	
B00F - R0001 - Communal Space - (145.82 SQM)	 Student Space (67)	
B00F - R0002 - Raised Platform - (59.55 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (7.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (12.22 SQM)	Not Applicable	Circulation or storage space.
OS 502 15541 - OS 502 15541 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 602 10024 - OS 602 10024 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	