

VENTILATION AUDIT REPORT

SCHOOL:	Urana Public School (3314)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Albury
LOCAL GOVERNMENT AREA:	Federation

3314 - Urana Public School
Site Plan (11502)



1:907

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Duplicating Workroom - (14.8 SQM)	Office (3)	
B00A - R0003 - General Learning Space - (43.26 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0004 - Movement - (27.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Clerical Office - (12.94 SQM)	Office (3)	
B00A - R0006 - Sick Bay - (6.48 SQM)	Student Space (3)	
B00A - R0007 - Principal - (13.3 SQM)	Office (3)	
B00A - R0011 - Staff Room - (44.9 SQM)	Office (11)	
B00A - R0013 - Darkroom Space - (6.82 SQM)	Office (1)	
B00B - R0003 - Staff Room Annexe - (16.31 SQM)	Office (4)	
B00B - R0004 - Laboratory L.S. - (78.89 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0005 - Seminar - Type 1 - (18.94 SQM)	Office (4)	
B00B - R0011 - Pupil Entry - (5.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (52.76 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0015 - General Learning Space - (38.72 SQM) - Teaching Space: 1	Student Space (17)	
B00C - R0004 - Home Base - (86.06 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0005 - Special Programs Room - (24.3 SQM)	Student Space (11)	
B00D - R0006 - Special Programs Room - (22.36 SQM)	Student Space (10)	
B00E - R0002 - Welding Area - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Materials Technology L.S. - (99.95 SQM) - Teaching Space: 1	Student Space (46)	
B00E - R0004 - Design L.S. - (38.05 SQM) - Teaching Space: 1	Student Space (17)	
B00E - R0005 - Food Technology L.S. - (66.45 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0001 - Reading Area - (59.85 SQM)	Student Space (27)	