


VENTILATION AUDIT REPORT

SCHOOL:	Urbenville Public School (3316)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Tenterfield

3316 - Urbenville Public School
Site Plan (13260)



1:1,229

Printed: 08-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Canteen - (14.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Special Programs Room - (21.96 SQM)	● Student Space (10)	
B00A - R0003 - Movement - (25.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Reading Area - (34.95 SQM)	● Student Space (16)	
B00C - R0001 - Practical Activities - 1hb - (14.73 SQM)	● Student Space (6)	
B00C - R0002 - Home Base - (40.37 SQM) - Teaching Space: 1	● Student Space (18)	
B00D - R0001 - Clerical Office - (13.79 SQM)	○ Office (3)	
B00D - R0002 - Principal - (7.9 SQM)	○ Office (1)	
B00D - R0003 - Home Base - (51.55 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0004 - Home Base - (51.69 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0005 - Home Base - (41.92 SQM)	● Student Space (19)	
B00D - R0006 - Practical Activities - 1hb - (9.77 SQM)	● Student Space (4)	
B00D - R0007 - Staff Room - (24.15 SQM)	○ Office (6)	
B00D - R0008 - Movement - (48.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Entry Vestibule - (8.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Clerical Office/Workroom - (9.28 SQM)	○ Office (2)	
B00D - R0011 - Principal - (13.18 SQM)	○ Office (3)	
B00E - R0009 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (60.03 SQM)	● Student Space (27)	