

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Urunga Public School (3318)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Oxley</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bellingen</b>

3318 - Urunga Public School  
Site Plan (11503)



1:641

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0007 - Sick Bay - (8.32 SQM)	● Student Space (3)	
B001 - R0010 - Duplicating Workroom - (15.71 SQM)	● Office (3)	
B001 - R0011 - Practical Activities - 1hb - (16.67 SQM)	● Student Space (7)	
B001 - R0012 - Home Base - (52.05 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R0013 - Staff Room - (52.05 SQM)	● Office (13)	
B001 - R0014 - Practical Activities - 1hb - (12.7 SQM)	● Student Space (5)	
B001 - R0018 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R0019 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R0022 - Deputy Principal - (11.96 SQM)	● Office (2)	
B001 - R0027 - Withdrawal Space - 1hb - (20.75 SQM)	● Student Space (9)	
B001 - R0028 - Movement - (18.24 SQM)	Not Applicable	Circulation or storage space.
B001 - R0029 - Principal - (14.95 SQM)	● Office (3)	
B001 - R0033 - Movement - (23.76 SQM)	Not Applicable	Circulation or storage space.
B001 - R0034 - Interview - (10.29 SQM)	● Office (2)	
B001 - R0041 - Interview/Office - Type 3 - (6.33 SQM)	● Office (1)	
B001 - R0042 - Clerical Office - (20.61 SQM)	● Office (5)	
B001 - R0044 - Entry Vestibule - (17.08 SQM)	Not Applicable	Circulation or storage space.
B001 - R9001 - Canteen - (25.88 SQM)	Not Applicable	Circulation or storage space.
B001 - R9005 - Special Programs Room - (35.96 SQM)	● Student Space (16)	
B002 - R0003 - Reading Area - (98.97 SQM)	● Student Space (45)	
B003 - R0001 - Withdrawal Space - 1hb - (6.67 SQM)	● Student Space (3)	
B003 - R0006 - Practical Activities - 1hb - (18.66 SQM)	● Student Space (8)	
B003 - R0007 - Home Base - (61.74 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R0008 - Home Base - (61.74 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R0009 - Practical Activities - 1hb - (18.66 SQM)	● Student Space (8)	
B003 - R0010 - Withdrawal Space - 1hb - (6.58 SQM)	● Student Space (3)	
B006 - R0003 - Practical Activities - 1hb - (20.1 SQM)	● Student Space (9)	
B006 - R0004 - Home Base - (58.9 SQM) - Teaching Space: 1	● Student Space (27)	
B006 - R0005 - Withdrawal Space - 1hb - (9.67 SQM)	● Student Space (4)	
B006 - R0006 - Practical Activities - 1hb - (17.64 SQM)	● Student Space (8)	
B006 - R0007 - Home Base - (70.64 SQM) - Teaching Space: 1	● Student Space (32)	
B006 - R0008 - Practical Activities - 1hb - (17.51 SQM)	● Student Space (8)	
B006 - R0009 - Home Base - (61.43 SQM) - Teaching Space: 1	● Student Space (28)	
B006 - R0012 - Practical Activities - 1hb - (20.08 SQM)	● Student Space (9)	
B006 - R0013 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B008 - R0002 - Practical Activities - 1hb - (19.9 SQM)	● Student Space (9)	
B008 - R0003 - Home Base - (58.97 SQM) - Teaching Space: 1	● Student Space (27)	
B008 - R0005 - Withdrawal Space - 1hb - (7.52 SQM)	● Student Space (3)	
B008 - R0007 - Practical Activities - 1hb - (19.23 SQM)	● Student Space (8)	
B008 - R0009 - Home Base - (60.65 SQM) - Teaching Space: 1	● Student Space (28)	
B008 - R0010 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B008 - R0011 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B008 - R0013 - Practical Activities - 1hb - (19.16 SQM)	● Student Space (8)	
B010 - R0002 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
B010 - R0003 - Raised Platform - (22.49 SQM)	Not Applicable	Circulation or storage space.