

VENTILATION AUDIT REPORT

SCHOOL:	Valentine Public School (4185)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Lake Macquarie

4185 - Valentine Public School
Site Plan (11360)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (40.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (86.48 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R0005 - Home Base - (57.39 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0013 - Movement - (39.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0016 - Home Base - (53.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0017 - Special Programs Room - (31.38 SQM)	● Student Space (14)	
B00A - R0018 - Special Programs Room - (51.03 SQM)	● Student Space (23)	
B00B - R0001 - Practical Activities - 1hb - (17.81 SQM)	● Student Space (8)	
B00B - R0002 - Home Base - (56.92 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0003 - Movement - (39.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (9.08 SQM)	● Student Space (4)	
B00B - R0006 - Home Base - (57.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R9002 - Movement - (15.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room - (79.85 SQM)	○ Office (19)	
B00C - R0003 - Movement - (19.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Communal Space - (69.77 SQM)	● Student Space (32)	
B00C - R0011 - Movement - (47.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (24.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (73.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Duplicating Workroom - (15.6 SQM)	○ Office (3)	
B00C - R1003 - Sick Bay - (15.65 SQM)	● Student Space (7)	
B00C - R1004 - Movement - (20.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Clerical Office - (14.43 SQM)	○ Office (3)	
B00C - R1006 - Entry Vestibule - (16.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Movement - (52.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Staff Room Annexe - (14.29 SQM)	○ Office (3)	
B00C - R1011 - Principal - (20.94 SQM)	○ Office (5)	
B00C - R1013 - Staff Room Annexe - (14.14 SQM)	○ Office (3)	
B00C - R1014 - Home Base - (57.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1015 - Practical Activities - 1hb - (14.72 SQM)	● Student Space (6)	
B00D - R0001 - Movement - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Reading Area - (185.85 SQM)	● Student Space (86)	
B00D - R0013 - Movement - (15.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (54.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (33.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Canteen - (36.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (56.53 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0009 - Practical Activities - 1hb - (15.44 SQM)	● Student Space (7)	
B00E - R0011 - Home Base - (56.76 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0001 - Movement - (39.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (57.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0003 - Practical Activities - 1hb - (14.23 SQM)	● Student Space (6)	
B00F - R0006 - Movement - (7.93 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Home Base - (59.6 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0003 - Practical Activities - 1hb - (19.9 SQM)	● Student Space (9)	
B00I - R0004 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00I - R0005 - Practical Activities - 1hb - (19.96 SQM)	● Student Space (9)	
B00I - R0006 - Home Base - (59.15 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0009 - Movement - (35.72 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0002 - Home Base - (59.6 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0003 - Practical Activities - 1hb - (19.9 SQM)	● Student Space (9)	
B00J - R0004 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00J - R0005 - Practical Activities - 1hb - (19.96 SQM)	● Student Space (9)	
B00J - R0006 - Home Base - (59.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Movement - (35.72 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Communal Space - (201.97 SQM)	● Student Space (93)	
B00K - R0013 - Movement - (12.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Movement - (12.69 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Raised Platform - (61.63 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00K - R0017 - Outdoor Learning Area - (225.76 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00L - R0006 - Home Base - (60.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0007 - Withdrawal Space - 2hb - (11.51 SQM)	● Student Space (5)	
B00L - R0008 - Practical Activities - 1hb - (18.85 SQM)	● Student Space (8)	
B00L - R0009 - Home Base - (60.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0011 - Practical Activities - 1hb - (20.15 SQM)	● Student Space (9)	
B00L - R0012 - Withdrawal Space - 1hb - (9.12 SQM)	● Student Space (4)	
B00L - R0013 - Home Base - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R1003 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00L - R1005 - Home Base - (60.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R1006 - Withdrawal Space - 2hb - (11.51 SQM)	● Student Space (5)	
B00L - R1007 - Practical Activities - 1hb - (18.85 SQM)	● Student Space (8)	
B00L - R1008 - Home Base - (60.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R1010 - Practical Activities - 1hb - (20.15 SQM)	● Student Space (9)	
B00L - R1011 - Withdrawal Space - 1hb - (9.12 SQM)	● Student Space (4)	
B00L - R1012 - Home Base - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
OH 060 17054 - OH 060 17054 - OSHC Hub 60 - (19 SQM)	● Student Space (8)	
OS 602 12422 - OS 602 12422 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12768 - OS 602 12768 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19808 - OS 606 19808 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	