


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Valley View Public School (4508)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>The Entrance</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

4508 - Valley View Public School  
Site Plan (11362)



1:919

Printed: 05-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office/Workroom - (15.41 SQM)	Office (3)	
B00A - R0002 - Movement - (5.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Entry Vestibule - (18.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Principal - (23.17 SQM)	Office (5)	
B00A - R0007 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (14.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room - (68.99 SQM)	Office (17)	
B00A - R0011 - Staff Room Annexe - (9.32 SQM)	Office (2)	
B00A - R0016 - Movement - (20.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Deputy Principal - (11.24 SQM)	Office (2)	
B00A - R0018 - Deputy Principal - (11.24 SQM)	Office (2)	
B00A - R0019 - Movement - (16.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Clerical Office/Workroom - (11.24 SQM)	Office (2)	
B00A - R0021 - Duplicating Workroom - (24.8 SQM)	Office (6)	
B00A - R0024 - Movement - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Sick Bay - (9.11 SQM)	Student Space (4)	
B00A - R0026 - Movement - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (24.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (38.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (39.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Staff Room - (57.74 SQM)	Office (14)	
B00A - R0031 - Staff Kitchen - (10.51 SQM)	Office (2)	
B00B - R0003 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Reading Area - (91.61 SQM)	Student Space (42)	
B00B - R0010 - Movement - (10.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Reading Area - (162.9 SQM)	Student Space (75)	
B00B - R0014 - Movement - (76.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (75.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (28.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Canteen - (41.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Movement - (21.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Raised Platform - (55.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Communal Space - (213.55 SQM)	Student Space (99)	
B00D - R0004 - Movement - (8.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (54.2 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0008 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Withdrawal Space - 1hb - (12.05 SQM)	Student Space (5)	
B00D - R0010 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (54.22 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0013 - Movement - (8.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Movement - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Home Base - (54.21 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0026 - Withdrawal Space - 1hb - (12.05 SQM)	Student Space (5)	
B00D - R0028 - Home Base - (54.21 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0030 - Movement - (8.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0036 - Practical Activities - 1hb - (53.24 SQM)	Student Space (24)	
B00D - R0038 - Staff Room Annexe - (12.26 SQM)	Office (3)	
B00D - R0040 - Special Programs Room - (37.66 SQM)	Student Space (17)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0042 - Practical Activities - 1hb - (48.93 SQM)	● Student Space (22)	
B00D - R0043 - Movement - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Movement - (10.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R1007 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Home Base - (54.2 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1010 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00D - R1012 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Home Base - (54.2 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1015 - Movement - (9.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Movement - (9.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R1022 - Withdrawal Space - 1hb - (12.26 SQM)	● Student Space (5)	
B00D - R1026 - Movement - (25.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Special Programs Room - (43.17 SQM)	● Student Space (20)	
B00D - R9005 - Movement - (8.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R9006 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R9007 - Movement - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R9008 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00D - R9009 - Movement - (9.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R9010 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R9012 - Movement - (8.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R9018 - Practical Activities - 1hb - (53.18 SQM)	● Student Space (24)	
B00D - R9021 - Movement - (12.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (8.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (54.22 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0009 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00E - R0011 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0014 - Movement - (8.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (13.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (8.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Home Base - (54.22 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0027 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00E - R0029 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0032 - Movement - (8.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0038 - Practical Activities - 1hb - (54.59 SQM)	● Student Space (25)	
B00E - R0039 - Movement - (9.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0040 - Interview - (12.26 SQM)	● Office (3)	
B00E - R0041 - Special Programs Room - (37.65 SQM)	● Student Space (17)	
B00E - R0043 - Movement - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0044 - Practical Activities - 1hb - (48.94 SQM)	● Student Space (22)	
B00E - R1003 - Movement - (8.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R1008 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R1011 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00E - R1013 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R1014 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1016 - Movement - (9.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R1022 - Practical Activities - 1hb - (39.18 SQM)	● Student Space (18)	
B00E - R1023 - Movement - (9.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - Withdrawal Space - 1hb - (12.26 SQM)	● Student Space (5)	
B00E - R1026 - Movement - (28.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R9001 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R9002 - Movement - (20.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R9006 - Movement - (8.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R9008 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R9009 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R9010 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00E - R9011 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R9012 - Home Base - (54.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R9014 - Movement - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R9020 - Practical Activities - 1hb - (53.17 SQM)	● Student Space (24)	
B00E - R9021 - Movement - (12.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Practical Activities - 1hb - (43.07 SQM)	● Student Space (19)	
B00F - R0014 - Movement - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Special Programs Room - (37.65 SQM)	● Student Space (17)	
B00F - R0020 - Staff Room Annexe - (12.25 SQM)	● Office (3)	
B00F - R0021 - Practical Activities - 1hb - (78.51 SQM)	● Student Space (36)	
B00F - R0022 - Movement - (9.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - Home Base - (55.33 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0026 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0027 - Withdrawal Space - 1hb - (12.18 SQM)	● Student Space (5)	
B00F - R0028 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0029 - Home Base - (55.33 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0031 - Movement - (8.86 SQM)	Not Applicable	Circulation or storage space.
B00F - R0032 - Movement - (9.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0034 - Home Base - (55.33 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0035 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0036 - Withdrawal Space - 1hb - (9.03 SQM)	● Student Space (4)	
B00F - R0037 - Movement - (9.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0038 - Home Base - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0040 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0041 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0043 - Home Base - (51.77 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0044 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0047 - Withdrawal Space - 1hb - (9.03 SQM)	● Student Space (4)	
B00F - R0048 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (67.48 SQM) - Teaching Space: 1	● Student Space (31)	
B00H - R0003 - Practical Activities - M - 2hb - (38 SQM)	● Student Space (17)	
B00H - R0008 - Home Base - M - (67.64 SQM) - Teaching Space: 1	● Student Space (31)	