

VENTILATION AUDIT REPORT

SCHOOL:	Vardys Road Public School (4248)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Blacktown

4248 - Vardys Road Public School
Site Plan (13122)




















1:1,238

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (49.36 SQM)	Office (12)	
B00A - R0002 - Staff Room Annexe - (12.44 SQM)	Office (3)	
B00A - R0004 - Sick Bay - (8.46 SQM)	Student Space (3)	
B00A - R0005 - Clerical Office - (17.62 SQM)	Office (4)	
B00A - R0006 - Duplicating Workroom - (24.27 SQM)	Office (6)	
B00A - R0009 - Interview - (11.01 SQM)	Office (2)	
B00A - R0012 - Entry Vestibule - (11.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Principal - (17.61 SQM)	Office (4)	
B00A - R0014 - Deputy Principal - (12.29 SQM)	Office (3)	
B00A - R0015 - Movement - (22.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (60.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (72.75 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0007 - Home Base - (56.02 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0011 - Movement - (15.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Interview - (16.69 SQM)	Office (4)	
B00B - R0016 - Home Base - (56.33 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0018 - Home Base - (56.26 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0021 - Withdrawal Space - 1hb - (20.6 SQM)	Student Space (9)	
B00B - R0023 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (140.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Reading Area - (214.34 SQM)	Student Space (99)	
B00D - R0001 - Home Base - (58.55 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - Movement - (15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0011 - Home Base - (56.89 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0014 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Home Base - (58.54 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0001 - Home Base - (57.55 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0004 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - (57 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0008 - Home Base - (56.45 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0001 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0006 - Home Base - (56.23 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0003 - Practical Activities - 1hb - (13.8 SQM)	Student Space (6)	
B00G - R0004 - Home Base - (43.95 SQM) - Teaching Space: 1	Student Space (20)	
B00G - R0006 - Home Base - (56.73 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0009 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Home Base - (58.54 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0001 - Movement - (15.05 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Clinic - (19.15 SQM)	Office (4)	
B00M - R0003 - Staff Kitchen - (6.97 SQM)	Office (1)	
B00M - R0005 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Raised Platform - (55.92 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Communal Space - (198.5 SQM)	Student Space (92)	
B00M - R0019 - Canteen - (41.58 SQM)	Not Applicable	Circulation or storage space.
B00M - R0022 - Movement - (35.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0023 - Movement - (35.14 SQM)	Not Applicable	Circulation or storage space.
B00M - R0024 - Movement - (28.1 SQM)	Not Applicable	Circulation or storage space.
B00M - R0025 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Special Programs Room - (40.88 SQM)	 Student Space (18)	
B00N - R0005 - Home Base - (60.04 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0006 - Practical Activities - 1hb - (18.94 SQM)	 Student Space (8)	
B00N - R0007 - Withdrawal Space - 2hb - (11.54 SQM)	 Student Space (5)	
B00N - R0008 - Home Base - (60.07 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0009 - Practical Activities - 1hb - (18.92 SQM)	 Student Space (8)	
B00N - R0012 - Home Base - (60.12 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0013 - Practical Activities - 1hb - (19.03 SQM)	 Student Space (8)	
B00N - R0014 - Withdrawal Space - 2hb - (11.54 SQM)	 Student Space (5)	
B00N - R0015 - Home Base - (59.95 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0016 - Practical Activities - 1hb - (19 SQM)	 Student Space (8)	
B00P - R0002 - Interview/Office - Type 3 - (9.45 SQM)	 Office (2)	
B00P - R0005 - Staff Kitchen - (12.97 SQM)	 Office (3)	
B00P - R0006 - Sick Bay - (11.29 SQM)	 Student Space (5)	
B00P - R0009 - Clerical Office - (13.12 SQM)	 Office (3)	
OS 602 11844 - OS 602 11844 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19610 - OS 606 19610 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	