


VENTILATION AUDIT REPORT

SCHOOL:	Vaucluse Public School (3325)
AMU REGION:	Sydney
STATE ELECTORATE:	Vaucluse
LOCAL GOVERNMENT AREA:	Woollahra

3325 - Vaucluse Public School
Site Plan (12889)



1:1,058

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (56.87 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0015 - Interview - (18.57 SQM)	● Office (4)	
B00A - R0017 - Movement - (23.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Home Base - (61.26 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0021 - Practical Activities - 2hb - (11.06 SQM)	● Student Space (5)	
B00A - R0022 - Home Base - (62.62 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0023 - Withdrawal Space - 1hb - (6.32 SQM)	● Student Space (2)	
B00A - R0025 - Practical Activities - 1hb - (6.18 SQM)	● Student Space (2)	
B00A - R9001 - Practical Activities - 1hb - (53.97 SQM)	● Student Space (25)	
B00A - R9002 - Movement - (16.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (88.99 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R0003 - Practical Activities - 1hb - (11.55 SQM)	● Student Space (5)	
B00B - R1002 - Home Base - (89 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R1003 - Practical Activities - 1hb - (11.56 SQM)	● Student Space (5)	
B00C - R0002 - Movement - (20.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (46.86 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0005 - Home Base - (46.88 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0006 - Home Base - (47.19 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0007 - Home Base - (46.99 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0009 - Movement - (20.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Principal - (17.22 SQM)	● Office (4)	
B00C - R0028 - Duplicating Workroom - (8.76 SQM)	● Office (2)	
B00C - R0029 - Clerical Office - (31.81 SQM)	● Office (7)	
B00C - R0030 - Movement - (75.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Movement - (16.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Interview - (16.73 SQM)	● Office (4)	
B00C - R1004 - Special Programs Room - (49.16 SQM)	● Student Space (22)	
B00C - R1006 - Home Base - (49.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1007 - Movement - (18.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Communal Space - (122.48 SQM)	● Student Space (56)	
B00C - R1011 - Raised Platform - (24.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R1014 - Home Base - (49.93 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1015 - Home Base - (49.77 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0004 - Staff Room - (64.04 SQM)	● Office (16)	
B00D - R0005 - Special Programs Room - (50.06 SQM)	● Student Space (23)	
B00E - R0001 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (54.11 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0003 - Movement - (17.22 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Canteen - (27.58 SQM)	Not Applicable	Circulation or storage space.
OS 602 12547 - OS 602 12547 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12892 - OS 602 12892 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15198 - OS 602 15198 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15749 - OS 602 15749 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16228 - OS 602 16228 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	