


VENTILATION AUDIT REPORT

SCHOOL:	Victoria Avenue Public School (4655)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Strathfield
LOCAL GOVERNMENT AREA:	Canada Bay

4655 - Victoria Avenue Public School
Site Plan (15694)



1:2,778




















Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (32.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Clerical/Printing - (60.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Interview - (12.18 SQM)	Office (3)	
B00A - R0023 - Principal - (16.77 SQM)	Office (4)	
B00A - R0024 - Interview/Office - Type 3 - (16 SQM)	Office (4)	
B00A - R0026 - Staff Room - (44.05 SQM)	Office (11)	
B00A - R0033 - Staff Room Annexe - (56.28 SQM)	Office (14)	
B00A - R0035 - Movement - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (36.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Sick Bay - (9.02 SQM)	Student Space (4)	
B00A - R0042 - Movement - (43.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Communal Space - (237.14 SQM)	Student Space (110)	
B00A - R0057 - Practical Activities - 2hb - (20.45 SQM)	Student Space (9)	
B00A - R0058 - Clerical Office - (12.66 SQM)	Office (3)	
B00A - R0067 - Deputy Principal - (13.29 SQM)	Office (3)	
B00A - R0068 - Deputy Principal - (11.66 SQM)	Office (2)	
B00A - R0069 - Raised Platform - (56.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0071 - Movement - (35.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0072 - Staff Kitchen - (9.04 SQM)	Office (2)	
B00A - R1001 - Home Base - (63.41 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1002 - Withdrawal Space - 2hb - (13.5 SQM)	Student Space (6)	
B00A - R1003 - Home Base - (67.52 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1008 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1009 - Withdrawal Space - 2hb - (13.14 SQM)	Student Space (6)	
B00A - R1010 - Home Base - (59.55 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1013 - Home Base - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1014 - Withdrawal Space - 2hb - (13.11 SQM)	Student Space (6)	
B00A - R1015 - Home Base - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1018 - Home Base - (59.55 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1019 - Withdrawal Space - 2hb - (13.11 SQM)	Student Space (6)	
B00A - R1020 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1030 - Practical Activities - 1hb - (19.24 SQM)	Student Space (8)	
B00A - R1031 - Practical Activities - 1hb - (21.05 SQM)	Student Space (9)	
B00A - R1032 - Practical Activities - 1hb - (22.26 SQM)	Student Space (10)	
B00A - R1033 - Practical Activities - 1hb - (22.27 SQM)	Student Space (10)	
B00A - R1034 - Practical Activities - 1hb - (22.37 SQM)	Student Space (10)	
B00A - R1035 - Practical Activities - 1hb - (21.83 SQM)	Student Space (10)	
B00A - R1036 - Practical Activities - 1hb - (21.99 SQM)	Student Space (10)	
B00A - R1037 - Practical Activities - 1hb - (22.39 SQM)	Student Space (10)	
B00A - R1041 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (49.03 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0004 - Withdrawal Space - 1hb - (18.41 SQM)	Student Space (8)	
B00B - R0005 - Breakout Area - (8.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Breakout Area - (15.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Home Base - (53.83 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0013 - Home Base - (65.14 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0015 - Withdrawal Space - 2hb - (14.44 SQM)	Student Space (6)	
B00B - R0017 - Home Base - (65.37 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0018 - Withdrawal Space - 1hb - (9.22 SQM)	● Student Space (4)	
B00B - R0020 - Home Base - (62.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0029 - Canteen - (47.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Practical Activities - 1hb - (26.54 SQM)	● Student Space (12)	
B00B - R0032 - Practical Activities - 1hb - (29.03 SQM)	● Student Space (13)	
B00B - R0033 - Practical Activities - 1hb - (22.19 SQM)	● Student Space (10)	
B00B - R0034 - Practical Activities - 1hb - (22.44 SQM)	● Student Space (10)	
B00B - R0035 - Practical Activities - 1hb - (21.91 SQM)	● Student Space (10)	
B00B - R1001 - Home Base - (64.83 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1003 - Withdrawal Space - 2hb - (10.49 SQM)	● Student Space (4)	
B00B - R1005 - Home Base - (63.54 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1006 - Home Base - (63.39 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1008 - Withdrawal Space - 2hb - (10.49 SQM)	● Student Space (4)	
B00B - R1010 - Home Base - (63.43 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1011 - Home Base - (63.6 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1013 - Withdrawal Space - 2hb - (10.52 SQM)	● Student Space (4)	
B00B - R1015 - Home Base - (69.72 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1018 - Special Programs Room - Type 2 - (17.02 SQM)	● Student Space (7)	
B00B - R1019 - Special Programs Room - Type 2 - (30.66 SQM)	● Student Space (14)	
B00B - R1020 - Reading Area - (163.34 SQM)	● Student Space (75)	
B00B - R1025 - Movement - (24.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Computer Room - (47.42 SQM)	● Student Space (22)	
B00B - R1028 - Movement - (30.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R1032 - Special Programs Room - Type 2 - (17.52 SQM)	● Student Space (8)	
B00B - R1033 - Reading Area - (60.92 SQM)	● Student Space (28)	
B00B - R1034 - Staff Room - (12.47 SQM)	● Office (3)	
B00B - R1036 - Practical Activities - 1hb - (22.9 SQM)	● Student Space (10)	
B00B - R1037 - Practical Activities - 1hb - (22.31 SQM)	● Student Space (10)	
B00B - R1038 - Practical Activities - 1hb - (21.41 SQM)	● Student Space (9)	
B00B - R1039 - Practical Activities - 1hb - (22.33 SQM)	● Student Space (10)	
B00B - R1040 - Practical Activities - 1hb - (22.22 SQM)	● Student Space (10)	
B00B - R1041 - Practical Activities - 1hb - (22.35 SQM)	● Student Space (10)	
B00C - R0001 - Home Base - (62.7 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0002 - Breakout Area - (15.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (61.82 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0009 - Breakout Area - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Withdrawal Space - 1hb - (8.29 SQM)	● Student Space (3)	
B00C - R0012 - Home Base - (53.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0015 - Home Base - (55.99 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0016 - Withdrawal Space - 2hb - (12.81 SQM)	● Student Space (5)	
B00C - R0017 - Home Base - (55.96 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0020 - Home Base - (55.97 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0021 - Withdrawal Space - 2hb - (12.78 SQM)	● Student Space (5)	
B00C - R0022 - Home Base - (56.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0025 - Home Base - (55.91 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0026 - Withdrawal Space - 2hb - (12.74 SQM)	● Student Space (5)	
B00C - R0027 - Home Base - (56.05 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0029 - Practical Activities - 1hb - (24.68 SQM)	 Student Space (11)	
B00C - R0030 - Practical Activities - 1hb - (27.3 SQM)	 Student Space (12)	
B00C - R0031 - Practical Activities - 1hb - (24.6 SQM)	 Student Space (11)	
B00C - R0032 - Practical Activities - 1hb - (24.63 SQM)	 Student Space (11)	
B00C - R0033 - Practical Activities - 1hb - (24.04 SQM)	 Student Space (11)	
B00C - R0034 - Practical Activities - 1hb - (23.99 SQM)	 Student Space (11)	
B00C - R0035 - Practical Activities - 1hb - (24.5 SQM)	 Student Space (11)	
B00C - R0036 - Practical Activities - 1hb - (24.62 SQM)	 Student Space (11)	
B00C - R0037 - Practical Activities - 1hb - (24.72 SQM)	 Student Space (11)	
B00C - R0041 - Practical Activities - 1hb - (24.68 SQM)	 Student Space (11)	
B00C - R0042 - Practical Activities - 1hb - (27.3 SQM)	 Student Space (12)	
B00C - R0043 - Practical Activities - 1hb - (24.6 SQM)	 Student Space (11)	
B00C - R0044 - Practical Activities - 1hb - (24.63 SQM)	 Student Space (11)	
B00C - R0045 - Practical Activities - 1hb - (24.04 SQM)	 Student Space (11)	
B00C - R0046 - Practical Activities - 1hb - (23.99 SQM)	 Student Space (11)	
B00C - R0047 - Practical Activities - 1hb - (24.5 SQM)	 Student Space (11)	
B00C - R0048 - Practical Activities - 1hb - (24.62 SQM)	 Student Space (11)	
B00C - R0049 - Practical Activities - 1hb - (24.72 SQM)	 Student Space (11)	
B00C - R0054 - Child Care Centre - (136.82 SQM)	 Student Space (63)	