

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Villawood East Public School (3977)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Bankstown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

3977 - Villawood East Public School  
Site Plan (11363)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Principal - (16.7 SQM)	Office (4)	
B00A - R0008 - Clerical Office - (19.84 SQM)	Office (4)	
B00A - R0009 - Entry Vestibule - (28.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Duplicating Workroom - (16.55 SQM)	Office (4)	
B00A - R0014 - Sick Bay - (8.18 SQM)	Student Space (3)	
B00A - R0016 - Deputy Principal - (12.71 SQM)	Office (3)	
B00A - R0017 - Staff Room Annexe - (12.71 SQM)	Office (3)	
B00A - R0018 - Interview - (11.62 SQM)	Office (2)	
B00A - R0020 - Movement - (34.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (92.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (29.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Staff Room - (38.77 SQM)	Office (9)	
B00A - R0025 - Staff Kitchen - (7.37 SQM)	Office (1)	
B00A - R0026 - Deputy Principal - (9.18 SQM)	Office (2)	
B00A - R0027 - Deputy Principal - (9.15 SQM)	Office (2)	
B00B - R0007 - Canteen - (26.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (270.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Raised Platform - (47.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Communal Space - (141.26 SQM)	Student Space (65)	
B00C - R0001 - Reading Area - (161.56 SQM)	Student Space (74)	
B00C - R0005 - Special Programs Room - (32.88 SQM)	Student Space (15)	
B00C - R0006 - Movement - (96.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (20.11 SQM)	Not Applicable	Circulation or storage space.
B00E - M0001 - Withdrawal - Pre - (9.77 SQM)	Student Space (4)	
B00E - R0005 - Movement - (22.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - Pre - (51.64 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0008 - Withdrawal - Pre - (12.45 SQM)	Student Space (5)	
B00E - R0009 - Movement - (43.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Practical Activities - Pre - (13.75 SQM)	Student Space (6)	
B00F - R0001 - Movement - (17.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Special Programs Room - (16.95 SQM)	Student Space (7)	
B00F - R0005 - Special Programs Room - (24.6 SQM)	Student Space (11)	
B00G - R0001 - Home Base - (67 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0003 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (67 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0008 - Home Base - (66.81 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R0011 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Home Base - (67 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0016 - Home Base - M - (67 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0019 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Home Base - (66.99 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0024 - Outdoor Learning Area - (49.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Outdoor Learning Area - (49.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Outdoor Learning Area - (49.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Outdoor Learning Area - (49.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Outdoor Learning Area - (49.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0029 - Outdoor Learning Area - (49.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (91.34 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R0002 - Practical Activities - 1hb - (5.65 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0009 - Practical Activities - 1hb - (5.65 SQM)	● Student Space (2)	
B00H - R0011 - Home Base - (91.51 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0012 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Movement - (10.03 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Practical Activities - (80.39 SQM)	● Student Space (37)	
B00K - R0001 - Movement - (46.6 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (19.76 SQM)	● Student Space (9)	
B00K - R0006 - Home Base - (54.7 SQM) - Teaching Space: 1	● Student Space (25)	
B00K - R0007 - Withdrawal Space - 1hb - (10.58 SQM)	● Student Space (4)	
B00K - R0008 - Home Base - (54.56 SQM) - Teaching Space: 1	● Student Space (25)	
B00K - R0013 - Practical Activities - 1hb - (19.82 SQM)	● Student Space (9)	
B00K - R0014 - Movement - (22.11 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Practical Activities - 1hb - (14.99 SQM)	● Student Space (6)	
B00N - R0004 - Home Base - (60.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0005 - Withdrawal Space - 2hb - (11.63 SQM)	● Student Space (5)	
B00N - R0006 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0008 - Practical Activities - 1hb - (14.93 SQM)	● Student Space (6)	
B00O - R0004 - Withdrawal Space - 1hb - (7.66 SQM)	● Student Space (3)	
B00O - R0006 - Home Base - (55.91 SQM) - Teaching Space: 1	● Student Space (25)	
B00O - R0007 - Practical Activities - 1hb - (19.15 SQM)	● Student Space (8)	
NS 100 15186 - NS 100 15186 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 606 11487 - OS 606 11487 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	