


VENTILATION AUDIT REPORT

SCHOOL:	Vincentia High School (8593)
AMU REGION:	Southern NSW
STATE ELECTORATE:	South Coast
LOCAL GOVERNMENT AREA:	Shoalhaven

8593 - Vincentia High School
Site Plan (11641)















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (47.62 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0002 - Study Space - (11.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Staff Study - (38.99 SQM)	● Office (9)	
B00A - R0006 - General Learning Space - (46.47 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0007 - General Learning Space - (49.37 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0008 - General Learning Space - (49.37 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0009 - General Learning Space - (46.42 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0011 - Staff Study - (27.7 SQM)	● Office (6)	
B00A - R0012 - Movement - (79.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - General Learning Space - (46.48 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0017 - General Learning Space - (46.41 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0018 - General Learning Space - (46.49 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0020 - Study Space - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Study Space - (14.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (239.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (48.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1002 - Study Space - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Staff Study - (39.94 SQM)	● Office (9)	
B00A - R1006 - General Learning Space - (47.15 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1007 - Computer Learning Space - (60.17 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1010 - Staff Study - (19.16 SQM)	● Office (4)	
B00A - R1011 - General Learning Space - (47.15 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1013 - General Learning Space - (47.32 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1014 - Study Space - (15.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - General Learning Space - (47.77 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1016 - General Learning Space - (46.79 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1017 - General Learning Space - (47.07 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1018 - General Learning Space - (46.94 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1019 - General Learning Space - (47.25 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1022 - Study Space - (15.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Study Space - (15.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Movement - (237.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Multi-Purpose Space - (238.92 SQM)	● Student Space (110)	
B00B - R0009 - Movement - (22.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Student Canteen - (52.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (364.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Main Area - (430.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Seminar - (13.76 SQM)	● Office (3)	
B00B - R1004 - Seminar - (13.72 SQM)	● Office (3)	
B00B - R1005 - Seminar - (13.84 SQM)	● Office (3)	
B00B - R1006 - Workroom - (45.75 SQM)	● Office (11)	
B00B - R1007 - Audio Visual Workroom - (30.31 SQM)	● Student Space (14)	
B00B - R1009 - Entry - (11.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Movement - (12.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Staff Study - (11.81 SQM)	● Office (2)	
B00B - R1021 - Movement - (180.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Staff Study - (40.51 SQM)	● Office (10)	
B00C - R0001 - Senior Study - (54.67 SQM)	● Office (13)	
B00C - R0005 - General Assistants - (16.89 SQM)	● Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0009 - Commonroom - (109 SQM)	Office (27)	
B00C - R0011 - Clinic - Girls - (12.93 SQM)	Office (3)	
B00C - R0014 - Clinic - Boys - (13.3 SQM)	Office (3)	
B00C - R0015 - Interview/Meeting - (22.84 SQM)	Office (5)	
B00C - R0016 - Principal Office - (22.5 SQM)	Office (5)	
B00C - R0017 - Teachers Aides - (12.95 SQM)	Office (3)	
B00C - R0018 - Interview/Office - Type 1 - (12.86 SQM)	Office (3)	
B00C - R0019 - Administration - Clerical - (43.56 SQM)	Office (10)	
B00C - R0021 - Deputy Principal Office - (14.02 SQM)	Office (3)	
B00C - R0022 - Interview/Office - Type 1 - (15.63 SQM)	Office (3)	
B00C - R0023 - Duplicating Workroom - (26.75 SQM)	Office (6)	
B00C - R0024 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0025 - Movement - (114.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (161.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Movement - (12.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Movement - (58.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (124.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Laboratory L.S. - (93.76 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R1003 - Laboratory L.S. - (92.39 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R1007 - Preparation - (68.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Staff Study - (40.34 SQM)	Office (10)	
B00C - R1009 - Laboratory L.S. - (95.61 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R1010 - Laboratory L.S. - (91.87 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R1011 - Movement - (21.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Laboratory L.S. - (89.86 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R1014 - Laboratory L.S. - (89.11 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R1015 - Movement - (34.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Design/Technology L.S. - (80.89 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0002 - Design/Technology L.S. - (77.31 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0004 - Study Space - (24.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Darkroom Space - (29.06 SQM)	Office (7)	
B00D - R0007 - Design/Technology L.S. - (77.56 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0008 - Design/Technology L.S. - (80.81 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0009 - Movement - (69.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Movement - (129.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (65.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Interview/Office - Type 1 - (12.91 SQM)	Office (3)	
B00E - R0004 - Staff Study - (92.6 SQM)	Office (23)	
B00E - R0006 - Interview/Office - Type 1 - (12.98 SQM)	Office (3)	
B00F - R0001 - Art Learning Space - (60.32 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0006 - Movement - (11.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Art Learning Space - (60.68 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0008 - Workshop - (60.43 SQM)	Student Space (28)	
B00F - R0009 - Workshop - (50.99 SQM)	Student Space (23)	
B00F - R0011 - Art Learning Space - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0013 - Movement - (34.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (102.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Music Learning Space - (78.21 SQM) - Teaching Space: 1	Student Space (36)	
B00G - R0003 - Practice/Seminar - (25.95 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Music Learning Space - (60.54 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0007 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Movement - (80.7 SQM)	Not Applicable	Circulation or storage space.
B00H - M0001 - Multi-Purpose Space - (142.31 SQM)	● Student Space (66)	
B00H - R0001 - Gymnasium - (610.3 SQM)	● Student Space (283)	
B00H - R0006 - Staff Study - (20.34 SQM)	○ Office (5)	
B00H - R0008 - Movement - (16.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Student Canteen - (21.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (5.72 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0027 - Stage - (77.91 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - General Learning Space - (46.75 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0005 - General Learning Space - (46.62 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0006 - General Learning Space - (46.55 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0007 - General Learning Space - (46.82 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0016 - General Learning Space - (46.63 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0018 - Staff Study - (45.87 SQM)	○ Office (11)	
B00J - R0023 - Movement - (123.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R0025 - Interview/Office - Type 1 - (13.49 SQM)	○ Office (3)	
B00J - R1001 - General Learning Space - (47.36 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R1002 - Staff Study - (36.04 SQM)	○ Office (9)	
B00J - R1005 - General Learning Space - (47.3 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R1006 - General Learning Space - (46.9 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R1007 - General Learning Space - (47.3 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R1008 - Interview/Office - Type 1 - (13.34 SQM)	○ Office (3)	
B00J - R1010 - General Learning Space - (46.28 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R1011 - General Learning Space - (47.01 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R1012 - Movement - (105.21 SQM)	Not Applicable	Circulation or storage space.
B00J - R1013 - Movement - (13.36 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Food Technology L.S. - (76.55 SQM) - Teaching Space: 1	● Student Space (35)	
B00K - R0006 - Seminar/Technology Space - (38.31 SQM)	○ Office (9)	
B00K - R0008 - Movement - (22.52 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Kitchen - Type 1 - (85.54 SQM)	● Student Space (39)	
B00K - R0014 - Preparation - (21.26 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Materials Technology L.S. - (172.33 SQM) - Teaching Space: 1	● Student Space (79)	
B00L - R0006 - Welding Area - (13.02 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Workshop Area - (104.23 SQM)	● Student Space (48)	
B00L - R0010 - Materials Technology L.S. - (172.39 SQM) - Teaching Space: 1	● Student Space (79)	
B00L - R0011 - Metal Technology Bay - (69.48 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - General Learning Space - (76.98 SQM) - Teaching Space: 1	● Student Space (35)	
B00L - R0014 - Movement - (71.76 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Movement - (22.84 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Study Space - (33.91 SQM)	Not Applicable	Circulation or storage space.
NS 020 13153 - NS 020 13153 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
OS 523 18139 - OS 523 18139 - Staff Study With Toilets - (76 SQM)	○ Office (19)	
OS 601 10736 - OS 601 10736 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10826 - OS 601 10826 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 11355 - OS 601 11355 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11612 - OS 601 11612 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12250 - OS 601 12250 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12719 - OS 601 12719 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13019 - OS 601 13019 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13322 - OS 601 13322 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13466 - OS 601 13466 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13562 - OS 601 13562 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14170 - OS 601 14170 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14310 - OS 601 14310 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14505 - OS 601 14505 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 16060 - OS 601 16060 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 780 16064 - OS 780 16064 - Woodwork/Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.