

VENTILATION AUDIT REPORT

SCHOOL:	Vincentia Public School (4592)
AMU REGION:	Southern NSW
STATE ELECTORATE:	South Coast
LOCAL GOVERNMENT AREA:	Shoalhaven

4592 - Vincentia Public School
Site Plan (11640)



1:1,046

Printed: 28-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (14.83 SQM)	Student Space (6)	
B00A - R0003 - Home Base - (57.71 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0005 - Withdrawal Space - 1hb - (5.43 SQM)	Student Space (2)	
B00A - R0007 - Practical Activities - 1hb - (14.9 SQM)	Student Space (6)	
B00A - R0008 - Home Base - (57.87 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0010 - Withdrawal Space - 1hb - (14.01 SQM)	Student Space (6)	
B00A - R0013 - Practical Activities - 1hb - (14.79 SQM)	Student Space (6)	
B00A - R0015 - Home Base - (57.71 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0018 - Practical Activities - 1hb - (14.99 SQM)	Student Space (6)	
B00A - R0019 - Home Base - (57.87 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0021 - Withdrawal Space - 1hb - (5.42 SQM)	Student Space (2)	
B00B - R0001 - Practical Activities - 1hb - (14.85 SQM)	Student Space (6)	
B00B - R0003 - Home Base - (57.94 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0005 - Withdrawal Space - 1hb - (5.41 SQM)	Student Space (2)	
B00B - R0007 - Practical Activities - 1hb - (14.9 SQM)	Student Space (6)	
B00B - R0008 - Home Base - (49.76 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0009 - Withdrawal Space - 1hb - (8.01 SQM)	Student Space (3)	
B00B - R0011 - Withdrawal Space - 1hb - (14.06 SQM)	Student Space (6)	
B00B - R0014 - Practical Activities - 1hb - (14.82 SQM)	Student Space (6)	
B00B - R0016 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0019 - Practical Activities - 1hb - (14.79 SQM)	Student Space (6)	
B00B - R0020 - Home Base - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0022 - Withdrawal Space - 1hb - (5.44 SQM)	Student Space (2)	
B00C - R0002 - Special Programs Room - (32.76 SQM)	Student Space (15)	
B00C - R0004 - Reading Area - (161.85 SQM)	Student Space (75)	
B00C - R0005 - Movement - (25.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Practical Activities - 1hb - (15.08 SQM)	Student Space (6)	
B00D - R0006 - Home Base - (57.71 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0009 - Withdrawal Space - 1hb - (5.96 SQM)	Student Space (2)	
B00D - R0011 - Practical Activities - 1hb - (14.81 SQM)	Student Space (6)	
B00D - R0012 - Home Base - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0013 - Withdrawal Space - 1hb - (5.75 SQM)	Student Space (2)	
B00D - R0015 - Withdrawal Space - 1hb - (5.43 SQM)	Student Space (2)	
B00E - R0001 - Clerical Office - (23.03 SQM)	Office (5)	
B00E - R0002 - Duplicating Workroom - (21.95 SQM)	Office (5)	
B00E - R0003 - Sick Bay - (10.07 SQM)	Student Space (4)	
B00E - R0010 - Staff Room - (51.88 SQM)	Office (12)	
B00E - R0011 - Staff Room Annexe - (18.98 SQM)	Office (4)	
B00E - R0012 - Movement - (35.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Deputy Principal - (12.47 SQM)	Office (3)	
B00E - R0016 - Deputy Principal - (12.47 SQM)	Office (3)	
B00E - R0017 - Principal - (17.67 SQM)	Office (4)	
B00E - R0018 - Interview - (11.55 SQM)	Office (2)	
B00E - R0019 - Entry Vestibule - (24.2 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Communal Space - (220.71 SQM)	Student Space (102)	
B00F - R0009 - Raised Platform - (38.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Canteen - (27.52 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00G - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00G - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00H - R0007 - Special Programs Room - (34.11 SQM)	● Student Space (15)	
B00H - R0008 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Practical Activities/Movement - 1hb - (21.16 SQM)	● Student Space (9)	
B00H - R0010 - Home Base - (57.9 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0012 - Withdrawal Space - 1hb - (9.06 SQM)	● Student Space (4)	
OS 602 14919 - OS 602 14919 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	