

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Wagga Wagga High School (8142)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Wagga Wagga</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wagga Wagga</b>



8142 - Wagga Wagga High School  
Site Plan (11565)



1:1,244

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (18.65 SQM)	Office (4)	
B00A - R0003 - Interview/Office - Type 1 - (17.14 SQM)	Office (4)	
B00A - R0004 - Leading Teacher - (16.92 SQM)	Office (4)	
B00A - R0009 - Movement - (11.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (32.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Public Entry - (7.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Administration - Clerical - (18.77 SQM)	Office (4)	
B00A - R0034 - Clinic - Girls - (11.72 SQM)	Office (2)	
B00A - R0036 - Deputy Principal Office - (14.26 SQM)	Office (3)	
B00A - R0038 - Duplicating Workroom - (39.2 SQM)	Office (9)	
B00A - R0039 - General Learning Space - (51.08 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0040 - General Learning Space - (54.51 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0041 - General Learning Space - (54.8 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0042 - Movement - (77.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Movement - (37.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Leading Teacher - (11 SQM)	Office (2)	
B00A - R0045 - Leading Teacher - (13.24 SQM)	Office (3)	
B00A - R0046 - Movement - (20.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Administration - Clerical - (46.72 SQM)	Office (11)	
B00A - R0049 - Pupil Entry - (22.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Clinic - Boys - (11.68 SQM)	Office (2)	
B00A - R0053 - Movement - (11.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Commonroom - (143.38 SQM)	Office (35)	
B00A - R1002 - Staff Study - (35.81 SQM)	Office (8)	
B00A - R1006 - General Learning Space - (53.5 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - General Learning Space - (53.86 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - General Learning Space - (53.86 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (55.4 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1011 - Movement - (147.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Staff Study - (34.68 SQM)	Office (8)	
B00A - R9014 - Student Canteen - (59.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R9016 - Movement - (13.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R9019 - Movement - (126.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Pupil Entry - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - General Learning Space - (47.88 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0004 - General Learning Space - (48.22 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0005 - Pupil Entry - (7.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Staff Study - (20.33 SQM)	Office (5)	
B00B - R0008 - General Learning Space - (47.87 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0009 - General Learning Space - (43.74 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0010 - General Learning Space - (39.82 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0015 - Special Learning Space - (62.84 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0019 - Computer Learning Space - (43.49 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0020 - General Learning Space - (39.44 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0021 - General Learning Space - (43.48 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0022 - General Learning Space - (47.46 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0023 - Pupil Entry - (7.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Movement - (191.03 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0032 - General Learning Space - (64.11 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0033 - Staff Study - (21.56 SQM)	● Office (5)	
B00B - R1001 - Staff Study - (27.63 SQM)	● Office (6)	
B00B - R1003 - Pupil Entry - (5.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Staff Study - (15.78 SQM)	● Office (3)	
B00B - R1005 - Performance Workspace - (81.38 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1006 - Pupil Entry - (6.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Staff Study - (35.22 SQM)	● Office (8)	
B00B - R1008 - General Learning Space - (47.79 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1009 - General Learning Space - (43.74 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R1010 - General Learning Space - (40.01 SQM) - Teaching Space: 1	● Student Space (18)	
B00B - R1011 - Pupil Entry - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R1012 - Movement - (189.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Pupil Entry - (8.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - General Learning Space - (46.1 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R1015 - General Learning Space - (41.01 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R1016 - General Learning Space - (45.21 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R1017 - General Learning Space - (49.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R9001 - General Assistants - (45.71 SQM)	● Office (11)	
B00B - R9003 - Movement - (17.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R9004 - General Learning Space - (41.97 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R9009 - Pupil Entry - (7.65 SQM)	Not Applicable	Circulation or storage space.
B00C - M2001 - Seminar - (39 SQM)	● Office (9)	
B00C - M2002 - Seminar - (70.06 SQM)	● Office (17)	
B00C - M2003 - Staff Study - (16.14 SQM)	● Office (4)	
B00C - R0001 - General Learning Space - (63.53 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0005 - Textiles Technology L.S. - (66.18 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0009 - Computer Learning Space - (60.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0014 - Workshop - (67.27 SQM)	● Student Space (31)	
B00C - R0015 - General Learning Space - (67.27 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0016 - Movement - (67.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - General Learning Space - (58.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1001 - Laboratory L.S. - (90.92 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1003 - Laboratory L.S. - (91.17 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1006 - Laboratory L.S. - (91.26 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1009 - Laboratory L.S. - (91.37 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1012 - Movement - (59.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R2001 - Workroom - (12.63 SQM)	● Office (3)	
B00C - R2002 - Workroom - (17.67 SQM)	● Office (4)	
B00C - R2005 - Seminar - (72.1 SQM)	● Office (18)	
B00C - R2009 - Seminar - (11.61 SQM)	● Office (2)	
B00C - R2010 - Seminar - (13.46 SQM)	● Office (3)	
B00C - R2011 - Main Area - (325.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R2012 - Audio Visual Workroom - (28.9 SQM)	● Student Space (13)	
B00C - R2013 - Workroom - (11.31 SQM)	● Office (2)	
B00C - R2014 - Movement - (23.73 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R2021 - Seminar - (25.26 SQM)	Office (6)	
B00C - R2023 - Movement - (28.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R9003 - Movement - (11.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Materials Technology L.S. - (101.72 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R0007 - Computer Learning Space - (79.19 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0008 - Staff Study - (57.02 SQM)	Office (14)	
B00D - R1004 - Art Learning Space - (60.76 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1005 - Art Learning Space - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1007 - Darkroom Space - (31.45 SQM)	Office (7)	
B00D - R1008 - Art Learning Space - (60.44 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1010 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Staff Study - (26.8 SQM)	Office (6)	
B00D - R2003 - Staff Study - (35.8 SQM)	Office (8)	
B00D - R2004 - Laboratory L.S. - (93.26 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R2005 - Preparation - (28.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R2008 - Laboratory L.S. - (94.18 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R3002 - General Learning Space - (71.61 SQM) - Teaching Space: 1	Student Space (33)	
B00D - R3003 - Staff Study - (16.57 SQM)	Office (4)	
B00D - R3004 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R3005 - Practice/Seminar - (25.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R3006 - Music Learning Space - (62.59 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R3008 - Music Learning Space - (80.44 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R3013 - Staff Study - (11.4 SQM)	Office (2)	
B00D - R9001 - Computer Learning Space - (89.34 SQM) - Teaching Space: 1	Student Space (41)	
B00F - R0005 - Materials Technology L.S. - (98.75 SQM) - Teaching Space: 1	Student Space (45)	
B00F - R0007 - Wood Technology Bay - (34.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Materials Technology L.S. - (171.43 SQM) - Teaching Space: 1	Student Space (79)	
B00F - R0009 - Welding Area - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Metal Technology Bay - (33.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Materials Technology L.S. - (55.44 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0013 - Welding Area - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Welding Area - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Food Technology L.S. - (35.18 SQM) - Teaching Space: 1	Student Space (16)	
B00F - R1004 - Food Technology L.S. - (74.36 SQM) - Teaching Space: 1	Student Space (34)	
B00F - R1005 - Movement - (28.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R1010 - Interview/Office - Type 1 - (13.26 SQM)	Office (3)	
B00F - R1018 - Food Technology L.S. - (99.43 SQM) - Teaching Space: 1	Student Space (46)	
B00F - R1019 - Food/Research Space - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R1023 - Movement - (8.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - General Learning Space - (52.18 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0003 - General Learning Space - (52.18 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0002 - Public Entry - (24.06 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Student Canteen - (15.9 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Multi-Purpose Space - (447.78 SQM)	Student Space (207)	
B00H - R0017 - Stage - (98.58 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Gymnasium - (477.87 SQM)	Student Space (221)	
B00I - R0012 - Staff Study - (16.09 SQM)	Office (4)	
B00N - R0001 - Welding Area - (131.68 SQM)	Not Applicable	Circulation or storage space.
B00N - R0004 - General Learning Space - Type 6 - (42.45 SQM) - Teaching Space: 1	Student Space (19)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0006 - Wood Technology Bay - (123.37 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - General Learning Space - (50.3 SQM) - Teaching Space: 1	● Student Space (23)	
B00X - R0001 - Movement - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00X - R1001 - Movement - (12.53 SQM)	Not Applicable	Circulation or storage space.
B00X - R2001 - Movement - (14.45 SQM)	Not Applicable	Circulation or storage space.
B00X - R3001 - Movement - (8.5 SQM)	Not Applicable	Circulation or storage space.
B00X - R9001 - Movement - (9.43 SQM)	Not Applicable	Circulation or storage space.