

VENTILATION AUDIT REPORT

SCHOOL:	Wakehurst Public School (4368)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Davidson
LOCAL GOVERNMENT AREA:	Northern Beaches

4368 - Wakehurst Public School
Site Plan (11369)




1:764

Printed: 17-Apr-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (58.2 SQM)	● Student Space (27)	
B00A - R0003 - Movement - (9.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Seminar/Study - (10.59 SQM)	● Office (2)	
B00A - R0008 - Movement - (9.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (18.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Sick Bay - (7.11 SQM)	● Student Space (3)	
B00A - R0015 - Duplicating Workroom - (15.96 SQM)	● Office (3)	
B00A - R0016 - Entry Vestibule - (15.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Principal - (15.12 SQM)	● Office (3)	
B00A - R0021 - Deputy Principal - (14.48 SQM)	● Office (3)	
B00A - R0022 - Clerical Office - (14.36 SQM)	● Office (3)	
B00A - R0027 - Reading Area - (181.94 SQM)	● Student Space (84)	
B00A - R0028 - Seminar/Study - (11.89 SQM)	● Office (2)	
B00A - R0029 - Staff Room - (78.52 SQM)	● Office (19)	
B00A - R0033 - Sick Bay - (6.25 SQM)	● Student Space (2)	
B00B - R0001 - Movement - (12.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Canteen - (17.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (57.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0014 - Home Base - (56.67 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0015 - Home Base - (56.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0020 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Home Base - (56.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0026 - Home Base - (56.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0034 - Home Base - (57.37 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0001 - Home Base - (57.29 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0010 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0011 - Home Base - (58.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0016 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0005 - Raised Platform - (30.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Communal Space - (25.87 SQM)	● Student Space (12)	
B00F - R0007 - Communal Space - (85.62 SQM)	● Student Space (39)	
B00F - R0010 - Movement - (7.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Home Base - (85.23 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0017 - Home Base - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0023 - Outdoor Learning Area - (138.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (58.94 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0006 - Home Base - (57.44 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0010 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Home Base - (57.12 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0017 - Movement - (10.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Deputy Principal - (16.75 SQM)	● Office (4)	
B00G - R0021 - Movement - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Interview - (25.81 SQM)	● Office (6)	
B00G - R0027 - Movement - (19.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Home Base - (56.46 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0031 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0035 - Home Base - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0001 - Communal Space - (145.34 SQM)	 Student Space (67)	
B00H - R0014 - Movement - (14.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Raised Platform - (59.72 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (10.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Canteen - (26.54 SQM)	Not Applicable	Circulation or storage space.