

VENTILATION AUDIT REPORT

SCHOOL:	Walbundrie Public School (3338)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Albury
LOCAL GOVERNMENT AREA:	Greater Hume

3338 - Walbundrie Public School
Site Plan (12015)













1:899

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Principal - (9.17 SQM)	 Office (2)	
B00A - R0005 - Clerical Office - (10.11 SQM)	 Office (2)	
B00A - R0006 - Staff Room - (7.5 SQM)	 Office (1)	
B00A - R0007 - Movement - (15.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Reading Area - (12.73 SQM)	 Student Space (5)	
B00A - R0010 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Home Base/Practical Activities - (53.5 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0012 - Clerical Office/Workroom - (15.73 SQM)	 Office (3)	
B00A - R0014 - Principal - (14.16 SQM)	 Office (3)	
B00C - R0001 - Movement - (33.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Special Programs Room - (20.28 SQM)	 Student Space (9)	
B00D - R0001 - Reading Area - (23.76 SQM)	 Student Space (11)	
B00E - R0001 - Home Base - (59.83 SQM) - Teaching Space: 1	 Student Space (27)	