

VENTILATION AUDIT REPORT

SCHOOL:	Walcha Central School (3340)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Walcha

3340 - Walcha Central School
Site Plan (12894)



1:1,833

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (12.96 SQM)	Office (3)	
B00A - R0002 - Public Entry - (24.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Teachers Aides - (14.44 SQM)	Office (3)	
B00A - R0009 - Interview - (12.98 SQM)	Office (3)	
B00A - R0013 - Staff Room Annexe - (12.92 SQM)	Office (3)	
B00A - R0014 - Deputy Principal - (15.84 SQM)	Office (3)	
B00A - R0015 - Pupil Entry - (13.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Staff Room Annexe - (13.46 SQM)	Office (3)	
B00A - R0017 - Staff Room - (75.17 SQM)	Office (18)	
B00A - R0018 - Staff Room Annexe - (20.59 SQM)	Office (5)	
B00A - R0025 - Movement - (56.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Principal - (24.92 SQM)	Office (6)	
B00A - R0029 - Clerical Office - (50.8 SQM)	Office (12)	
B00A - R0030 - Clerical/Printing - (23.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Interview/Office - Type 1 - (14.09 SQM)	Office (3)	
B00B - R0003 - Reading Area - (262.89 SQM)	Student Space (121)	
B00B - R0006 - Seminar/Study - (13.06 SQM)	Office (3)	
B00B - R0007 - Seminar/Study - (12.58 SQM)	Office (3)	
B00B - R0016 - Special Programs Room - (106.38 SQM)	Student Space (49)	
B00C - R0001 - Movement - (182.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Withdrawal Space - 1hb - (5.93 SQM)	Student Space (2)	
B00C - R0005 - Home Base - (60.99 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0007 - Practical Activities - 1hb - (18.3 SQM)	Student Space (8)	
B00C - R0008 - Practical Activities - 1hb - (18.35 SQM)	Student Space (8)	
B00C - R0009 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0010 - Withdrawal Space - 1hb - (12.74 SQM)	Student Space (5)	
B00C - R0014 - Home Base - (61.46 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0015 - Practical Activities - 1hb - (18.3 SQM)	Student Space (8)	
B00C - R0018 - Withdrawal Space - 1hb - (6.26 SQM)	Student Space (2)	
B00C - R0019 - Home Base - (61.31 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0020 - Practical Activities - 1hb - (18.12 SQM)	Student Space (8)	
B00C - R0021 - Practical Activities - 1hb - (18.12 SQM)	Student Space (8)	
B00C - R0022 - Home Base - (61.07 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0023 - Withdrawal Space - 1hb - (6.21 SQM)	Student Space (2)	
B00D - R0001 - General Learning Space - (41.66 SQM) - Teaching Space: 1	Student Space (19)	
B00D - R0006 - Special Programs Room - (79.46 SQM)	Student Space (36)	
B00E - R0002 - Movement - (15.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (24.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Raised Platform - (98.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (10.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (134.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Staff Kitchen - (9.84 SQM)	Office (2)	
B00E - R0017 - Canteen - (34.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Multi-Purpose Space - (421.86 SQM)	Student Space (195)	
B00E - R0023 - Movement - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Computer Learning Space - (67.32 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0004 - General Learning Space - (53.22 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0005 - Staff Room Annexe - (22.44 SQM)	Office (5)	
B00F - R0006 - General Learning Space - (54.24 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0007 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0008 - General Learning Space - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0009 - General Learning Space - (52.48 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0010 - Preparation - (28.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Laboratory L.S. - (100.59 SQM) - Teaching Space: 1	Student Space (46)	
B00F - R0012 - Movement - (126.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R9001 - Staff Kitchen - (9.37 SQM)	Office (2)	
B00F - R9005 - General Learning Space - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R9006 - Senior Seminar - (67.46 SQM)	Office (16)	
B00G - R0001 - Workshop - (44.4 SQM)	Student Space (20)	
B00G - R0003 - Art Learning Space - (76.11 SQM) - Teaching Space: 1	Student Space (35)	
B00G - R0006 - Interview - (23.49 SQM)	Office (5)	
B00G - R0007 - Darkroom Space - (5.71 SQM)	Office (1)	
B00J - R0002 - Movement - (30.44 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Music Learning Space - (89.58 SQM) - Teaching Space: 1	Student Space (41)	
B00K - R0009 - Design L.S. - (56.37 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0012 - Welding Area - (7.04 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Materials Technology L.S. - (166.24 SQM) - Teaching Space: 1	Student Space (77)	
B00K - R0017 - Outdoor Learning Space - Type 1 - (75.29 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Staff Room Annexe - (22.24 SQM)	Office (5)	
B00L - R0003 - General Learning Space - (52.4 SQM) - Teaching Space: 1	Student Space (24)	
B00L - R0004 - General Learning Space - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00L - R0005 - Design L.S. - (45.33 SQM) - Teaching Space: 1	Student Space (21)	
B00L - R0008 - Movement - (44.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Movement - (14.45 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Food Technology L.S. - (84.46 SQM) - Teaching Space: 1	Student Space (39)	
B00L - R0019 - Preparation - Materials - (22.12 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Laboratory L.S. - (94.48 SQM) - Teaching Space: 1	Student Space (43)	
B00M - R0003 - Preparation - (29.21 SQM)	Not Applicable	Circulation or storage space.
B00M - R0005 - Staff Room Annexe - (26.49 SQM)	Office (6)	
B00M - R0006 - General Learning Space - (54.02 SQM) - Teaching Space: 1	Student Space (25)	
B00M - R0007 - Movement - (63.44 SQM)	Not Applicable	Circulation or storage space.
B00M - R9003 - Study Space - (18.29 SQM)	Not Applicable	Circulation or storage space.
B00M - R9006 - Home Base - (53.64 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R9007 - General Learning Space - (53.64 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R9009 - Movement - (49.38 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Home Base - (60.9 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0003 - Practical Activities - 1hb - (14.1 SQM)	Student Space (6)	
B00N - R0005 - Movement - (25.52 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Home Base - (60.9 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0007 - Practical Activities - 1hb - (14.4 SQM)	Student Space (6)	
B00N - R0015 - Practical Activities - 1hb - (14.13 SQM)	Student Space (6)	
B00N - R0017 - Home Base - (60.9 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0018 - Practical Activities - 1hb - (14.13 SQM)	Student Space (6)	
B00N - R0020 - Home Base - (60.9 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0021 - Special Programs Room - (17.18 SQM)	Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0022 - Movement - (25.76 SQM)	Not Applicable	Circulation or storage space.
B00S - R0002 - Canteen - (30.86 SQM)	Not Applicable	Circulation or storage space.