


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Walgett Community College - High School (8475)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Barwon</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Walgett</b>

8475 - Walgett Community College - High School  
Site Plan (13361)



1:1,021

Printed: 13-Feb-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0028 - Interview/Meeting - (25.23 SQM)	Office (6)	
B00A - R0029 - General Learning Space - Type 2 - (74.36 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R0034 - Interview/Meeting - (16.81 SQM)	Office (4)	
B00A - R0035 - Interview/Meeting - (20.18 SQM)	Office (5)	
B00A - R0036 - Interview/Meeting - (20.51 SQM)	Office (5)	
B00A - R0037 - Movement - (15.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Interview/Office - Type 1 - (11.87 SQM)	Office (2)	
B00A - R1008 - Staff Study - (11.81 SQM)	Office (2)	
B00A - R1012 - General Learning Space - Type 1 - (54.11 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1013 - General Learning Space - Type 2 - (65.61 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1014 - General Learning Space - Type 1 - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0011 - Interview/Meeting - (13.83 SQM)	Office (3)	
B00B - R0012 - Public Entry - (18.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Pupil Entry - (7.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Interview/Meeting - (15.1 SQM)	Office (3)	
B00B - R0017 - Deputy Principal Office - (14.72 SQM)	Office (3)	
B00B - R0018 - Deputy Principal Office - (15.1 SQM)	Office (3)	
B00B - R0019 - Principal Office - (20.02 SQM)	Office (5)	
B00B - R0020 - Tea Room - (12.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Administration - Clerical - (60.76 SQM)	Office (15)	
B00B - R1001 - Audio Visual Workroom - (12.56 SQM)	Student Space (5)	
B00B - R1002 - Workroom - (12.59 SQM)	Office (3)	
B00B - R1004 - Main Area - (152.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Seminar - (15.92 SQM)	Office (3)	
B00B - R1006 - Seminar - (15.99 SQM)	Office (3)	
B00B - R1009 - Study Space - (16.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Study Space - (16.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Student Canteen - (35.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R1034 - General Learning Space - Type 1 - (51.5 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1035 - General Learning Space - Type 2 - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1036 - General Learning Space - Type 1 - (52.38 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1039 - Outdoor Learning Space - Type 1 - (28.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R1040 - General Learning Space - Type 1 - (56.46 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1041 - General Learning Space - Type 1 - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1042 - General Learning Space - Type 2 - (59.39 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1043 - General Learning Space - Type 1 - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1046 - Outdoor Learning Space - Type 1 - (26.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1047 - General Learning Space - Type 1 - (54.13 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0010 - Kitchen - Type 2 - (18.26 SQM)	Student Space (8)	
B00D - R0011 - Kitchen - Type 1 - (79.04 SQM)	Student Space (36)	
B00E - R0003 - General Learning Space - (52.31 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0013 - Staff Lounge - (131.94 SQM)	Office (32)	
B00E - R0014 - Special Learning Space - (51.95 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0002 - Staff Study - (11.75 SQM)	Office (2)	
B00F - R0010 - Art Learning Space - (90.13 SQM) - Teaching Space: 1	Student Space (41)	
B00G - R0013 - Staff Kitchen - (16 SQM)	Office (4)	
B00G - R0022 - Staff Lounge - (60.31 SQM)	Office (15)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0001 - Materials Technology L.S. - (85.96 SQM) - Teaching Space: 1	● Student Space (39)	
B00H - R0002 - Welding Area - (17.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (30.97 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Materials Technology L.S. - (125.02 SQM) - Teaching Space: 1	● Student Space (58)	
B00J - R0001 - Design L.S. - (74.39 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0003 - Movement - (28.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Movement - (35.93 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Movement - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Staff Kitchen - (13.66 SQM)	● Office (3)	
B00K - R0017 - Staff Study - (11.74 SQM)	● Office (2)	
B00K - R0020 - Multi-Purpose Space - (460.66 SQM)	● Student Space (213)	
B00K - R0021 - Stage - (59.72 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - General Learning Space - (59.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0002 - Science Laboratory - (59.91 SQM)	● Student Space (27)	
B00O - R0003 - Preparation - Science - (31.07 SQM)	Not Applicable	Circulation or storage space.
B00O - R0006 - Staff Study - (21.08 SQM)	● Office (5)	
B00O - R0007 - Seminar - Type 2 - (21.08 SQM)	● Office (5)	
B00O - R0008 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00O - R0011 - Outdoor Learning Space - Type 4 - (40.38 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Growing/Breeding - (8.72 SQM)	Not Applicable	Circulation or storage space.
B00S - R0007 - Movement - (26.28 SQM)	Not Applicable	Circulation or storage space.
OS 505 14657 - OS 505 14657 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	
OS 601 13578 - OS 601 13578 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14327 - OS 601 14327 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	