

VENTILATION AUDIT REPORT

SCHOOL:	Walgett Community College - Public School (3342)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Walgett

3342 - Walgett Community College - Public School
Site Plan (13208)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (15.73 SQM)	Office (3)	
B00A - R0009 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (31.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Interview - (15.59 SQM)	Office (3)	
B00A - R0018 - Staff Room Annexe - (11.83 SQM)	Office (2)	
B00A - R0021 - Principal - (15.32 SQM)	Office (3)	
B00A - R0027 - Movement - (29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Entry Vestibule - (13.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (36.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Clerical Office/Workroom - (32.67 SQM)	Office (8)	
B00A - R0034 - Clerical Office - (17.87 SQM)	Office (4)	
B00A - R0035 - Sick Bay - (10.49 SQM)	Student Space (4)	
B00A - R0036 - Movement - (22.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Deputy Principal - (17.81 SQM)	Office (4)	
B00A - R0038 - Clerical Office - (11.17 SQM)	Office (2)	
B00A - R0039 - Staff Room - (76.44 SQM)	Office (19)	
B00A - R0040 - Staff Kitchen - (14.13 SQM)	Office (3)	
B00A - R1001 - Movement - (16.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Reading Area - (123.18 SQM)	Student Space (57)	
B00A - R1006 - Movement - (54.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Movement - (16.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Home Base - (60.08 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1009 - Practical Activities - (13.36 SQM)	Student Space (6)	
B00A - R1010 - Practical Activities - (13.8 SQM)	Student Space (6)	
B00A - R1011 - Home Base - (45.18 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R1013 - Withdrawal - Pre - (9.44 SQM)	Student Space (4)	
B00B - R0001 - Home Base - (58.83 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0002 - Practical Activities - 1hb - (13.69 SQM)	Student Space (6)	
B00B - R0003 - Movement - (36.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Practical Activities - (13.69 SQM)	Student Space (6)	
B00B - R0006 - Home Base - (59.71 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0007 - Home Base - (59.88 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0008 - Practical Activities - (13.2 SQM)	Student Space (6)	
B00B - R0009 - Movement - (27.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (55.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (59.12 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0013 - Practical Activities - 1hb - (13.69 SQM)	Student Space (6)	
B00B - R1001 - Movement - (16.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Practical Activities - 1hb - (24.26 SQM)	Student Space (11)	
B00B - R1003 - Home Base - (49.12 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1004 - Home Base - (49.01 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1005 - Practical Activities - (23.58 SQM)	Student Space (10)	
B00B - R1006 - Movement - (16.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Movement - (56.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1009 - Practical Activities - 1hb - (13.12 SQM)	Student Space (6)	
B00B - R1011 - Practical Activities - 1hb - (13.02 SQM)	Student Space (6)	
B00B - R1012 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0003 - Movement - (162.9 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0004 - Principal Office - (11.24 SQM)	Office (2)	
B00C - R0005 - Clerical Office/Workroom - (59 SQM)	Office (14)	
B00C - R0006 - Movement - (6.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Home Base - (85.32 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0015 - Home Base - (85.48 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0021 - Home Base - (56.89 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0022 - Movement - (103.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (49.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (10.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (80.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1007 - Home Base - (59.27 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0001 - Staff Room - (52.59 SQM)	Office (13)	
B00E - R0003 - Staff Room - (52.52 SQM)	Office (13)	
B00E - R0004 - Movement - (26.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (109.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Communal Space - (357.54 SQM)	Student Space (165)	
B00G - R0002 - Communal Space - (53.51 SQM)	Student Space (24)	
B00G - R0005 - Movement - (38.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (83.28 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (72.86 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Canteen - (24.92 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Home Base - Pre - (67.92 SQM) - Teaching Space: 1	Student Space (31)	
OS 523 16795 - OS 523 16795 - Staff Study With Toilets - (76 SQM)	Office (19)	