


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Walla Walla Public School (3352)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Albury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Greater Hume</b>

3352 - Walla Walla Public School  
Site Plan (11370)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (45.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (23.21 SQM)	Office (5)	
B00A - R0003 - Entry Vestibule - (12.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Principal - (12.08 SQM)	Office (3)	
B00A - R0007 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Practical Activities - 1hb - (41.38 SQM)	Student Space (19)	
B00A - R0010 - Home Base - (56.44 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0013 - Withdrawal Space - 1hb - (10.44 SQM)	Student Space (4)	
B00A - R0015 - Home Base - (55.96 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0023 - Home Base - (56.43 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0025 - Withdrawal Space - 1hb - (10.38 SQM)	Student Space (4)	
B00A - R0028 - Home Base - (56.5 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0029 - Movement - (52.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Practical Activities - 1hb - (41.39 SQM)	Student Space (19)	
B00A - R0034 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Sick Bay - (8.19 SQM)	Student Space (3)	
B00A - R0037 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Room - (30.57 SQM)	Office (7)	
B00B - R0002 - Movement - (30.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Reading Area - (77.48 SQM)	Student Space (35)	
B00E - R0001 - Canteen - (13.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Withdrawal Space - 1hb - (17.68 SQM)	Student Space (8)	