


VENTILATION AUDIT REPORT

SCHOOL:	Wallacia Public School (3346)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mulgoa
LOCAL GOVERNMENT AREA:	Penrith

3346 - Wallacia Public School
Site Plan (12016)



1:904

Printed: 17-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (13.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (9.33 SQM)	Office (2)	
B00A - R0005 - Staff Room - (21.71 SQM)	Office (5)	
B00A - R0006 - Duplicating Workroom - (13.68 SQM)	Office (3)	
B00A - R0010 - Clerical Office - (8.21 SQM)	Office (2)	
B00A - R0011 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Principal - (12.78 SQM)	Office (3)	
B00A - R0015 - Movement - (24.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (23.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Withdrawal Space - 1hb - (14.4 SQM)	Student Space (6)	
B00B - R0003 - Home Base - (35.01 SQM) - Teaching Space: 1	Student Space (16)	
B00D - R0002 - Movement - (14.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Withdrawal Space - 1hb - (14.33 SQM)	Student Space (6)	
B00D - R0005 - Home Base - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Movement - (36.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (85.61 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0005 - Practical Activities - 1hb - (14.98 SQM)	Student Space (6)	
B00H - R0001 - Movement - (11.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (61.77 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0005 - Withdrawal Space - 1hb - (11.29 SQM)	Student Space (5)	
B00H - R0007 - Home Base - (61.45 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0009 - Canteen - (44.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (22.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Home Base - (61.8 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0017 - Withdrawal Space - 1hb - (5.69 SQM)	Student Space (2)	
B00H - R0018 - Practical Activities - 1hb - (22.59 SQM)	Student Space (10)	
B00I - R0002 - Reading Area - (90.18 SQM)	Student Space (41)	