

VENTILATION AUDIT REPORT































SCHOOL:	Wallsend Public School (3357)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Wallsend
LOCAL GOVERNMENT AREA:	Newcastle

3357 - Wallsend Public School
Site Plan (11929)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0015 - Home Base - (49.17 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0016 - Home Base - (50.24 SQM) - Teaching Space: 1	 Student Space (23)	
B00A - R0020 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (54.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Reading Area - (29.56 SQM)	 Student Space (13)	
B00A - R0023 - Practical Activities - 1hb - (13 SQM)	 Student Space (6)	
B00A - R0024 - Staff Room - (38.07 SQM)	 Office (9)	
B00A - R0025 - Staff Kitchen - (9.36 SQM)	 Office (2)	
B00A - R0029 - Duplicating Workroom - (20.81 SQM)	 Office (5)	
B00A - R0030 - Movement - (6.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (32.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Clerical Office - (14.54 SQM)	 Office (3)	
B00A - R0033 - Sick Bay - (7.84 SQM)	 Student Space (3)	
B00A - R0034 - Interview - (10.28 SQM)	 Office (2)	
B00A - R0035 - Deputy Principal - (12.28 SQM)	 Office (3)	
B00A - R0040 - Principal - (14.56 SQM)	 Office (3)	
B00A - R9005 - Movement - (46.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (67.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (7.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (56.68 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R0005 - Home Base - (54.53 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R0006 - Home Base - (54.67 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R0007 - Home Base - (55.45 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R0011 - Practical Activities - 1hb - (21.36 SQM)	 Student Space (9)	
B00C - R0001 - Movement - (99.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (15.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Home Base - (68.37 SQM) - Teaching Space: 1	 Student Space (31)	
B00C - R0012 - Home Base - (54.52 SQM) - Teaching Space: 1	 Student Space (25)	
B00C - R0016 - Practical Activities - 3hb - (24.65 SQM)	 Student Space (11)	
B00C - R0017 - Home Base - (65.46 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R0018 - Home Base - (65.61 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R0001 - Movement - (26.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (6.78 SQM)	 Student Space (3)	
B00G - R0003 - Home Base - (53.96 SQM) - Teaching Space: 1	 Student Space (25)	
B00G - R0004 - Home Base - (53.88 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0005 - Practical Activities - 1hb - (6.78 SQM)	 Student Space (3)	
B00G - R0008 - Withdrawal Space - 1hb - (12.86 SQM)	 Student Space (5)	
B00K - R0001 - Communal Space - (163.63 SQM)	 Student Space (75)	
B00K - R0002 - Movement - (48.29 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Movement - (265.51 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Canteen - (28.03 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Special Programs Room - (51.23 SQM)	 Student Space (23)	
B00M - R0007 - Reading Area - (166.6 SQM)	 Student Space (77)	