


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Waniora Public School (3960)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Keira</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollongong</b>



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0019 - Practical Activities - (15.25 SQM)	Student Space (7)	
B00A - R0020 - Withdrawal Space - 2hb - (12.14 SQM)	Student Space (5)	
B00A - R0021 - Practical Activities - (12.39 SQM)	Student Space (5)	
B00A - R0022 - Entry Vestibule - (8.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Practical Activities - (11.09 SQM)	Student Space (5)	
B00A - R0024 - Withdrawal Space - 2hb - (11.12 SQM)	Student Space (5)	
B00A - R0025 - Practical Activities - (18.06 SQM)	Student Space (8)	
B00A - R0026 - Home Base - (63.06 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0027 - Home Base - (57.36 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0030 - Home Base - (57.47 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0031 - Home Base - (67.79 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0025 - Duplicating Workroom - (15.87 SQM)	Office (3)	
B00B - R0026 - Clerical Office - (36.69 SQM)	Office (9)	
B00B - R0027 - Entry Vestibule - (15.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Interview - (15.21 SQM)	Office (3)	
B00B - R0029 - Movement - (41.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0032 - Staff Room Annexe - (21.8 SQM)	Office (5)	
B00B - R0033 - Staff Room - (52.64 SQM)	Office (13)	
B00B - R0034 - Movement - (65.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Sick Bay - (10.63 SQM)	Student Space (4)	
B00B - R0040 - Interview/Office - Type 3 - (17.06 SQM)	Office (4)	
B00B - R0043 - Principal - (16.89 SQM)	Office (4)	
B00B - R0044 - Deputy Principal - (15.38 SQM)	Office (3)	
B00B - R0049 - Staff Kitchen - (10.6 SQM)	Office (2)	
B00C - R0001 - Reading Area - (168.44 SQM)	Student Space (78)	
B00D - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00D - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00D - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00E - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00E - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00E - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00F - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00F - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00F - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00H - R0001 - Canteen - (27.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Communal Space - (238.5 SQM)	Student Space (110)	
OS 601 16157 - OS 601 16157 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 12760 - OS 602 12760 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12949 - OS 602 12949 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13723 - OS 602 13723 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14235 - OS 602 14235 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 606 19015 - OS 606 19015 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19110 - OS 606 19110 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	