

VENTILATION AUDIT REPORT

SCHOOL:	Waratah West Public School (3932)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Wallsend
LOCAL GOVERNMENT AREA:	Newcastle

3932 - Waratah West Public School
Site Plan (11781)



1:1,156

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Interview - (11.77 SQM)	Office (2)	
B00A - R0009 - Deputy Principal - (13.74 SQM)	Office (3)	
B00A - R0011 - Principal - (17.2 SQM)	Office (4)	
B00A - R0014 - Sick Bay - (8.54 SQM)	Student Space (3)	
B00A - R0018 - Movement - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Interview - (15.86 SQM)	Office (3)	
B00A - R0022 - Staff Room - (34.4 SQM)	Office (8)	
B00A - R0023 - Staff Kitchen - (12.75 SQM)	Office (3)	
B00A - R0024 - Movement - (15.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Clerical Office - (21.25 SQM)	Office (5)	
B00A - R0028 - Movement - (15.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (14.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (56.29 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0003 - Movement - (9.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Reading Area - (113.2 SQM)	Student Space (52)	
B00B - R0010 - Movement - (9.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Home Base - (71.52 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R9001 - Movement - (69.84 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (106.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Canteen - (19.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (9.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (57.4 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R9001 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R9002 - Movement - (43.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R9007 - Movement - (11.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R9008 - Movement - (11.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (57.63 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0004 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Practical Activities - 2hb - (5.05 SQM)	Student Space (2)	
B00E - R0014 - Home Base - (32.98 SQM) - Teaching Space: 1	Student Space (15)	
B00G - R0004 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (11.29 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Staff Room Annexe - (18.98 SQM)	Office (4)	
B00H - R0004 - Movement - (91.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Home Base - (53.48 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0006 - Home Base - (53.4 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0009 - Communal Space - (107.39 SQM)	Student Space (49)	
B00I - R0001 - Movement - (24.24 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (13.45 SQM)	Student Space (6)	
B00I - R0003 - Home Base - (74.21 SQM) - Teaching Space: 1	Student Space (34)	