


VENTILATION AUDIT REPORT


















SCHOOL:	Wardell Public School (3378)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Ballina

3378 - Wardell Public School
Site Plan (14632)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Home Base - (64.24 SQM) - Teaching Space: 1	 Student Space (29)	
B00A - R0012 - Special Programs Room - (39.33 SQM)	 Student Space (18)	
B00C - R0001 - Practical Activities - 1hb - (16.64 SQM)	 Student Space (7)	
B00C - R0002 - Home Base - (56.4 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0003 - Reading Area - (52.46 SQM)	 Student Space (24)	
B00C - R0005 - Duplicating Workroom - (9.17 SQM)	 Office (2)	
B00D - R0004 - Movement - (18.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Withdrawal Space - 1hb - (16.12 SQM)	 Student Space (7)	
B00E - R0007 - Practical Activities - 1hb - (25.15 SQM)	 Student Space (11)	
B00E - R0009 - Staff Room - (16.9 SQM)	 Office (4)	
B00E - R0015 - Principal - (21.64 SQM)	 Office (5)	
B00E - R0016 - Entry Vestibule - (10.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Sick Bay - (7.03 SQM)	 Student Space (3)	
B00F - R0001 - Canteen - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (11.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Special Programs Room - (6.96 SQM)	 Student Space (3)	
B00I - R0002 - Practical Activities - 1hb - (19.62 SQM)	 Student Space (9)	
B00I - R0004 - Home Base - (59.32 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (10.89 SQM)	 Student Space (5)	
B00I - R0006 - Home Base - (58.78 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.59 SQM)	 Student Space (9)	