

VENTILATION AUDIT REPORT

SCHOOL:	Warners Bay High School (8440)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Charlestown
LOCAL GOVERNMENT AREA:	Lake Macquarie

8440 - Warners Bay High School
Site Plan (11380)



1:1,599

Printed: 21-Mar-2020


Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Ancillary Staff - (32.61 SQM)	Office (8)	
B00A - R0003 - Clinic - Boys - (12.19 SQM)	Office (3)	
B00A - R0006 - Clinic - Girls - (13.71 SQM)	Office (3)	
B00A - R0009 - Principal Office - (19.58 SQM)	Office (4)	
B00A - R0010 - Leading Teacher - (13 SQM)	Office (3)	
B00A - R0011 - Deputy Principal Office - (13 SQM)	Office (3)	
B00A - R0012 - Duplicating Workroom - (26.33 SQM)	Office (6)	
B00A - R0018 - Interview/Office - Type 1 - (9.1 SQM)	Office (2)	
B00A - R0022 - Laboratory L.S. - (86.66 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0023 - Preparation - (18.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Preparation - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Study - (37.98 SQM)	Office (9)	
B00A - R0026 - Deputy Principal Office - (26.03 SQM)	Office (6)	
B00A - R0028 - Movement - (219.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Public Reception - (32.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Administration - Clerical - (57.75 SQM)	Office (14)	
B00A - R0033 - Movement - (23.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Music Learning Space - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1003 - Music Learning Space - (65.75 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1004 - General Learning Space - (60.13 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1005 - General Learning Space - (53.47 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1006 - Computer Learning Space - (53.55 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - General Learning Space - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1008 - Leading Teacher - (7.62 SQM)	Office (1)	
B00A - R1010 - Leading Teacher - (13.11 SQM)	Office (3)	
B00A - R1011 - General Learning Space - (54.13 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1017 - Staff Study - (13.29 SQM)	Office (3)	
B00A - R1019 - Music Learning Space - (53.4 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1024 - Movement - (115.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - Movement - (11.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1028 - General Learning Space - (53.35 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0001 - Staff Study - (73.54 SQM)	Office (18)	
B00B - R0004 - Laboratory L.S. - (93.41 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0005 - Preparation - (9.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Preparation - (28.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Laboratory L.S. - (94.05 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0010 - Senior Study - (41.58 SQM)	Office (10)	
B00B - R0013 - Laboratory L.S. - (94.26 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0014 - Preparation - (8.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Preparation - (24.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (205.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Staff Study - (32.84 SQM)	Office (8)	
B00B - R1004 - General Learning Space - (54.43 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1005 - General Learning Space - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1009 - Stage - (25.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Performance Workspace - (53.11 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1011 - General Learning Space - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1014 - General Learning Space - (54.07 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1017 - General Learning Space - (59.87 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1018 - General Learning Space - (53.25 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1019 - General Learning Space - (53.19 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1021 - Leading Teacher - (12.93 SQM)	Office (3)	
B00B - R1025 - Movement - (117.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R1030 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Laboratory L.S. - (100.03 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R0004 - General Learning Space - (66.04 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0005 - Laboratory L.S. - (86.4 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R0006 - Preparation - (19.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Computer Learning Space - (53.41 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0012 - Leading Teacher - (13.22 SQM)	Office (3)	
B00C - R0013 - Ancillary Staff - (13.63 SQM)	Office (3)	
B00C - R0016 - Laboratory L.S. - (87.03 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R0017 - Preparation - (29.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Preparation - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (149.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (60.13 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1004 - General Learning Space - (65.95 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1005 - General Learning Space - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1006 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1007 - General Learning Space - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1008 - Computer Learning Space - (60.51 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1009 - Staff Study - (22.29 SQM)	Office (5)	
B00C - R1010 - General Learning Space - (54.88 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1013 - Staff Study - (87.11 SQM)	Office (21)	
B00C - R1014 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1016 - Leading Teacher - (12.61 SQM)	Office (3)	
B00C - R1024 - Movement - (118.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Main Area - (432.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Seminar - (25.87 SQM)	Office (6)	
B00D - R0010 - General Learning Space - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0011 - Leading Teacher - (12.65 SQM)	Office (3)	
B00D - R0017 - Audio Visual Workroom - (32.43 SQM)	Student Space (15)	
B00D - R0018 - Seminar - (12.31 SQM)	Office (3)	
B00D - R0019 - Seminar - (10.75 SQM)	Office (2)	
B00D - R0020 - Seminar - (10.84 SQM)	Office (2)	
B00D - R0026 - Movement - (192.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Staff Study - (60.33 SQM)	Office (15)	
B00D - R1002 - Textiles Technology L.S. - (72.49 SQM) - Teaching Space: 1	Student Space (33)	
B00D - R1009 - General Learning Space - (53.71 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - General Learning Space - (59.87 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1013 - General Learning Space - (53.04 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1014 - General Learning Space - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1015 - Computer Learning Space - (68.42 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R1017 - Computer Learning Space - (50.31 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1020 - General Learning Space - (58.8 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1023 - Staff Study - (20.8 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1024 - Leading Teacher - (12.74 SQM)	Office (3)	
B00D - R1025 - Commonroom - (109.18 SQM)	Office (27)	
B00D - R1027 - Seminar - (32.95 SQM)	Office (8)	
B00D - R1035 - Movement - (163.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Wood Technology L.S. - (81.65 SQM) - Teaching Space: 1	Student Space (37)	
B00E - R0007 - Food Technology L.S. - (72.72 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0009 - Food/Research Space - (15.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Food Technology L.S. - (66.08 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0011 - Staff Study - (17.15 SQM)	Office (4)	
B00E - R0013 - Staff Study - (16.95 SQM)	Office (4)	
B00E - R0015 - Textiles Technology L.S. - (54.73 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0018 - Wood Technology L.S. - (78.24 SQM) - Teaching Space: 1	Student Space (36)	
B00E - R0022 - Staff Study - (37.49 SQM)	Office (9)	
B00E - R0024 - Movement - (147.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Art Learning Space - (68.1 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R1008 - Design L.S. - (59.64 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1009 - Leading Teacher - (11.54 SQM)	Office (2)	
B00E - R1010 - Leading Teacher - (13.76 SQM)	Office (3)	
B00E - R1013 - Workshop - (61.89 SQM)	Student Space (28)	
B00E - R1014 - Art Learning Space - (59.27 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1017 - Art Learning Space - (67.5 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R1019 - Metal Technology Bay - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R1020 - Metal Technology L.S. - (99.89 SQM) - Teaching Space: 1	Student Space (46)	
B00E - R1021 - Wood Technology L.S. - (79.4 SQM) - Teaching Space: 1	Student Space (36)	
B00E - R1023 - Movement - (100.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Student Canteen - (57.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (403.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (279.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Darkroom Space - (10.58 SQM)	Office (2)	
B00F - R1005 - Dark Room - (38.89 SQM)	Office (9)	
B00F - R1006 - Staff Study - (38.19 SQM)	Office (9)	
B00F - R1007 - Preparation - (10.43 SQM)	Not Applicable	Circulation or storage space.
B00G - M0001 - Stage - (87.3 SQM)	Not Applicable	Circulation or storage space.
B00G - M0002 - Stage - (88.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Student Canteen - (11.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Staff Study - (22.27 SQM)	Office (5)	
B00G - R0014 - Movement - (14.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Multi-Purpose Space - (471.85 SQM)	Student Space (218)	
B00G - R0017 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Movement - (41.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - General Learning Space - (87.17 SQM) - Teaching Space: 1	Student Space (40)	
OS 600 13090 - OS 600 13090 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 10867 - OS 601 10867 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11721 - OS 601 11721 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11722 - OS 601 11722 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14855 - OS 601 14855 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15061 - OS 601 15061 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 621 11744 - OS 621 11744 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	