

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Warners Bay Public School (3384)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Charlestown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

3384 - Warners Bay Public School  
Site Plan (11972)



1:810

Printed: 18-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (95.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Communal Space - (186.68 SQM)	● Student Space (86)	
B00A - R0009 - Canteen - (43.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (31.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Raised Platform - (53.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (16.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (8.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (57.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0005 - Home Base - (57.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0007 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (53.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Movement - (8.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Home Base - (58.06 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1008 - Home Base - (58.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0009 - Reading Area - (179.93 SQM)	● Student Space (83)	
B00D - R0014 - Movement - (20.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (46.62 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0004 - Practical Activities - 1hb - (53.59 SQM)	● Student Space (24)	
B00E - R0005 - Staff Room Annexe - (11.59 SQM)	● Office (2)	
B00E - R0006 - Home Base - (47.75 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0007 - Home Base - (47.81 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0001 - Home Base - (56.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0003 - Movement - (9.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (56.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0007 - Movement - (9.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0002 - Practical Activities - 1hb - (18.55 SQM)	● Student Space (8)	
B00G - R0005 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0009 - Practical Activities - 1hb - (18.62 SQM)	● Student Space (8)	
B00G - R0010 - Home Base - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0013 - Movement - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0017 - Movement - (11.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (11.04 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Staff Room Annexe - (18.04 SQM)	● Office (4)	
B00H - R0006 - Movement - (19.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Staff Room Annexe - (17.4 SQM)	● Office (4)	
B00H - R0011 - Home Base - (65.63 SQM)	● Student Space (30)	
B00H - R0012 - Home Base - (74.56 SQM)	● Student Space (34)	
B00H - R0013 - Practical Activities - 1hb - (20.44 SQM)	● Student Space (9)	
B00H - R0016 - Movement - (10.16 SQM)	Not Applicable	Circulation or storage space.
B00H - R0021 - Movement - (105.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0023 - Staff Kitchen - (5.88 SQM)	● Office (1)	
B00H - R0024 - Staff Room Annexe - (23.36 SQM)	● Office (5)	
B00H - R0025 - Home Base - (73.42 SQM) - Teaching Space: 1	● Student Space (34)	
B00H - R0026 - Practical Activities - (17 SQM)	● Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0027 - Withdrawal Space - 2hb - (8.41 SQM)	● Student Space (3)	
B00H - R0028 - Home Base - (60.72 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0029 - Practical Activities - (12.58 SQM)	● Student Space (5)	
B00H - R0030 - Home Base - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0001 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (9.85 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Home Base - (56.61 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0005 - Clerical Office - (37.75 SQM)	● Office (9)	
B00I - R0006 - Entry Vestibule - (9.32 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Movement - (12.5 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Principal - (18.79 SQM)	● Office (4)	
B00I - R0013 - Duplicating Workroom - (18.05 SQM)	● Office (4)	
B00M - R0002 - Movement - (21.42 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Entry Vestibule - (23.06 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Clerical Office - (27.83 SQM)	● Office (6)	
B00P - R0003 - Duplicating Workroom - (22.14 SQM)	● Office (5)	
B00P - R0004 - Sick Bay - (9.78 SQM)	● Student Space (4)	
B00P - R0009 - Interview - (16.76 SQM)	● Office (4)	
B00P - R0011 - Staff Room Annexe - (19.68 SQM)	● Office (4)	
B00P - R0012 - Staff Room - (48.78 SQM)	● Office (12)	
B00P - R0015 - Deputy Principal - (13.08 SQM)	● Office (3)	
B00P - R0016 - Principal - (16.49 SQM)	● Office (4)	
B00P - R0017 - Interview - (13.26 SQM)	● Office (3)	
B00P - R0018 - Movement - (56.36 SQM)	Not Applicable	Circulation or storage space.
B00P - R0019 - Movement - (34.28 SQM)	Not Applicable	Circulation or storage space.
B00P - R0020 - Movement - (6.06 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Practical Activities - 1hb - (19.75 SQM)	● Student Space (9)	
B00Q - R0004 - Home Base - (60.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0005 - Withdrawal Space - 2hb - (11.67 SQM)	● Student Space (5)	
B00Q - R0006 - Practical Activities - 1hb - (19.75 SQM)	● Student Space (9)	
B00Q - R0007 - Home Base - (60.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R1002 - Practical Activities - 1hb - (19.73 SQM)	● Student Space (9)	
B00Q - R1004 - Home Base - (60.12 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R1005 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00Q - R1006 - Practical Activities - 1hb - (19.73 SQM)	● Student Space (9)	
B00Q - R1007 - Home Base - (60.12 SQM) - Teaching Space: 1	● Student Space (27)	
OS 606 11966 - OS 606 11966 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19738 - OS 606 19738 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	