

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Warragamba Public School (3744)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollondilly</b>

3744 - Warragamba Public School  
Site Plan (11383)



1:1,095

Printed: 03-Apr-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (58.8 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0005 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0020 - Withdrawal Space - 1hb - (14.73 SQM)	Student Space (6)	
B00A - R0025 - Staff Room Annexe - (13 SQM)	Office (3)	
B00A - R0026 - Staff Room Annexe - (18.38 SQM)	Office (4)	
B00A - R0029 - Staff Room - (63.97 SQM)	Office (15)	
B00A - R0032 - Practical Activities - 1hb - (12.58 SQM)	Student Space (5)	
B00A - R0034 - Practical Activities - 1hb - (12.41 SQM)	Student Space (5)	
B00B - R0013 - Practical Activities - 1hb - (19.03 SQM)	Student Space (8)	
B00B - R0014 - Practical Activities - 1hb - (19.83 SQM)	Student Space (9)	
B00B - R0017 - Withdrawal Space - 1hb - (11.52 SQM)	Student Space (5)	
B00B - R0019 - Home Base - (56.74 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0020 - Home Base - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0008 - Home Base - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0009 - Practical Activities - 1hb - (19.3 SQM)	Student Space (8)	
B00C - R0010 - Practical Activities - 1hb - (18.69 SQM)	Student Space (8)	
B00C - R0011 - Home Base - (56.7 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0014 - Withdrawal Space - 1hb - (11.68 SQM)	Student Space (5)	
B00D - R0003 - Special Programs Room - (39.96 SQM)	Student Space (18)	
B00D - R0016 - Special Programs Room - (59.39 SQM)	Student Space (27)	
B00D - R0017 - Reading Area - (157.13 SQM)	Student Space (72)	
B00E - R0001 - Staff Room - (46.78 SQM)	Office (11)	
B00E - R0004 - Special Programs Room - (17.34 SQM)	Student Space (8)	
B00G - R0001 - Canteen - (18.74 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Communal Space - (95.5 SQM)	Student Space (44)	
B00H - R0002 - Outdoor Learning Area - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Home Base - (59.91 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0004 - Practical Activities - 1hb - (15.33 SQM)	Student Space (7)	
B00H - R0005 - Withdrawal Space - 1hb - (12 SQM)	Student Space (5)	
B00H - R0006 - Outdoor Learning Area - (13.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Home Base - (60.23 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0009 - Practical Activities - 1hb - (15.39 SQM)	Student Space (7)	
B00J - R0003 - Practical Activities - 1hb - (17.45 SQM)	Student Space (8)	
B00J - R0004 - Home Base - (60.41 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0006 - Movement - (14.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Withdrawal Space - 1hb - (11.82 SQM)	Student Space (5)	
B00J - R0008 - Movement - (14.32 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Home Base - (60.41 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0011 - Practical Activities - 1hb - (17.46 SQM)	Student Space (8)	
B00M - R0015 - Entry Vestibule - (8.11 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Clerical Office - (9.49 SQM)	Office (2)	
B00M - R0017 - Clerical/Printing - (22.92 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Clerical Office - (15.49 SQM)	Office (3)	
B00M - R0019 - Interview - (10.98 SQM)	Office (2)	
B00M - R0020 - Principal - (19.81 SQM)	Office (4)	
B00M - R0021 - Deputy Principal - (12.78 SQM)	Office (3)	
B00M - R0022 - Movement - (18.14 SQM)	Not Applicable	Circulation or storage space.
B00M - R0025 - Sick Bay - (7.1 SQM)	Student Space (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B000 - R0003 - Movement - (14.28 SQM)	Not Applicable	Circulation or storage space.
B000 - R0005 - Withdrawal Space - 1hb - (11.78 SQM)	● Student Space (5)	
B000 - R0007 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B000 - R0010 - Practical Activities - 1hb - (17.12 SQM)	● Student Space (7)	
B000 - R0011 - Home Base - (61.13 SQM) - Teaching Space: 1	● Student Space (28)	
B000 - R0012 - Practical Activities - 1hb - (17.12 SQM)	● Student Space (7)	
B000 - R0013 - Home Base - (61.12 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0003 - Withdrawal Space - 1hb - (14.09 SQM)	● Student Space (6)	
B00P - R0004 - Withdrawal Space - 1hb - (11.83 SQM)	● Student Space (5)	
B00P - R0005 - Movement - (14.77 SQM)	Not Applicable	Circulation or storage space.
B00P - R0010 - Practical Activities - 1hb - (17.21 SQM)	● Student Space (7)	
B00P - R0011 - Home Base - (61.67 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0012 - Practical Activities - 1hb - (17.21 SQM)	● Student Space (7)	
B00P - R0013 - Home Base - (61.67 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0001 - Communal Space - (145.04 SQM)	● Student Space (67)	
B00Q - R0002 - Raised Platform - (62.37 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0016 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0018 - Movement - (12.16 SQM)	Not Applicable	Circulation or storage space.
OS 602 10005 - OS 602 10005 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	