


VENTILATION AUDIT REPORT

SCHOOL:	Warren Central School (3392)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Warren

3392 - Warren Central School
Site Plan (12440)



1:2,145







Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (66.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Staff Room Annexe - (7.28 SQM)	Office (1)	
B00A - R0007 - Movement - (236.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Home Base - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0015 - Home Base - (58.02 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0016 - Withdrawal Space - 1hb - (11.4 SQM)	Student Space (5)	
B00A - R0019 - Special Programs Room - (45.37 SQM)	Student Space (21)	
B00A - R0024 - Movement - (73.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Special Learning Space - (59.17 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0026 - Withdrawal Space - 1hb - (11.19 SQM)	Student Space (5)	
B00A - R0028 - Movement - (42.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Staff Room Annexe - (21.49 SQM)	Office (5)	
B00A - R0049 - Home Base - (58.83 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0050 - Withdrawal Space - 1hb - (11.31 SQM)	Student Space (5)	
B00A - R0051 - Home Base - (58.69 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0055 - Movement - (186.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Interview - (5.86 SQM)	Office (1)	
B00A - R0057 - Staff Room Annexe - (17.96 SQM)	Office (4)	
B00A - R0060 - Principal - (18.23 SQM)	Office (4)	
B00A - R0061 - Duplicating Workroom - (25.09 SQM)	Office (6)	
B00A - R0062 - Clerical Office - (16.61 SQM)	Office (4)	
B00A - R0063 - Movement - (40.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Staff Room Annexe - (12.32 SQM)	Office (3)	
B00A - R0066 - Deputy Principal - (16.28 SQM)	Office (4)	
B00A - R0070 - Sick Bay - (8.79 SQM)	Student Space (4)	
B00A - R0071 - Entry Vestibule - (18.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0072 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0073 - Clerical Office/Workroom - (10.63 SQM)	Office (2)	
B00A - R0078 - Movement - (11.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0079 - Staff Room - (87.27 SQM)	Office (21)	
B00B - R0001 - Movement - (66.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (248.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0014 - Withdrawal Space - 1hb - (11.48 SQM)	Student Space (5)	
B00B - R0015 - Home Base - (58.29 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0016 - Movement - (42.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Staff Room Annexe - (21.6 SQM)	Office (5)	
B00B - R0020 - Home Base - (58.25 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0021 - Withdrawal Space - 1hb - (11.32 SQM)	Student Space (5)	
B00B - R0022 - Home Base - (58.5 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0024 - Movement - (34.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Special Programs Room - (43.2 SQM)	Student Space (20)	
B00B - R0029 - General Learning Space - (58.83 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0047 - Withdrawal - M - (11.53 SQM)	Student Space (5)	
B00B - R0048 - Home Base - M - (58.78 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0049 - Staff Room Annexe - (7.33 SQM)	Office (1)	
B00B - R0054 - Movement - (203.45 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0066 - Staff Room - (23.96 SQM)	Office (5)	
B00B - R0068 - Reading Area - (230.77 SQM)	Student Space (107)	
B00C - R0001 - Movement - (139.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Communal Space - (280.33 SQM)	Student Space (130)	
B00C - R0007 - Raised Platform - (71.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (85.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (7.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Canteen - (42.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Laboratory L.S. - (96.12 SQM) - Teaching Space: 1	Student Space (44)	
B00D - R0008 - Preparation - (57.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Staff Study - (96.52 SQM)	Office (24)	
B00D - R0010 - Darkroom Space - (18.49 SQM)	Office (4)	
B00D - R0013 - Movement - (178.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Music Learning Space - (96.31 SQM) - Teaching Space: 1	Student Space (44)	
B00E - R0007 - T.A.S. Outdoor Area - (19.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Materials Technology L.S. - (79.83 SQM) - Teaching Space: 1	Student Space (37)	
B00E - R0010 - Materials Technology L.S. - (36.52 SQM) - Teaching Space: 1	Student Space (16)	
B00E - R0011 - Metal Technology Bay - (11.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Welding Area - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Materials Technology L.S. - (63.97 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0014 - T.A.S. Outdoor Area - (20.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Staff Room Annexe - (23.35 SQM)	Office (5)	
B00E - R0019 - Art Learning Space - (51.13 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0021 - Art Learning Space - (56.44 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0023 - Art Learning Space - (50.7 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0028 - General Learning Space - (51.26 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0030 - General Learning Space - (51.19 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0035 - General Learning Space - (51.12 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0037 - General Learning Space - (51.19 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0041 - General Learning Space - (31.9 SQM) - Teaching Space: 1	Student Space (14)	
B00E - R0044 - Movement - (357.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Seminar/Study - (52.47 SQM)	Office (13)	
B00F - R0002 - Design L.S. - (75.06 SQM) - Teaching Space: 1	Student Space (34)	
B00F - R0003 - Food/Research Space - (114.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Staff Room Annexe - (31.2 SQM)	Office (7)	
B00F - R0011 - Laboratory L.S. - (92.09 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0012 - General Learning Space - (48.7 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0013 - General Learning Space - (48.7 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0014 - General Learning Space - (48.79 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0016 - Movement - (11.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - General Learning Space - (64.24 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0020 - General Learning Space - (64.31 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0021 - Staff Room - (67.97 SQM)	Office (16)	
B00F - R0022 - Interview - (13.67 SQM)	Office (3)	
B00F - R0023 - Interview - (13.63 SQM)	Office (3)	
B00F - R0029 - Staff Room Annexe - (43.73 SQM)	Office (10)	
B00F - R0031 - Movement - (185.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Computer Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Seminar/Study - (52.27 SQM)	 Office (13)	
B00G - R0008 - Senior Seminar - (54.02 SQM)	 Office (13)	
B00G - R0011 - Movement - (61.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - General Learning Space - Type 10 - (59.94 SQM) - Teaching Space: 0.5	 Student Space (27)	
B00K - R0002 - Science Laboratory - (60.09 SQM)	 Student Space (27)	
B00K - R0003 - Preparation - (30.29 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Staff Room - (21.07 SQM)	 Office (5)	
B00K - R0005 - Seminar - Type 2 - (21.07 SQM)	 Office (5)	
B00K - R0008 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Outdoor Learning Space - Type 4 - (41.27 SQM)	Not Applicable	Circulation or storage space.