

VENTILATION AUDIT REPORT

SCHOOL:	Warrimoo Public School (4195)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blue Mountains
LOCAL GOVERNMENT AREA:	Blue Mountains

4195 - Warrimoo Public School
Site Plan (11388)



1:1,142

Printed: 29-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0019 - Sick Bay - (12.11 SQM)	● Student Space (5)	
B00A - R0020 - Clerical Office - (18.55 SQM)	● Office (4)	
B00A - R0021 - Movement - (35.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Entry Vestibule - (12.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Duplicating Workroom - (21.04 SQM)	● Office (5)	
B00A - R0027 - Deputy Principal - (10.47 SQM)	● Office (2)	
B00A - R0030 - Staff Kitchen - (10.34 SQM)	● Office (2)	
B00A - R0031 - Staff Room - (28.32 SQM)	● Office (7)	
B00A - R0032 - Staff Room Annexe - (26.37 SQM)	● Office (6)	
B00A - R0035 - Interview - (11.97 SQM)	● Office (2)	
B00A - R0036 - Principal - (15.62 SQM)	● Office (3)	
B00B - R0004 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Practical Activities - 1hb - (13.74 SQM)	● Student Space (6)	
B00B - R0022 - Home Base - (55.11 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0025 - Withdrawal Space - 1hb - (10.69 SQM)	● Student Space (4)	
B00B - R0027 - Home Base - (54.6 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0028 - Practical Activities - 1hb - (19.6 SQM)	● Student Space (9)	
B00B - R0029 - Practical Activities - 1hb - (17.5 SQM)	● Student Space (8)	
B00B - R0030 - Home Base - (54.66 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0031 - Withdrawal Space - 1hb - (5.24 SQM)	● Student Space (2)	
B00B - R9007 - Withdrawal Space - 1hb - (12.93 SQM)	● Student Space (5)	
B00B - R9009 - Movement - (20.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Special Programs Room - (74.19 SQM)	● Student Space (34)	
B00D - R0009 - Practical Activities - 1hb - (9.31 SQM)	● Student Space (4)	
B00E - R0001 - Reading Area - (166.48 SQM)	● Student Space (77)	
BOA1 - R0001 - Raised Platform - (47.44 SQM)	Not Applicable	Circulation or storage space.
BOA1 - R0003 - Communal Space - (123.72 SQM)	● Student Space (57)	
BOA1 - R0004 - Canteen - (20.74 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0002 - Practical Activities - 1hb - (25.35 SQM)	● Student Space (11)	
BOB1 - R0003 - Home Base - (55.16 SQM) - Teaching Space: 1	● Student Space (25)	
BOB1 - R0004 - Withdrawal Space - 1hb - (10.7 SQM)	● Student Space (4)	
BOB1 - R0005 - Home Base - (54.81 SQM) - Teaching Space: 1	● Student Space (25)	
BOB1 - R0006 - Practical Activities - 1hb - (25.26 SQM)	● Student Space (11)	
BOC1 - R0001 - Practical Activities - 1hb - (25.23 SQM)	● Student Space (11)	
BOC1 - R0003 - Home Base - (54.9 SQM) - Teaching Space: 1	● Student Space (25)	
BOC1 - R0004 - Withdrawal Space - 1hb - (10.69 SQM)	● Student Space (4)	
BOC1 - R0005 - Home Base - (55.19 SQM) - Teaching Space: 1	● Student Space (25)	
BOC1 - R0007 - Practical Activities - 1hb - (25.09 SQM)	● Student Space (11)	
OS 603 11269 - OS 603 11269 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	