


VENTILATION AUDIT REPORT

SCHOOL:	Wattle Grove Public School (3871)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Holsworthy
LOCAL GOVERNMENT AREA:	Liverpool

3871 - Wattle Grove Public School
Site Plan (03087)



1:1,073

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (13.09 SQM)	Office (3)	
B00A - R0002 - Entry Vestibule - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Sick Bay - (8.19 SQM)	Student Space (3)	
B00A - R0005 - Principal - (17.9 SQM)	Office (4)	
B00A - R0012 - Staff Room - (57.69 SQM)	Office (14)	
B00A - R0013 - Staff Room - (26.41 SQM)	Office (6)	
B00A - R0014 - Deputy Principal - (13.19 SQM)	Office (3)	
B00A - R0015 - Deputy Principal - (13.19 SQM)	Office (3)	
B00A - R0016 - Clerical Office - (49.28 SQM)	Office (12)	
B00A - R0017 - Movement - (38.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (155.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Special Programs Room - (33.11 SQM)	Student Space (15)	
B00B - R0002 - Canteen - (44.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (11.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (27.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Raised Platform - (53.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (11.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (11.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Communal Space - (201.41 SQM)	Student Space (93)	
B00C - R0003 - Entry Vestibule - (7.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Practical Activities - 1hb - (19.79 SQM)	Student Space (9)	
B00C - R0007 - Home Base - (57.83 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0008 - Withdrawal Space - 1hb - (11.2 SQM)	Student Space (5)	
B00C - R0009 - Home Base - (57.91 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0010 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B00C - R0013 - Movement - (162.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B00C - R0016 - Home Base - (57.83 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0017 - Withdrawal Space - 1hb - (11.24 SQM)	Student Space (5)	
B00C - R0018 - Home Base - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0019 - Practical Activities - 1hb - (18.97 SQM)	Student Space (8)	
B00C - R0023 - Practical Activities - 1hb - (19.87 SQM)	Student Space (9)	
B00C - R0024 - Home Base - (57.68 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0025 - Withdrawal Space - 1hb - (11.2 SQM)	Student Space (5)	
B00C - R0026 - Home Base - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0027 - Practical Activities - 1hb - (19.77 SQM)	Student Space (9)	
B00D - R0003 - Practical Activities - 1hb - (20.04 SQM)	Student Space (9)	
B00D - R0004 - Home Base - (58.06 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0005 - Withdrawal Space - 2hb - (11.17 SQM)	Student Space (5)	
B00D - R0006 - Home Base - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0007 - Practical Activities - 1hb - (19.81 SQM)	Student Space (9)	
B00D - R0010 - Movement - (121.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Special Programs Room - (16.39 SQM)	Student Space (7)	
B00D - R0015 - Special Programs Room - (15.98 SQM)	Student Space (7)	
B00D - R0019 - Reading Area - (222.43 SQM)	Student Space (103)	
B00E - R0003 - Practical Activities - 1hb - (19.84 SQM)	Student Space (9)	
B00E - R0004 - Home Base - (57.76 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0005 - Withdrawal Space - 2hb - (11.24 SQM)	● Student Space (5)	
B00E - R0006 - Home Base - (57.76 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0007 - Practical Activities - 1hb - (19.77 SQM)	● Student Space (9)	
B00E - R0010 - Movement - (143.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Practical Activities - 1hb - (19.01 SQM)	● Student Space (8)	
B00E - R0017 - Home Base - (57.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0018 - Withdrawal Space - 2hb - (11.2 SQM)	● Student Space (5)	
B00E - R0019 - Home Base - (57.83 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0020 - Practical Activities - 1hb - (19.04 SQM)	● Student Space (8)	
B00F - R0003 - Practical Activities - 1hb - (19.94 SQM)	● Student Space (9)	
B00F - R0004 - Home Base - (57.76 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0005 - Withdrawal Space - 2hb - (11.31 SQM)	● Student Space (5)	
B00F - R0006 - Home Base - (57.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0007 - Practical Activities - 1hb - (19.89 SQM)	● Student Space (9)	
B00F - R0011 - Movement - (39.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00G - R0002 - Special Programs Room - (59.01 SQM)	● Student Space (27)	
B00G - R0004 - Withdrawal Space - 1hb - (7.51 SQM)	● Student Space (3)	
B00G - R0005 - Practical Activities - 1hb - (18.35 SQM)	● Student Space (8)	
B00G - R0006 - Home Base - (61.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0008 - Withdrawal Space - 2hb - (11.4 SQM)	● Student Space (5)	
B00G - R0009 - Practical Activities - 1hb - (18.92 SQM)	● Student Space (8)	
B00G - R0010 - Home Base - (60.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1001 - Practical Activities - 1hb - (19.52 SQM)	● Student Space (9)	
B00G - R1002 - Home Base - (59.09 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1004 - Withdrawal Space - 1hb - (7.68 SQM)	● Student Space (3)	
B00G - R1005 - Practical Activities - 1hb - (19.01 SQM)	● Student Space (8)	
B00G - R1006 - Home Base - (61.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1008 - Withdrawal Space - 2hb - (11.73 SQM)	● Student Space (5)	
B00G - R1009 - Practical Activities - 1hb - (19.97 SQM)	● Student Space (9)	
B00G - R1010 - Home Base - (61.15 SQM) - Teaching Space: 1	● Student Space (28)	
NS 101 15686 - NS 101 15686 - Learning Unit - Double Primary/PAA - (133 SQM)	● Student Space (61)	
OS 602 10614 - OS 602 10614 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15927 - OS 602 15927 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16245 - OS 602 16245 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 13332 - OS 603 13332 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	