

VENTILATION AUDIT REPORT

SCHOOL:	Wauchope Public School (3404)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

3404 - Wauchope Public School
Site Plan (11672)



1:1,122

Printed: 29-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Home Base - (64.48 SQM) - Teaching Space: 1	● Student Space (29)	
B001 - R0005 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R0006 - Practical Activities - 1hb - (40.25 SQM)	● Student Space (18)	
B001 - R0008 - Home Base - (58.42 SQM) - Teaching Space: 1	● Student Space (27)	
B001 - R0014 - Movement - (10.26 SQM)	Not Applicable	Circulation or storage space.
B001 - R0015 - Staff Room Annexe - (21.63 SQM)	● Office (5)	
B001 - R0016 - Staff Room - (12.52 SQM)	● Office (3)	
B001 - R0017 - Sick Bay - (5.63 SQM)	● Student Space (2)	
B001 - R1003 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B001 - R1004 - Practical Activities - 1hb - (25.12 SQM)	● Student Space (11)	
B001 - R1006 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R1007 - Practical Activities - 1hb - (22.4 SQM)	● Student Space (10)	
B001 - R1008 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R1010 - Withdrawal Space - 1hb - (10.82 SQM)	● Student Space (5)	
B001 - R1011 - Practical Activities - 1hb - (18.22 SQM)	● Student Space (8)	
B001 - R1012 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R1013 - Practical Activities - 1hb - (21.61 SQM)	● Student Space (10)	
B001 - R1014 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R0007 - Practical Activities - 1hb - (14.69 SQM)	● Student Space (6)	
B002 - R0008 - Home Base - (48.72 SQM) - Teaching Space: 1	● Student Space (22)	
B002 - R0009 - Home Base - (48.72 SQM) - Teaching Space: 1	● Student Space (22)	
B002 - R0010 - Practical Activities - 1hb - (12.83 SQM)	● Student Space (5)	
B002 - R1001 - Practical Activities - 1hb - (14.09 SQM)	● Student Space (6)	
B002 - R1002 - Practical Activities - 1hb - (15.74 SQM)	● Student Space (7)	
B002 - R1003 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R1004 - Home Base - (53.3 SQM) - Teaching Space: 1	● Student Space (24)	
B003 - R1001 - Movement - (24.57 SQM)	Not Applicable	Circulation or storage space.
B003 - R1004 - Home Base - (72.74 SQM) - Teaching Space: 1	● Student Space (33)	
B004 - R0001 - Canteen - (24.12 SQM)	Not Applicable	Circulation or storage space.
B004 - R1001 - Practical Activities - 1hb - (10.57 SQM)	● Student Space (4)	
B004 - R1002 - Practical Activities - 1hb - (23.24 SQM)	● Student Space (10)	
B004 - R1005 - Raised Platform - (19.93 SQM)	Not Applicable	Circulation or storage space.
B004 - R1006 - Communal Space - (135.21 SQM)	● Student Space (62)	
B005 - R0003 - Interview - (10.04 SQM)	● Office (2)	
B005 - R0004 - Interview - (13.6 SQM)	● Office (3)	
B005 - R0005 - Interview/Office - Type 1 - (16.41 SQM)	● Office (4)	
B005 - R0006 - Movement - (17.84 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Withdrawal Space - 1hb - (15.04 SQM)	● Student Space (6)	
B005 - R0008 - Special Programs Room - (59.58 SQM)	● Student Space (27)	
B005 - R1010 - Home Base - (55.36 SQM) - Teaching Space: 1	● Student Space (25)	
B005 - R1012 - Practical Activities - 2hb - (20.51 SQM)	● Student Space (9)	
B005 - R1013 - Withdrawal Space - 2hb - (12.31 SQM)	● Student Space (5)	
B005 - R1014 - Home Base - (55.33 SQM) - Teaching Space: 1	● Student Space (25)	
B005 - R1015 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B007 - R0001 - Practical Activities - 1hb - (18.72 SQM)	● Student Space (8)	
B008 - R0001 - Practical Activities - 1hb - (16 SQM)	● Student Space (7)	
B008 - R0002 - Home Base - (43.37 SQM) - Teaching Space: 1	● Student Space (20)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B008 - R0003 - Practical Activities - 1hb - (16.29 SQM)	● Student Space (7)	
B008 - R0004 - Home Base - (43.37 SQM) - Teaching Space: 1	● Student Space (20)	
B009 - R0001 - Movement - (9.58 SQM)	Not Applicable	Circulation or storage space.
B009 - R0002 - Movement - (9.59 SQM)	Not Applicable	Circulation or storage space.
B010 - R0001 - Staff Room - (64.25 SQM)	● Office (16)	
B010 - R0002 - Staff Room Annexe - (21.05 SQM)	● Office (5)	
B010 - R0003 - Movement - (52.2 SQM)	Not Applicable	Circulation or storage space.
B010 - R0009 - Clerical Office/Workroom - (44.29 SQM)	● Office (11)	
B010 - R0010 - Clerical Office - (13.87 SQM)	● Office (3)	
B010 - R0011 - Sick Bay - (8.89 SQM)	● Student Space (4)	
B010 - R0012 - Deputy Principal - (12.64 SQM)	● Office (3)	
B010 - R0013 - Deputy Principal - (12.72 SQM)	● Office (3)	
B010 - R0014 - Principal - (17.04 SQM)	● Office (4)	
B010 - R0015 - Interview - (12.75 SQM)	● Office (3)	
B010 - R0017 - Entry Vestibule - (22.68 SQM)	Not Applicable	Circulation or storage space.
B010 - R0018 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B010 - R0025 - Movement - (7.15 SQM)	Not Applicable	Circulation or storage space.
B010 - R1001 - Reading Area - (240.86 SQM)	● Student Space (111)	
B010 - R1002 - Clerical Office - (26.88 SQM)	● Office (6)	
B010 - R1007 - Movement - (38.67 SQM)	Not Applicable	Circulation or storage space.
B013 - R0002 - Practical Activities - 1hb - (19.42 SQM)	● Student Space (9)	
B013 - R0004 - Home Base - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B013 - R0005 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B013 - R0006 - Home Base - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B013 - R0008 - Practical Activities - 1hb - (19.43 SQM)	● Student Space (9)	
B015 - R0001 - Communal Space - (200.44 SQM)	● Student Space (92)	
B015 - R0002 - Raised Platform - (56.62 SQM)	Not Applicable	Circulation or storage space.
B015 - R0016 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B015 - R0018 - Movement - (16.81 SQM)	Not Applicable	Circulation or storage space.
B016 - R0001 - Canteen - (44.72 SQM)	Not Applicable	Circulation or storage space.
B017 - R0001 - Home Base - M - (64.7 SQM) - Teaching Space: 1	● Student Space (30)	
B021 - R0004 - Movement - (11.86 SQM)	Not Applicable	Circulation or storage space.
B021 - R0006 - Home Base - (44.96 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R0007 - Withdrawal Space - 2hb - (11.37 SQM)	● Student Space (5)	
B021 - R0008 - Practical Activities - 1hb - (17.68 SQM)	● Student Space (8)	
B021 - R0009 - Home Base - (45.5 SQM) - Teaching Space: 1	● Student Space (21)	
B021 - R0010 - Withdrawal Space - 1hb - (11.36 SQM)	● Student Space (5)	
B021 - R0011 - Practical Activities - 1hb - (17.2 SQM)	● Student Space (7)	
B021 - R0012 - Home Base - (44.67 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R0013 - Practical Activities - 1hb - (19.23 SQM)	● Student Space (8)	
B021 - R0014 - Home Base - (44.29 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R0015 - Practical Activities - 1hb - (19.7 SQM)	● Student Space (9)	
B021 - R0016 - Withdrawal Space - 2hb - (12.08 SQM)	● Student Space (5)	
B021 - R0017 - Home Base - (43.15 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R0018 - Practical Activities - 1hb - (19.74 SQM)	● Student Space (9)	
B021 - R0020 - Practical Activities - 1hb - (16.07 SQM)	● Student Space (7)	
B021 - R0021 - Home Base - (53.48 SQM) - Teaching Space: 1	● Student Space (24)	
B021 - R0022 - Withdrawal Space - 1hb - (9.28 SQM)	● Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B021 - R0028 - Breakout Area - (13.89 SQM)	Not Applicable	Circulation or storage space.
B021 - R0029 - Breakout Area - (13.07 SQM)	Not Applicable	Circulation or storage space.
B021 - R0030 - Breakout Area - (14.11 SQM)	Not Applicable	Circulation or storage space.
B021 - R0031 - Practical Activities - 2hb - (8.46 SQM)	● Student Space (3)	
B021 - R0032 - Practical Activities - 2hb - (8.45 SQM)	● Student Space (3)	
B021 - R0033 - Breakout Area - (15.39 SQM)	Not Applicable	Circulation or storage space.
B021 - R0034 - Breakout Area - (14.92 SQM)	Not Applicable	Circulation or storage space.
B021 - R0036 - Staff Kitchen - (7.34 SQM)	● Office (1)	
B021 - R1003 - Movement - (12.12 SQM)	Not Applicable	Circulation or storage space.
B021 - R1006 - Home Base - (46.04 SQM) - Teaching Space: 1	● Student Space (21)	
B021 - R1007 - Practical Activities - 1hb - (17.2 SQM)	● Student Space (7)	
B021 - R1008 - Withdrawal Space - 2hb - (11.42 SQM)	● Student Space (5)	
B021 - R1009 - Home Base - (46.28 SQM) - Teaching Space: 1	● Student Space (21)	
B021 - R1010 - Practical Activities - 1hb - (16.52 SQM)	● Student Space (7)	
B021 - R1011 - Withdrawal Space - 1hb - (11.42 SQM)	● Student Space (5)	
B021 - R1012 - Home Base - (44.52 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R1013 - Practical Activities - P - 1hb - (18.88 SQM)	● Student Space (8)	
B021 - R1014 - Home Base - (44.82 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R1015 - Practical Activities - 1hb - (19.8 SQM)	● Student Space (9)	
B021 - R1016 - Withdrawal Space - 2hb - (12.08 SQM)	● Student Space (5)	
B021 - R1017 - Home Base - (44.75 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R1018 - Practical Activities - 1hb - (20.35 SQM)	● Student Space (9)	
B021 - R1019 - Practical Activities - 1hb - (18.94 SQM)	● Student Space (8)	
B021 - R1020 - Home Base - (45.11 SQM) - Teaching Space: 1	● Student Space (20)	
B021 - R1021 - Withdrawal Space - 2hb - (11.57 SQM)	● Student Space (5)	
B021 - R1022 - Home Base - (45.81 SQM) - Teaching Space: 1	● Student Space (21)	
B021 - R1023 - Practical Activities - 1hb - (19.35 SQM)	● Student Space (8)	
B021 - R1024 - Breakout Area - (13.88 SQM)	Not Applicable	Circulation or storage space.
B021 - R1025 - Breakout Area - (13.08 SQM)	Not Applicable	Circulation or storage space.
B021 - R1026 - Breakout Area - (14.25 SQM)	Not Applicable	Circulation or storage space.
B021 - R1027 - Practical Activities - 2hb - (8.43 SQM)	● Student Space (3)	
B021 - R1028 - Practical Activities - 2hb - (8.43 SQM)	● Student Space (3)	
B021 - R1029 - Breakout Area - (15.39 SQM)	Not Applicable	Circulation or storage space.
B021 - R1030 - Breakout Area - (14.92 SQM)	Not Applicable	Circulation or storage space.
B021 - R1031 - Practical Activities - 2hb - (9.18 SQM)	● Student Space (4)	
B021 - R1032 - Practical Activities - 2hb - (8.94 SQM)	● Student Space (4)	
B021 - R1033 - Breakout Area - (14.55 SQM)	Not Applicable	Circulation or storage space.
B021 - R1034 - Breakout Area - (14.62 SQM)	Not Applicable	Circulation or storage space.
OS 620 10670 - OS 620 10670 - Learning Unit Single - PWD - (76 SQM)	● Student Space (35)	