

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Weethalle Public School (3415)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bland</b>

3415 - Weethalle Public School  
Site Plan (11817)









1:698

Printed: 07-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (43.43 SQM) - Teaching Space: 1	 Student Space (20)	
B00A - R0003 - Home Base - (44.03 SQM) - Teaching Space: 1	 Student Space (20)	
B00A - R0011 - Movement - (25.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Reading Area - (67.35 SQM)	 Student Space (31)	
B00B - R0001 - Staff Room - (5.93 SQM)	 Office (1)	
B00B - R0006 - Home Base - (53.67 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0009 - Clerical Office/Workroom - (27.64 SQM)	 Office (6)	
B00C - R0004 - Canteen - (20.17 SQM)	Not Applicable	Circulation or storage space.