


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Wellington High School (8197)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Dubbo</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Dubbo</b>

8197 - Wellington High School  
Site Plan (13389)

















1:725

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Computer Learning Space - (64.72 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0002 - General Learning Space - (49.6 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0003 - Movement - (57.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - General Learning Space - (49.6 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0011 - General Learning Space - (49.6 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0012 - General Learning Space - (49.61 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0013 - General Learning Space - (49.45 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0015 - Staff Study - (23.81 SQM)	Office (5)	
B00A - R0016 - Clinic - Girls - (11.78 SQM)	Office (2)	
B00A - R0018 - Clinic - Boys - (11.79 SQM)	Office (2)	
B00A - R0020 - Deputy Principal Office - (13.8 SQM)	Office (3)	
B00A - R0021 - Interview/Office - Type 1 - (13.47 SQM)	Office (3)	
B00A - R0022 - Principal Office - (18.04 SQM)	Office (4)	
B00A - R0024 - Interview/Office - Type 1 - (14.88 SQM)	Office (3)	
B00A - R0025 - Duplicating Workroom - (18.74 SQM)	Office (4)	
B00A - R0027 - Administration - Clerical - (24.01 SQM)	Office (6)	
B00A - R0031 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Staff Kitchen - (6.13 SQM)	Office (1)	
B00A - R0040 - Commonroom - (43.25 SQM)	Office (10)	
B00A - R0042 - Movement - (20.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Public Reception - (18.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Movement - (14.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Movement - (118.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - General Learning Space - S/P - (30.07 SQM) - Teaching Space: 1	Student Space (13)	
B00A - R0052 - Practical Activities Area - 2 G.L.S. - (21.77 SQM)	Student Space (10)	
B00A - R1001 - Computer Learning Space - (65.03 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1002 - General Learning Space - (49.6 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1007 - Staff Study - (24.85 SQM)	Office (6)	
B00A - R1008 - General Learning Space - (49.91 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1009 - General Learning Space - (49.98 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1010 - Preparation - (24.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - General Learning Space - (76.29 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R1012 - General Learning Space - (50.31 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1013 - General Learning Space - (49.99 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1015 - Staff Study - (40.28 SQM)	Office (10)	
B00A - R1019 - Movement - (151.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Multi-Purpose Space - (458.13 SQM)	Student Space (212)	
B00B - R0007 - Movement - (63.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Stage - (63.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Staff Kitchen - (14.15 SQM)	Office (3)	
B00B - R0014 - Staff Study - (8.66 SQM)	Office (2)	
B00C - R0005 - Staff Study - (39.25 SQM)	Office (9)	
B00C - R0006 - Laboratory L.S. - (93.01 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0007 - Preparation - (28.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Preparation - (9.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Materials Technology L.S. - (101.98 SQM) - Teaching Space: 1	Student Space (47)	
B00C - R0022 - Movement - (10.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Music Learning Space - (52.83 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1005 - Art Learning Space - (111.5 SQM) - Teaching Space: 1	 Student Space (51)	
B00C - R1008 - Workshop - (12.58 SQM)	 Student Space (5)	
B00C - R1010 - Art Learning Space - (51.96 SQM) - Teaching Space: 1	 Student Space (24)	
B00C - R1011 - Staff Study - (12.73 SQM)	 Office (3)	
B00C - R1013 - Darkroom Space - (8.56 SQM)	 Office (2)	
B00C - R1014 - Movement - (77.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (55.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Student Canteen - (39.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Special Learning Space - (62.17 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R0006 - Materials Technology L.S. - (103.21 SQM) - Teaching Space: 1	 Student Space (47)	
B00E - R0010 - Design L.S. - (78.61 SQM) - Teaching Space: 1	 Student Space (36)	
B00E - R0011 - Movement - (67.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Staff Study - (18.59 SQM)	 Office (4)	
B00E - R0017 - Workshop Area - (139.8 SQM)	 Student Space (64)	
B00F - R0003 - Materials Technology L.S. - (90.82 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R0005 - Food/Research Space - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Food Technology L.S. - (139.14 SQM) - Teaching Space: 1	 Student Space (64)	
B00F - R0009 - Movement - (51.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Staff Study - (19.83 SQM)	 Office (4)	
B00G - R0001 - Laboratory L.S. - (93.16 SQM) - Teaching Space: 1	 Student Space (43)	
B00G - R0002 - Preparation - (48.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Laboratory L.S. - (91.87 SQM) - Teaching Space: 1	 Student Space (42)	
B00G - R0008 - Staff Study - (59.06 SQM)	 Office (14)	
B00G - R0009 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Seminar - (12.54 SQM)	 Office (3)	
B00G - R1006 - Audio Visual Workroom - (12.87 SQM)	 Student Space (5)	
B00G - R1007 - Seminar - (12.83 SQM)	 Office (3)	
B00G - R1008 - Seminar - (12.79 SQM)	 Office (3)	
B00G - R1009 - Main Area - (243.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Seminar - (19.85 SQM)	 Office (4)	
B00G - R1012 - Movement - (19.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - General Assistants - (49.95 SQM)	 Office (12)	
B00O - R0001 - Gymnasium - (86.34 SQM)	 Student Space (40)	
B00Q - R0003 - Administration - Clerical - (12.05 SQM)	 Office (3)	
B00Q - R0005 - General Learning Space - (47.7 SQM) - Teaching Space: 1	 Student Space (22)	