

VENTILATION AUDIT REPORT

SCHOOL:	Wellington Public School (3420)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

3420 - Wellington Public School
Site Plan (12442)



1.923




Printed: 13-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.35 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0002 - Movement - (11.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (46.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (75.52 SQM) - Teaching Space: 1	● Student Space (35)	
B00A - R0006 - Practical Activities - 1hb - (20.16 SQM)	● Student Space (9)	
B00A - R0010 - Practical Activities - 1hb - (21.46 SQM)	● Student Space (9)	
B00A - R0011 - Home Base - (65.32 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0013 - Interview - (11.01 SQM)	● Office (2)	
B00A - R0015 - Movement - (34.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Practical Activities - 1hb - (29.61 SQM)	● Student Space (13)	
B00A - R0018 - Clerical Office/Workroom - (50.5 SQM)	● Office (12)	
B00A - R0019 - Home Base - (95.94 SQM) - Teaching Space: 1	● Student Space (44)	
B00A - R0021 - Movement - (13.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Withdrawal Space - 1hb - (20.08 SQM)	● Student Space (9)	
B00A - R0025 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (41.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (104.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (36.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Home Base - (86.51 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0006 - Home Base - (86.67 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0015 - Home Base - M - (72.03 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0016 - Home Base - (86.03 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0020 - Movement - (57.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (60.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (47.68 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0002 - Home Base - (47.71 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0003 - Home Base - (47.54 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0004 - Home Base - (52.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - Home Base - (47.07 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0006 - Home Base - (47.21 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0008 - Movement - (18.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Staff Room Annexe - (8.52 SQM)	● Office (2)	
B00E - R0012 - Withdrawal Space - 1hb - (19.35 SQM)	● Student Space (8)	
B00E - R0013 - Movement - (137.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Practical Activities - 1hb - (12.96 SQM)	● Student Space (6)	
B00E - R0018 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (8.51 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Special Programs Room - (46.43 SQM)	● Student Space (21)	
B00F - R0002 - Movement - (16.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0004 - Interview - (24.94 SQM)	● Office (6)	
B00F - R0005 - Movement - (10.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (158.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (43.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (51.37 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0009 - Home Base - (51.5 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0010 - Practical Activities - 1hb - (10.31 SQM)	● Student Space (4)	
B00F - R0011 - Withdrawal Space - 1hb - (24.78 SQM)	● Student Space (11)	
B00F - R0012 - Home Base - (52.35 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0013 - Special Programs Room - (46.35 SQM)	● Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0014 - Movement - (16.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (7.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (14.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Staff Room - (59.36 SQM)	Office (14)	
B00G - R0006 - Staff Room Annexe - (36.86 SQM)	Office (9)	
B00G - R0007 - Clerical Office/Workroom - (25.55 SQM)	Office (6)	
B00G - R0009 - Deputy Principal - (13.93 SQM)	Office (3)	
B00G - R0010 - Deputy Principal - (10.21 SQM)	Office (2)	
B00G - R0013 - Principal - (16.62 SQM)	Office (4)	
B00G - R0014 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Entry Vestibule - (17.83 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Sick Bay - (8.8 SQM)	Student Space (4)	
B00G - R0018 - Movement - (8.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Movement - (70.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Clerical Office - (11.36 SQM)	Office (2)	
B00G - R1001 - Reading Area - (212.52 SQM)	Student Space (98)	
B00G - R1002 - Withdrawal Space - 2hb - (53.05 SQM)	Student Space (24)	
B00G - R1011 - Movement - (18.23 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Practical Activities - 1hb - (20.09 SQM)	Student Space (9)	
B00L - R0003 - Home Base - (58.11 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R0004 - Withdrawal Space - 2hb - (11.48 SQM)	Student Space (5)	
B00L - R0005 - Home Base - (57.89 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R0007 - Practical Activities - 1hb - (20.03 SQM)	Student Space (9)	
B00L - R0010 - Movement - (38.37 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Entry Vestibule - (13.9 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Home Base - Pre - (69 SQM) - Teaching Space: 1	Student Space (32)	
B00N - R0006 - Practical Activities - Pre - (46.36 SQM)	Student Space (21)	
B00N - R0015 - Movement - (69.38 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Practical Activities - (19.56 SQM)	Student Space (9)	
B00Q - R0002 - Home Base - (58.73 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0004 - Withdrawal Space - 2hb - (10.72 SQM)	Student Space (4)	
B00Q - R0005 - Home Base - (58.72 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0006 - Practical Activities - (19.56 SQM)	Student Space (9)	
B00R - R0013 - Communal Space - (141.9 SQM)	Student Space (65)	
B00R - R0014 - Raised Platform - (63.69 SQM)	Not Applicable	Circulation or storage space.
B00R - R0017 - Movement - (6.85 SQM)	Not Applicable	Circulation or storage space.
B00R - R0018 - Movement - (12.67 SQM)	Not Applicable	Circulation or storage space.
B00R - R0019 - Movement - (11.97 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Home Base - (88.27 SQM) - Teaching Space: 1	Student Space (40)	
B00T - R0001 - Interview - (23.15 SQM)	Office (5)	
B00T - R0002 - Staff Room Annexe - (20.96 SQM)	Office (5)	
B00T - R0004 - Movement - (16.49 SQM)	Not Applicable	Circulation or storage space.
B00T - R0005 - Special Programs Room - (20.86 SQM)	Student Space (9)	
B00T - R0006 - Interview - (11.81 SQM)	Office (2)	
B00T - R0007 - Staff Room Annexe - (11.8 SQM)	Office (2)	
B00T - R0008 - Movement - (11.54 SQM)	Not Applicable	Circulation or storage space.
B00T - R0011 - Practical Activities - (13.37 SQM)	Student Space (6)	
BOH1 - R0001 - Movement - (13.07 SQM)	Not Applicable	Circulation or storage space.
BOH1 - R0003 - Movement - (18.71 SQM)	Not Applicable	Circulation or storage space.
OH 045 17011 - OH 045 17011 - OSHC Hub 45 - (SQM)	Student Space ()	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 10511 - OS 602 10511 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 13059 - OS 603 13059 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 15228 - OS 603 15228 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	