


# VENTILATION AUDIT REPORT

SCHOOL:	Wentworth Falls Public School (3422)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blue Mountains
LOCAL GOVERNMENT AREA:	Blue Mountains

3422 - Wentworth Falls Public School  
Site Plan (12447)












1:1,022

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.13 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0002 - Practical Activities - 1hb - (12.46 SQM)	Student Space (5)	
B00A - R0004 - Movement - (10.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Principal - (16.27 SQM)	Office (4)	
B00C - R0002 - Movement - (30.38 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Interview - (14.02 SQM)	Office (3)	
B00C - R0004 - Clerical Office/Workroom - (12.25 SQM)	Office (3)	
B00C - R0005 - Sick Bay - (7.85 SQM)	Student Space (3)	
B00C - R0007 - Movement - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Staff Room - (55.02 SQM)	Office (13)	
B00C - R0013 - Duplicating Workroom - (15.12 SQM)	Office (3)	
B00C - R0014 - Clerical Office - (15.93 SQM)	Office (3)	
B00C - R0015 - Entry Vestibule - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Interview - (11.46 SQM)	Office (2)	
B00D - R0007 - Home Base - (63.83 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0008 - Practical Activities - 1hb - (17.08 SQM)	Student Space (7)	
B00E - R0002 - Home Base - (58.59 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0003 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Practical Activities - 1hb - (28.05 SQM)	Student Space (13)	
B00E - R0006 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (59 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Movement - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (67.08 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0002 - Withdrawal Space - 1hb - (5.22 SQM)	Student Space (2)	
B00F - R0005 - Practical Activities - 1hb - (45.23 SQM)	Student Space (20)	
B00F - R0006 - Home Base - (76.07 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0008 - Withdrawal Space - 1hb - (6.37 SQM)	Student Space (2)	
B00F - R0009 - Withdrawal Space - 1hb - (6.59 SQM)	Student Space (3)	
B00G - R0002 - Home Base - (72.44 SQM) - Teaching Space: 1	Student Space (33)	
B00J - R0002 - Home Base - (68.93 SQM) - Teaching Space: 1	Student Space (31)	
B00J - R0003 - Practical Activities - 1hb - (19.95 SQM)	Student Space (9)	
B00J - R0004 - Practical Activities - 1hb - (31.28 SQM)	Student Space (14)	
B00J - R0005 - Home Base - (56.86 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R0002 - Canteen - (30.06 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Reading Area - (162.95 SQM)	Student Space (75)	
B00L - R0010 - Special Programs Room - (31.76 SQM)	Student Space (14)	
B00P - R0011 - Communal Space - (159.03 SQM)	Student Space (73)	
B00P - R0012 - Raised Platform - (43.53 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Practical Activities - 1hb - (17.39 SQM)	Student Space (8)	
B00Q - R0003 - Home Base - (60.47 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0004 - Withdrawal Space - 2hb - (11.3 SQM)	Student Space (5)	
B00Q - R0005 - Home Base - (60.45 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0007 - Practical Activities - 1hb - (17.99 SQM)	Student Space (8)	
B00Q - R1001 - Practical Activities - 1hb - (17.81 SQM)	Student Space (8)	
B00Q - R1003 - Home Base - (60.45 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R1004 - Withdrawal Space - 2hb - (11.3 SQM)	Student Space (5)	
B00Q - R1005 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R1007 - Practical Activities - 1hb - (18.38 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00R - R0001 - Withdrawal Space - 1hb - (8.6 SQM)	 Student Space (3)	
B00R - R0003 - Home Base - (58.31 SQM) - Teaching Space: 1	 Student Space (27)	
B00R - R0004 - Practical Activities - 1hb - (18.15 SQM)	 Student Space (8)	
B00S - R0001 - Special Programs Room - (17.47 SQM)	 Student Space (8)	
B00Z - R0002 - Practical Activities - 1hb - (18.11 SQM)	 Student Space (8)	
B00Z - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	 Student Space (27)	
B00Z - R0005 - Withdrawal Space - 1hb - (11.62 SQM)	 Student Space (5)	
B00Z - R0007 - Home Base - (59.29 SQM) - Teaching Space: 1	 Student Space (27)	
B00Z - R0008 - Practical Activities - 1hb - (18.2 SQM)	 Student Space (8)	