

VENTILATION AUDIT REPORT

SCHOOL:	Wentworth Point Public School (4662)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Auburn
LOCAL GOVERNMENT AREA:	Parramatta

4662 - Wentworth Point Public School
Site Plan (15697)



1.915

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (32.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical/Printing - (54.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Interview - (12.98 SQM)	Office (3)	
B00A - R0005 - Principal - (19.63 SQM)	Office (4)	
B00A - R0006 - Deputy Principal - (24.35 SQM)	Office (6)	
B00A - R0008 - Interview/Office - Type 3 - (16.57 SQM)	Office (4)	
B00A - R0009 - Interview/Office - Type 3 - (16.57 SQM)	Office (4)	
B00A - R0010 - Staff Room - (64.78 SQM)	Office (16)	
B00A - R0011 - Sick Bay - (8.67 SQM)	Student Space (4)	
B00A - R0024 - Staff Kitchen - (19.45 SQM)	Office (4)	
B00A - R0025 - Clerical Office - (12.45 SQM)	Office (3)	
B00A - R0026 - Movement - (66.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Communal Space - (314.99 SQM)	Student Space (146)	
B00A - R0036 - Staff Kitchen - (23.27 SQM)	Office (5)	
B00B - R0001 - Home Base - (58.58 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0003 - Withdrawal Space - 1hb - (6.98 SQM)	Student Space (3)	
B00B - R0004 - Home Base - (57.74 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Withdrawal Space - 1hb - (6.96 SQM)	Student Space (3)	
B00B - R0007 - Practical Activities - (24.91 SQM)	Student Space (11)	
B00B - R0008 - Home Base - (58.95 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0010 - Withdrawal Space - 1hb - (7 SQM)	Student Space (3)	
B00B - R0011 - Home Base - (58.3 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0013 - Withdrawal Space - 1hb - (5.9 SQM)	Student Space (2)	
B00B - R0014 - Home Base - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0016 - Withdrawal Space - 1hb - (6.99 SQM)	Student Space (3)	
B00B - R0017 - Practical Activities - (25.47 SQM)	Student Space (11)	
B00B - R0018 - Home Base - (56.61 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0020 - Withdrawal Space - 1hb - (7.03 SQM)	Student Space (3)	
B00B - R0021 - Movement - (193.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Reading Area - (173 SQM)	Student Space (80)	
B00B - R0023 - Movement - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Canteen - (37.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0059 - Movement - (21.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (57.84 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1003 - Withdrawal Space - 1hb - (6.98 SQM)	Student Space (3)	
B00B - R1004 - Home Base - (57.84 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1006 - Withdrawal Space - 1hb - (6.99 SQM)	Student Space (3)	
B00B - R1007 - Practical Activities - (26.83 SQM)	Student Space (12)	
B00B - R1008 - Home Base - (58.02 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1010 - Withdrawal Space - 1hb - (7.01 SQM)	Student Space (3)	
B00B - R1011 - Home Base - (57.61 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1013 - Withdrawal Space - 1hb - (5.93 SQM)	Student Space (2)	
B00B - R1014 - Home Base - (57.84 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1016 - Withdrawal Space - 1hb - (7.12 SQM)	Student Space (3)	
B00B - R1017 - Practical Activities - (26.85 SQM)	Student Space (12)	
B00B - R1018 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1020 - Withdrawal Space - 1hb - (6.99 SQM)	Student Space (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1021 - Movement - (190.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Reading Area - (115.14 SQM)	● Student Space (53)	
B00B - R1033 - Clerical Office/Workroom - (24.9 SQM)	● Office (6)	
B00B - R1034 - Special Programs Room - (50.81 SQM)	● Student Space (23)	
B00B - R1036 - Staff Kitchen - (9.2 SQM)	● Office (2)	
B00B - R1039 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R1040 - Movement - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R1045 - Tiered Learning Space - (30.31 SQM)	● Student Space (14)	
B00B - R2001 - Home Base - (57.7 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R2003 - Withdrawal Space - 1hb - (7.01 SQM)	● Student Space (3)	
B00B - R2004 - Home Base - (57.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R2006 - Withdrawal Space - 1hb - (7.01 SQM)	● Student Space (3)	
B00B - R2007 - Practical Activities - (26.88 SQM)	● Student Space (12)	
B00B - R2008 - Home Base - (59.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R2010 - Withdrawal Space - 1hb - (7.01 SQM)	● Student Space (3)	
B00B - R2011 - Home Base - (57.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R2013 - Withdrawal Space - 1hb - (5.77 SQM)	● Student Space (2)	
B00B - R2014 - Home Base - (57.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R2016 - Withdrawal Space - 1hb - (7.05 SQM)	● Student Space (3)	
B00B - R2017 - Practical Activities - (26.71 SQM)	● Student Space (12)	
B00B - R2018 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R2020 - Withdrawal Space - 1hb - (6.97 SQM)	● Student Space (3)	
B00B - R2021 - Movement - (191.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R2022 - Reading Area - (109.22 SQM)	● Student Space (50)	
B00B - R2032 - Special Programs Room - (53.24 SQM)	● Student Space (24)	
B00B - R2033 - Special Programs Room - (51.07 SQM)	● Student Space (23)	
B00B - R2043 - Tiered Learning Space - (33.74 SQM)	● Student Space (15)	
B00B - R2045 - Movement - (8.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R2046 - Movement - (12.14 SQM)	Not Applicable	Circulation or storage space.
OS 602 10097 - OS 602 10097 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11426 - OS 602 11426 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11474 - OS 602 11474 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11501 - OS 602 11501 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11518 - OS 602 11518 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12379 - OS 602 12379 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	