

VENTILATION AUDIT REPORT

SCHOOL:	Wentworthville Public School (3423)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Granville
LOCAL GOVERNMENT AREA:	Cumberland

3423 - Wentworthville Public School
Site Plan (11715)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (67.5 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0002 - Home Base - (50.78 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0006 - Movement - (15.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Withdrawal Space - 2hb - (47.25 SQM)	● Student Space (21)	
B00A - R0008 - Home Base - (49.34 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0009 - Home Base - (47.54 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0010 - Home Base - (51.14 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0012 - Staff Room Annexe - (18.55 SQM)	● Office (4)	
B00A - R0014 - Movement - (130.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (7.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Raised Platform - (28.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Communal Space - (147.07 SQM)	● Student Space (68)	
B00A - R0018 - Movement - (14.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (6.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (56.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (7.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Canteen - (26.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (101.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Home Base - (65.26 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0034 - Home Base - (63.92 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0035 - Home Base - (66.32 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0039 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Withdrawal Space - 1hb - (38.86 SQM)	● Student Space (18)	
B00A - R0042 - Movement - (10.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Withdrawal Space - 2hb - (15.44 SQM)	● Student Space (7)	
B00A - R0046 - Practical Activities - 1hb - (6.5 SQM)	● Student Space (3)	
B00A - R0047 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (21.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Movement - (20.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Movement - (83.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (69.59 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1007 - Movement - (17.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Movement - (16.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Home Base - (51.47 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R9001 - Movement - (11.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (45.37 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0003 - Withdrawal Space - 2hb - (45.24 SQM)	● Student Space (20)	
B00B - R0004 - Home Base - (45.47 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0005 - Movement - (39.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (45.3 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0009 - Home Base - (45.3 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0010 - Home Base - (47.21 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0011 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (35.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (30.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (24.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Home Base - (56.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Home Base - (52.9 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0005 - Movement - (21.6 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Special Programs Room - (54.25 SQM)	● Student Space (25)	
B00D - R0005 - Movement - (17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Reading Area - (168.8 SQM)	● Student Space (78)	
B00E - R0008 - Movement - (88.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Entry Vestibule - (23.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (55.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Clerical Office - (27.08 SQM)	● Office (6)	
B00F - R0004 - Duplicating Workroom - (23.83 SQM)	● Office (5)	
B00F - R0005 - Sick Bay - (9.05 SQM)	● Student Space (4)	
B00F - R0009 - Interview - (15.72 SQM)	● Office (3)	
B00F - R0011 - Staff Room Annexe - (19.28 SQM)	● Office (4)	
B00F - R0012 - Staff Room - (40.73 SQM)	● Office (10)	
B00F - R0013 - Staff Kitchen - (7.86 SQM)	● Office (1)	
B00F - R0016 - Deputy Principal - (12.67 SQM)	● Office (3)	
B00F - R0017 - Principal - (17.2 SQM)	● Office (4)	
B00F - R0018 - Interview - (13.16 SQM)	● Office (3)	
NS 100 13226 - NS 100 13226 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 13442 - NS 100 13442 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 602 10216 - OS 602 10216 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10276 - OS 602 10276 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10338 - OS 602 10338 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10487 - OS 602 10487 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13960 - OS 602 13960 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14058 - OS 602 14058 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15330 - OS 602 15330 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19703 - OS 602 19703 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19704 - OS 602 19704 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10640 - OS 603 10640 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 14370 - OS 603 14370 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 612 19423 - OS 612 19423 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19474 - OS 612 19474 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19532 - OS 612 19532 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19706 - OS 612 19706 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 750 17722 - OS 750 17722 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 750 18311 - OS 750 18311 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 801 16329 - OS 801 16329 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.