


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>West Wallsend Public School (3358)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Cessnock</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

3358 - West Wallsend Public School  
Site Plan (13455)




1:623

Printed: 30-May-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0002 - Movement - (38.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Home Base - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0004 - Home Base - (51.57 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0008 - Movement - (54.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Interview - (14.68 SQM)	● Office (3)	
B00A - R0014 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Home Base - (55.16 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0018 - Clerical Office - (27.39 SQM)	● Office (6)	
B00A - R0019 - Home Base - (57.29 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0020 - Deputy Principal - (11.65 SQM)	● Office (2)	
B00A - R0022 - Movement - (38.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (15.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Principal - (19.9 SQM)	● Office (4)	
B00A - R0025 - Sick Bay - (7.28 SQM)	● Student Space (3)	
B00A - R0026 - Clerical Office - (10.61 SQM)	● Office (2)	
B00A - R0027 - Clerical Office - (11.3 SQM)	● Office (2)	
B00A - R0028 - Entry Vestibule - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (75.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Home Base - (86.71 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R0032 - Home Base - (80.55 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R9001 - Raised Platform - (17.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R9002 - Communal Space - (109.73 SQM)	● Student Space (50)	
B00A - R9003 - Canteen - (26.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R9007 - Movement - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R9009 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R9011 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (8.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (10.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Staff Room Annexe - (21.99 SQM)	● Office (5)	
B00B - R0011 - Communal Space - (102.18 SQM)	● Student Space (47)	
B00B - R0017 - Movement - (25.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Home Base - (58.08 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0022 - Practical Activities - 1hb - (5.78 SQM)	● Student Space (2)	
B00B - R0023 - Home Base - (58.1 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0024 - Practical Activities - 1hb - (5.4 SQM)	● Student Space (2)	
B00B - R0025 - Home Base - (60.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0026 - Special Programs Room - (5.38 SQM)	● Student Space (2)	
B00B - R0027 - Home Base - (61.01 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0002 - Movement - (40.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (31.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Withdrawal Space - 1hb - (19.78 SQM)	● Student Space (9)	
B00E - R0003 - Interview - (15.74 SQM)	● Office (3)	
B00E - R0004 - Interview - (16.45 SQM)	● Office (4)	
B00E - R0006 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Staff Kitchen - (15.05 SQM)	● Office (3)	
B00E - R0009 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Staff Room - (23.67 SQM)	● Office (5)	
B00E - R0013 - Staff Room Annexe - (17.61 SQM)	● Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0014 - Movement - (21.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Reading Area - (166.31 SQM)	 Student Space (77)	