


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>West Wyalong High School (8392)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bland</b>



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (15.18 SQM)	Office (3)	
B00A - R0002 - Clinic - Boys - (8.74 SQM)	Office (2)	
B00A - R0007 - Staff Study - (16.71 SQM)	Office (4)	
B00A - R0008 - Interview/Office - Type 1 - (9.31 SQM)	Office (2)	
B00A - R0009 - Deputy Principal Office - (12.4 SQM)	Office (3)	
B00A - R0010 - Principal Office - (17.9 SQM)	Office (4)	
B00A - R0012 - Movement - (51.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (31.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Preparation - (16.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Laboratory L.S. - (92.5 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0017 - Laboratory L.S. - (79.16 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0018 - Preparation - (17.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (51.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Administration - Clerical - (31.61 SQM)	Office (7)	
B00B - R0006 - Design L.S. - (65.74 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0010 - Staff Study - (18.77 SQM)	Office (4)	
B00B - R0014 - Movement - (51.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (23.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Staff Study - (12.75 SQM)	Office (3)	
B00B - R0018 - Staff Study - (12.79 SQM)	Office (3)	
B00B - R0019 - Staff Study - (25.85 SQM)	Office (6)	
B00B - R0021 - Commonroom - (85.1 SQM)	Office (21)	
B00B - R0023 - General Learning Space - (39.29 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0025 - Movement - (48.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Food Technology L.S. - (77.87 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0027 - Preparation - Materials - (11.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - General Learning Space - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0007 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - Seminar - Type 1 - (19.43 SQM)	Office (4)	
B00C - R0010 - Staff Study - (38.04 SQM)	Office (9)	
B00C - R0012 - Movement - (23.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0014 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0015 - General Learning Space - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0016 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0018 - Movement - (48.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (58.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Student Canteen - (44.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Darkroom Space - (9.43 SQM)	Office (2)	
B00E - R0001 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Laboratory L.S. - (96.81 SQM) - Teaching Space: 1	Student Space (44)	
B00E - R0004 - Preparation - (49.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Laboratory L.S. - (96.92 SQM) - Teaching Space: 1	Student Space (44)	
B00E - R0006 - Movement - (57.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (17.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (29.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Staff Study - (11.62 SQM)	Office (2)	
B00G - R0004 - Staff Study - (26 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Ancillary Staff - (25.24 SQM)	Office (6)	
B00G - R0006 - Senior Study - (25.35 SQM)	Office (6)	
B00G - R0007 - Senior Study - (76.35 SQM)	Office (19)	
B00G - R0010 - Movement - (53.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (11.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Computer Learning Space - (51.42 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0003 - Staff Study - (25.21 SQM)	Office (6)	
B00H - R0004 - General Learning Space - (51.06 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0005 - General Learning Space - (51.15 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0006 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0007 - Movement - (140.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (11.83 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Materials Technology L.S. - (121.23 SQM) - Teaching Space: 1	Student Space (56)	
B00I - R0003 - Welding Area - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Welding Area - (5.47 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Computer Learning Space - (31.39 SQM) - Teaching Space: 1	Student Space (14)	
B00I - R0006 - Music Learning Space - (74 SQM) - Teaching Space: 1	Student Space (34)	
B00I - R0007 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Movement - (40.83 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Darkroom Space - (5.69 SQM)	Office (1)	
B00J - R0003 - Workshop - (64.28 SQM)	Student Space (29)	
B00J - R0004 - Workshop - (67.2 SQM)	Student Space (31)	
B00J - R0006 - Art Learning Space - (64.14 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R0008 - Materials Technology L.S. - (95.99 SQM) - Teaching Space: 1	Student Space (44)	
B00J - R0011 - Movement - (69.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (60.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Outdoor Workshop - (79.15 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Entry - (29 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Workroom - (12.82 SQM)	Office (3)	
B00K - R0007 - Workroom - (13.18 SQM)	Office (3)	
B00K - R0008 - Audio Visual Workroom - (26.26 SQM)	Student Space (12)	
B00K - R0009 - Main Area - (161.54 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Seminar - (52.8 SQM)	Office (13)	
B00K - R0012 - Duplicating Workroom - (19.88 SQM)	Office (4)	
B00L - R0002 - Staff Study - (11.63 SQM)	Office (2)	
B00L - R0004 - Staff Kitchen - (15.06 SQM)	Office (3)	
B00L - R0005 - Multi-Purpose Space - (460.54 SQM)	Student Space (213)	
B00L - R0009 - Movement - (63.86 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Stage - (60.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Movement - (238.13 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Assistants - (31.44 SQM)	Office (7)	
B00N - R0001 - General Learning Space - (53.42 SQM) - Teaching Space: 1	Student Space (24)	