

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Westdale Public School (3428)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Tamworth</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tamworth</b>

3428 - Westdale Public School  
Site Plan (12448)



Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Communal Space - (167.98 SQM)	● Student Space (77)	
B00A - R0007 - Raised Platform - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Outdoor Learning Area - (233 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Canteen - (27.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Reading Area - (162.63 SQM)	● Student Space (75)	
B00B - R0005 - Movement - (91.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Special Programs Room - (33.14 SQM)	● Student Space (15)	
B00C - R0003 - Practical Activities - 1hb - (23.77 SQM)	● Student Space (11)	
B00C - R0004 - Home Base - (54.54 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0005 - Withdrawal Space - 1hb - (10.62 SQM)	● Student Space (4)	
B00C - R0006 - Movement - (79.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (12.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Practical Activities - M - 1hb - (23.7 SQM)	● Student Space (10)	
B00C - R0014 - Home Base - M - (54.54 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0001 - Movement - (87.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Staff Room Annexe - (19.91 SQM)	● Office (4)	
B00D - R0004 - Staff Room - (46.33 SQM)	● Office (11)	
B00D - R0005 - Deputy Principal - (13.11 SQM)	● Office (3)	
B00D - R0006 - Deputy Principal - (13.1 SQM)	● Office (3)	
B00D - R0007 - Interview - (11.97 SQM)	● Office (2)	
B00D - R0009 - Sick Bay - (8.57 SQM)	● Student Space (3)	
B00D - R0010 - Clerical Office - (17.64 SQM)	● Office (4)	
B00D - R0011 - Entry Vestibule - (15.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Duplicating Workroom - (20.12 SQM)	● Office (5)	
B00D - R0013 - Principal - (16.83 SQM)	● Office (4)	
B00D - R0019 - Movement - (29.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (54.49 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0006 - Withdrawal Space - 1hb - (10.62 SQM)	● Student Space (4)	
B00E - R0007 - Home Base - (54.5 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0009 - Practical Activities - 1hb - (23.77 SQM)	● Student Space (11)	
B00E - R0013 - Home Base - (54.49 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0014 - Practical Activities - 1hb - (23.77 SQM)	● Student Space (11)	
B00E - R0015 - Withdrawal Space - 1hb - (10.61 SQM)	● Student Space (4)	
B00E - R0016 - Home Base - (54.5 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0017 - Practical Activities - 1hb - (23.81 SQM)	● Student Space (11)	
B00E - R0020 - Practical Activities - 1hb - (20.35 SQM)	● Student Space (9)	
B00F - R0001 - Movement - (130.35 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (23.78 SQM)	● Student Space (11)	
B00F - R0005 - Home Base - (54.51 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0006 - Withdrawal Space - 1hb - (10.62 SQM)	● Student Space (4)	
B00F - R0007 - Home Base - (54.5 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0008 - Practical Activities - 1hb - (23.78 SQM)	● Student Space (11)	
B00F - R0013 - Home Base - (54.49 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0014 - Practical Activities - 1hb - (23.77 SQM)	● Student Space (11)	
B00F - R0015 - Withdrawal Space - 1hb - (10.61 SQM)	● Student Space (4)	
B00F - R0016 - Home Base - (54.49 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0018 - Practical Activities - 1hb - (23.77 SQM)	● Student Space (11)	
B00F - R0022 - Movement - (14.6 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Practical Activities - 1hb - (6.28 SQM)	● Student Space (2)	
B00G - R0002 - Home Base - (66.91 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0003 - Home Base - (53.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0004 - Staff Room Annexe - (13.45 SQM)	● Office (3)	
B00G - R0006 - Movement - (42.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (53.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Practical Activities - 1hb - (11.03 SQM)	● Student Space (5)	
B00G - R0009 - Withdrawal Space - 1hb - (11.36 SQM)	● Student Space (5)	
B00G - R0011 - Movement - (20.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (20.98 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (29.19 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Staff Kitchen - (10.54 SQM)	● Office (2)	
B00I - R0005 - Staff Room - (14.52 SQM)	● Office (3)	
B00I - R0006 - Withdrawal Space - 1hb - (10.64 SQM)	● Student Space (4)	
B00I - R0007 - Withdrawal Space - 1hb - (10.64 SQM)	● Student Space (4)	
B00I - R0008 - Staff Room - (10.8 SQM)	● Office (2)	
B00K - R0001 - Special Programs Room - (95.28 SQM)	● Student Space (44)	
B00L - R0004 - Special Programs Room - Type 1 - (38.43 SQM)	● Student Space (17)	
B00L - R0007 - Practical Activities - 1hb - (18.89 SQM)	● Student Space (8)	
B00L - R0008 - Home Base - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0009 - Withdrawal Space - 2hb - (11.56 SQM)	● Student Space (5)	
B00L - R0010 - Home Base - (61.01 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0011 - Practical Activities - 1hb - (18.93 SQM)	● Student Space (8)	
B00M - R0001 - Canteen - (27.39 SQM)	Not Applicable	Circulation or storage space.
OS 602 14156 - OS 602 14156 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14679 - OS 602 14679 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15921 - OS 602 15921 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10915 - OS 603 10915 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 12273 - OS 603 12273 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 14339 - OS 603 14339 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 18090 - OS 606 18090 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	