

VENTILATION AUDIT REPORT

SCHOOL:	Westfields Sports High School (8384)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Fairfield
LOCAL GOVERNMENT AREA:	Fairfield

8384 - Westfields Sports High School
Site Plan (11393)



1:1,367

Printed: 14-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Interview/Office - Type 1 - (13.54 SQM)	Office (3)	
B00A - R0005 - Interview/Office - Type 1 - (13.6 SQM)	Office (3)	
B00A - R0006 - Leading Teacher - (13.76 SQM)	Office (3)	
B00A - R0012 - Principal Office - (20.17 SQM)	Office (5)	
B00A - R0013 - Tea Room - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Public Reception - (80.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Administration - Clerical - (128.62 SQM)	Office (32)	
B00A - R0016 - Ancillary Staff - (12.4 SQM)	Office (3)	
B00A - R0018 - Clinic - (12.8 SQM)	Office (3)	
B00A - R0019 - Deputy Principal Office - (12.6 SQM)	Office (3)	
B00A - R0020 - Deputy Principal Office - (12.66 SQM)	Office (3)	
B00A - R0021 - Deputy Principal Office - (12.64 SQM)	Office (3)	
B00A - R0022 - Interview/Office - Type 1 - (12.31 SQM)	Office (3)	
B00A - R0023 - Student Reception - (52.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - General Learning Space - (66.19 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1005 - General Learning Space - (60.96 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1006 - General Learning Space - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1007 - Senior Study - (24.47 SQM)	Office (6)	
B00A - R1008 - General Learning Space - (61.2 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1009 - General Learning Space - (67.29 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1010 - Practical Activity Area - (6.93 SQM)	Student Space (3)	
B00A - R1011 - Movement - (75.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - General Learning Space - (46.79 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0001 - Movement - (64.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0040 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0041 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0042 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0043 - Computer Learning Space - (65.64 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0045 - Senior Seminar - (25.92 SQM)	Office (6)	
B00B - R0046 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0047 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0048 - Senior Seminar - (25.03 SQM)	Office (6)	
B00B - R0049 - General Learning Space - (61.67 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0058 - Movement - (109.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - General Learning Space - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1008 - Seminar - (25.89 SQM)	Office (6)	
B00B - R1009 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1021 - Senior Seminar - (23.31 SQM)	Office (5)	
B00B - R1022 - Staff Study - (23.4 SQM)	Office (5)	
B00B - R1023 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1024 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1025 - General Learning Space - (65.81 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1026 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1027 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1028 - General Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1033 - Movement - (118.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Laboratory L.S. - (86.41 SQM) - Teaching Space: 1	Student Space (40)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0004 - Laboratory L.S. - (86.31 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0009 - Computer Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0010 - General Learning Space - (50.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0011 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0012 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0013 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0021 - Preparation - Science - (38.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (37.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Movement - (62.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - Movement - (18.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - Interview/Office - Type 1 - (16.06 SQM)	● Office (4)	
B00C - R1018 - Interview/Office - Type 1 - (15.8 SQM)	● Office (3)	
B00C - R1026 - Movement - (52.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R1030 - Movement - (7.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R1037 - Staff Study - (273.3 SQM)	● Office (68)	
B00C - R1039 - Commonroom - (118.39 SQM)	● Office (29)	
B00C - R1040 - Tea Room - (10.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R1041 - Staff Study - (121.76 SQM)	● Office (30)	
B00C - R1043 - Movement - (8.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Movement - (18.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Design/Technology L.S. - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0031 - Food Technology L.S. - (98.5 SQM) - Teaching Space: 1	● Student Space (45)	
B00D - R0032 - Computer Learning Space - (60.78 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0033 - Seminar/Study - (26.4 SQM)	● Office (6)	
B00D - R0035 - Design/Technology L.S. - (52.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0039 - General Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0048 - Movement - (45.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0051 - Preparation - (20.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0053 - Kitchen - Type 1 - (119.33 SQM)	● Student Space (55)	
B00D - R0054 - Tea Room - (33.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1013 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1015 - General Learning Space - (66.12 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1021 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1022 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1026 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1027 - General Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1031 - Senior Study - (25.37 SQM)	● Office (6)	
B00D - R1034 - General Learning Space - (52.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1035 - Movement - (109.52 SQM)	Not Applicable	Circulation or storage space.
B00E - M1002 - Computer Room - (37.11 SQM)	● Student Space (17)	
B00E - M1009 - Movement - (13.87 SQM)	Not Applicable	Circulation or storage space.
B00E - M1010 - Seminar/Study - (15.21 SQM)	● Office (3)	
B00E - M1011 - Seminar/Study - (10.33 SQM)	● Office (2)	
B00E - M1012 - Seminar/Study - (10.25 SQM)	● Office (2)	
B00E - M1013 - Seminar/Study - (15.23 SQM)	● Office (3)	
B00E - R0001 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	● Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0002 - Preparation - Science - (44.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Laboratory L.S. - (91.34 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0007 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0008 - Preparation - Science - (44.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0011 - Movement - (40.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Audio Visual Workroom - (27.83 SQM)	● Student Space (12)	
B00E - R1007 - Seminar - (24.98 SQM)	○ Office (6)	
B00E - R1011 - Interview/Office - Type 1 - (12.09 SQM)	○ Office (3)	
B00E - R1012 - Interview/Office - Type 1 - (12.68 SQM)	○ Office (3)	
B00E - R1013 - General Learning Space - (69.08 SQM) - Teaching Space: 1	● Student Space (32)	
B00E - R1022 - Main Entry - (34.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R1023 - Main Area - (287.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R1025 - Staff Kitchen - (12.43 SQM)	○ Office (3)	
B00F - R0001 - Tiered Learning Area - (67.56 SQM)	● Student Space (31)	
B00G - R0001 - General Learning Space - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0002 - Art Learning Space - (59.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Art Learning Space - (50.77 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0006 - General Learning Space - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0007 - General Learning Space - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1001 - Music Learning Space - (89.54 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R1004 - Music Learning Space - (59.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1008 - General Learning Space - (60.03 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1017 - Practice/Seminar - (27.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R1019 - Computer Learning Space - (37.49 SQM) - Teaching Space: 1	● Student Space (17)	
B00G - R1021 - General Learning Space - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1024 - Dark Room - (30.1 SQM)	○ Office (7)	
B00H - R0002 - Gymnasium - (818.56 SQM)	● Student Space (379)	
B00H - R0004 - Movement - (7.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0021 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Commonroom - (22.52 SQM)	○ Office (5)	
B00H - R0025 - Interview/Office - Type 1 - (10.27 SQM)	○ Office (2)	
B00H - R0032 - Seminar - (38.08 SQM)	○ Office (9)	
B00I - R0011 - Movement - (7.15 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Outdoor Learning Area - (146.36 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Gymnasium - (305.82 SQM)	● Student Space (141)	
B00I - R0018 - Movement Studio - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00J - R0024 - General Assistants - (15.01 SQM)	○ Office (3)	
B00J - R0025 - Materials Workshop - Type 3 - (60.79 SQM)	● Student Space (28)	
B00J - R0026 - Materials Technology L.S. - (60.19 SQM)	● Student Space (27)	
B00J - R0027 - Computer Learning Space - (65.68 SQM)	● Student Space (30)	
B00J - R0029 - Materials Technology L.S. - (103.39 SQM)	● Student Space (47)	
B00J - R0030 - Movement - (94.66 SQM)	Not Applicable	Circulation or storage space.
B00J - R0031 - Movement - (24.01 SQM)	Not Applicable	Circulation or storage space.
B00J - R0033 - Wood Technology L.S. - (99.66 SQM)	● Student Space (46)	
B00J - R0035 - Wood Technology Bay - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00J - R0036 - Wood Technology L.S. - (98.95 SQM)	● Student Space (45)	
B00J - R0037 - Senior Study - (26.51 SQM)	○ Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0038 - Movement - (22.55 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Student Canteen - (49.18 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Movement Studio - (104.71 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Movement - (12.04 SQM)	Not Applicable	Circulation or storage space.
B00K - R0024 - Movement - (235.32 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Performance Workshop - (154.69 SQM)	● Student Space (71)	
B00K - R1002 - Movement Studio - (154.81 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Movement - (41.98 SQM)	Not Applicable	Circulation or storage space.
B00L - R0011 - Gymnasium - (1360.58 SQM)	● Student Space (631)	
B00L - R0022 - Staff Study - (49.22 SQM)	● Office (12)	
B00L - R0023 - Tea Room - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Learning Space - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0002 - General Learning Space - (58.55 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0004 - General Learning Space - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0009 - Movement - (17.8 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - General Learning Space - (58.41 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R1002 - General Learning Space - (58.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1003 - Movement - (19.44 SQM)	Not Applicable	Circulation or storage space.
B00M - R1004 - General Learning Space - (57.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00P - R0004 - Movement - (5.25 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Hydrotherapy - Spa - (11.5 SQM)	Not Applicable	Circulation or storage space.
B00P - R0009 - Movement - (11.76 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Multi-Purpose Space - (351.08 SQM)	● Student Space (162)	
B00S - R0011 - Movement - (20.22 SQM)	Not Applicable	Circulation or storage space.
B00S - R0013 - Movement - (24.49 SQM)	Not Applicable	Circulation or storage space.
B00S - R0020 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B00S - R1001 - General Learning Space - (65.75 SQM) - Teaching Space: 1	● Student Space (30)	
B00S - R1002 - General Learning Space - (65.32 SQM) - Teaching Space: 1	● Student Space (30)	
B00S - R1003 - Shared Learning Space - (82.69 SQM)	● Student Space (38)	
B00S - R1004 - Staff Study - (56.21 SQM)	● Office (14)	
B00S - R1007 - General Learning Space - (60.03 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R1008 - General Learning Space - (64.26 SQM) - Teaching Space: 1	● Student Space (29)	
B00S - R1009 - Seminar - (28.36 SQM)	● Office (7)	
B00S - R1016 - General Learning Space - (61.72 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R1017 - Staff Study - (26.71 SQM)	● Office (6)	
B00S - R1018 - Welding Area - (41.4 SQM)	Not Applicable	Circulation or storage space.
B00S - R1019 - Movement - (50.79 SQM)	Not Applicable	Circulation or storage space.
B00S - R1022 - Metal Technology Bay - (117.12 SQM)	Not Applicable	Circulation or storage space.
B00S - R1023 - General Learning Space - (58.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R1024 - General Learning Space - (59.55 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R1025 - General Learning Space - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R1030 - Movement - (75.66 SQM)	Not Applicable	Circulation or storage space.
B00S - R1032 - Movement - (129.71 SQM)	Not Applicable	Circulation or storage space.
B00S - R1034 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00S - R1035 - Movement - (52.28 SQM)	Not Applicable	Circulation or storage space.
B00S - R1038 - Welding Area - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00S - R1039 - Welding Area - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00S - R2001 - General Learning Space - (65.64 SQM) - Teaching Space: 1	● Student Space (30)	
B00S - R2002 - General Learning Space - (66.25 SQM) - Teaching Space: 1	● Student Space (30)	
B00S - R2003 - Shared Learning Space - (84.26 SQM)	● Student Space (39)	
B00S - R2004 - General Learning Space - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R2008 - General Learning Space - (59.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R2009 - General Learning Space - (64.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00S - R2010 - Seminar - (28.69 SQM)	○ Office (7)	
B00S - R2017 - Seminar - (25.24 SQM)	○ Office (6)	
B00S - R2018 - General Learning Space - (73.02 SQM) - Teaching Space: 1	● Student Space (33)	
B00S - R2019 - General Learning Space - (66.68 SQM) - Teaching Space: 1	● Student Space (30)	
B00S - R2020 - Staff Study - (36.89 SQM)	○ Office (9)	
B00S - R2023 - Movement - (38.01 SQM)	Not Applicable	Circulation or storage space.
B00S - R2024 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00S - R2025 - Movement - (135.04 SQM)	Not Applicable	Circulation or storage space.
B00S - R2027 - Movement - (66.72 SQM)	Not Applicable	Circulation or storage space.
B00S - R3001 - Staff Study - (191.89 SQM)	○ Office (47)	
B00S - R3002 - Staff Lounge - (63.79 SQM)	○ Office (15)	
B00S - R3007 - General Learning Space - (60.78 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R3008 - General Learning Space - (64.86 SQM) - Teaching Space: 1	● Student Space (30)	
B00S - R3009 - Seminar - (28.27 SQM)	○ Office (7)	
B00S - R3016 - Staff Lounge - (41.21 SQM)	○ Office (10)	
B00S - R3020 - Movement - (58.1 SQM)	Not Applicable	Circulation or storage space.
B00S - R3021 - Movement - (114.82 SQM)	Not Applicable	Circulation or storage space.
B00S - R3022 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00S - R9001 - General Learning Space - (67.85 SQM) - Teaching Space: 1	● Student Space (31)	
B00S - R9003 - Staff Study - (19.95 SQM)	○ Office (4)	
B00S - R9004 - General Learning Space - (64.6 SQM) - Teaching Space: 1	● Student Space (29)	
B00S - R9006 - Wood Technology Bay - (117.53 SQM)	Not Applicable	Circulation or storage space.
B00S - R9007 - Wood Technology Bay - (117.53 SQM)	Not Applicable	Circulation or storage space.
B00S - R9010 - Wood Technology Bay - (123.65 SQM)	Not Applicable	Circulation or storage space.
B00S - R9011 - Wood Technology Bay - (125.89 SQM)	Not Applicable	Circulation or storage space.
B00S - R9014 - Movement - (114.09 SQM)	Not Applicable	Circulation or storage space.
OS 600 10608 - OS 600 10608 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 10817 - OS 600 10817 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11708 - OS 600 11708 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 13989 - OS 600 13989 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15189 - OS 600 15189 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 10705 - OS 601 10705 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11561 - OS 601 11561 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12845 - OS 601 12845 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 12199 - OS 720 12199 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 10924 - OS 760 10924 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 13375 - OS 760 13375 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 15010 - OS 760 15010 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 770 14451 - OS 770 14451 - Technics - Metalwork/Heat Area/Store - (76 SQM)	Not Applicable	Circulation or storage space.